



# Trinidad RC Lead in Water Test Results

## FY26 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011874	2/26/2026	2/26/2027	1	Cooler	In hallway adjacent to reception desk	High Left	WF-02262026-011874	4/7/2026	FT-FY26-03262026-011874-A	<2	FT-FY26-03262026-011874-B	<2
WS- 011875	2/26/2026	2/26/2027	1	Cooler	In hallway adjacent to reception desk	Low Right	WF-02262026-011875	4/7/2026	FT-FY26-03262026-011875-A	<2	FT-FY26-03262026-011875-B	<2
WS- 011876	2/26/2026	2/26/2027	1	Cooler	In hallway across from gym 100	Low Right	WF-02262026-011876	4/7/2026	FT-FY26-03262026-011876-A	<2	FT-FY26-03262026-011876-B	<2
WS- 011878	11/18/2025	11/18/2026	1	Food Prep Sink	In pantry room 125		WF-11182025-011878	4/7/2026	FT-FY26-03262026-011878-A	<2	FT-FY26-03262026-011878-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.