



Trinidad RC Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011875	6/16/17	6/16/18	1	Cooler	In hallway adjacent to reception desk Right Low	WF-62017-011875	2/15/18	FT-FY18--62017-011875-A	<1	FT-FY18--62017-011875-B	<1
WS-011877	6/16/17	6/16/18	1	Cooler	In hallway across from gym 100 Left High	WF-62017-011877	2/15/18	FT-FY18--62017-011877-A	<1	FT-FY18--62017-011877-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011878	6/16/17	6/16/18	1	Food Prep Sink	In pantry room 125	WF-62017-011878	2/15/18	FT-FY18--62017-011878-A	<1	FT-FY18--62017-011878-B	<1