



TRUESDELL EC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	TRUESDELL EDUCATIONAL CAMPUS	WS- 001000	8/19/2016	Basement	Cooler	Annex, in hallway adjacent to room 013	FT-82016-001000-A	< 1	FT-82016-001000-B	< 1
2	TRUESDELL EDUCATIONAL CAMPUS	WS- 001001	8/19/2016	Basement	Health Suite	Annex, in health suite 011	FT-82016-001001-A	< 1	FT-82016-001001-B	< 1
3	TRUESDELL EDUCATIONAL CAMPUS	WS- 001002	8/19/2016	Basement	Fountain	Annex, in health suite 011	FT-82016-001002-A	< 1	FT-82016-001002-B	< 1
4	TRUESDELL EDUCATIONAL CAMPUS	WS- 001003	8/19/2016	1	Cooler	Annex, in hallway adjacent to room 130	FT-82016-001003-A	< 1	FT-82016-001003-B	< 1
5	TRUESDELL EDUCATIONAL CAMPUS	WS- 001004	8/19/2016	1	Cooler	Annex, in hallway adjacent to room 117	FT-82016-001004-A	< 1	FT-82016-001004-B	< 1
6	TRUESDELL EDUCATIONAL CAMPUS	WS- 001005	8/19/2016	2	Cooler	Annex, in hallway adjacent to room 218	FT-82016-001005-A	< 1	FT-82016-001005-B	< 1
7	TRUESDELL EDUCATIONAL CAMPUS	WS- 001006	8/19/2016	2	Cooler	Annex, in hallway adjacent to staff restroom 226	FT-82016-001006-A	< 1	FT-82016-001006-B	< 1
8	TRUESDELL EDUCATIONAL CAMPUS	WS- 001008	8/19/2016	1	Cooler	In hallway adjacent to operations office	FT-82016-001008-A	< 1	FT-82016-001008-B	< 1
9	TRUESDELL EDUCATIONAL CAMPUS	WS- 001009	8/19/2016	1	Cooler	In hallway adjacent to custodians' office	FT-82016-001009-A	< 1	FT-82016-001009-B	< 1
10	TRUESDELL EDUCATIONAL CAMPUS	WS- 001011	8/19/2016	1	Fountain	In classroom 100	Right FT-82016-001011-A	< 1	FT-82016-001011-B	< 1
11	TRUESDELL EDUCATIONAL CAMPUS	WS- 001012	8/19/2016	1	Fountain	In classroom 101	Right FT-82016-001012-A	< 1	FT-82016-001012-B	< 1
12	TRUESDELL EDUCATIONAL CAMPUS	WS- 001014	8/19/2016	2	Cooler	In hallway adjacent to room 200	FT-82016-001014-A	< 1	FT-82016-001014-B	< 1
13	TRUESDELL EDUCATIONAL CAMPUS	WS- 001015	8/19/2016	2	Cooler	In hallway adjacent to room 212	FT-82016-001015-A	< 1	FT-82016-001015-B	< 1
14	TRUESDELL EDUCATIONAL CAMPUS	WS- 001017	8/19/2016	2	Fountain	In classroom 200	Right FT-82016-001017-A	< 1	FT-82016-001017-B	< 1
15	TRUESDELL EDUCATIONAL CAMPUS	WS- 001018	8/19/2016	2	Fountain	In classroom 201	Right FT-82016-001018-A	< 1	FT-82016-001018-B	< 1
16	TRUESDELL EDUCATIONAL CAMPUS	WS- 001020	8/19/2016	2	Fountain	In classroom 217	Right FT-82016-001020-A	< 1	FT-82016-001020-B	< 1
17	TRUESDELL EDUCATIONAL CAMPUS	WS- 001022	8/19/2016	2	Fountain	In classroom 216	Right FT-82016-001022-A	< 1	FT-82016-001022-B	< 1
18	TRUESDELL EDUCATIONAL CAMPUS	WS- 001024	8/19/2016	3	Cooler	In hallway adjacent to room 308	FT-82016-001024-A	< 1	FT-82016-001024-B	< 1
19	TRUESDELL EDUCATIONAL CAMPUS	WS- 001025	8/19/2016	3	Cooler	In hallway adjacent to room 300	FT-82016-001025-A	< 1	FT-82016-001025-B	< 1
20	TRUESDELL EDUCATIONAL CAMPUS	WS- 001027	8/19/2016	1	Food Prep Sink	In kitchen room 110	Right FT-82016-001027-A	< 1	FT-82016-001027-B	< 1