



Truesdell EC Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000990	10/23/2018	10/23/2019	1	Classroom Faucet	In classroom 103	WF-10232018-000990	12/9/2018	FT-FY19-122018-000990-A	<1	FT-FY19-122018-000990-B	<1
WS- 000991	10/23/2018	10/23/2019	1	Combo Faucet	In classroom 115	WF-10232018-000991	12/9/2018	FT-FY19-122018-000991-A	<1	FT-FY19-122018-000991-B	<1
WS- 000992	10/23/2018	10/23/2019	1	Combo Faucet	In classroom 114	WF-10232018-000992	12/9/2018	FT-FY19-122018-000992-A	<1	FT-FY19-122018-000992-B	<1
WS- 000993	4/23/2018	4/23/2019	1	Combo Fountain	In classroom 115	WF-04232018-000993	12/9/2018	FT-FY19-122018-000993-A	<1	FT-FY19-122018-000993-B	<1
WS- 000994	4/23/2018	4/23/2019	1	Combo Fountain	In classroom 114	WF-04232018-000994	12/9/2018	FT-FY19-122018-000994-A	<1	FT-FY19-122018-000994-B	<1
WS- 001000	4/23/2018	4/23/2019	Basement	Cooler	Annex, in hallway adjacent to room 013	WF-04232018-001000	12/9/2018	FT-FY19-122018-001000-A	<1	FT-FY19-122018-001000-B	<1
WS- 001001	4/23/2018	4/23/2019	Basement	Health Suite	Annex, in health suite 011	WF-04232018-001001	12/9/2018	FT-FY19-122018-001001-A	<1	FT-FY19-122018-001001-B	<1
WS- 001002	4/23/2018	4/23/2019	Basement	Fountain	Annex, in health suite 011	WF-04232018-001002	12/9/2018	FT-FY19-122018-001002-A	<1	FT-FY19-122018-001002-B	<1
WS- 001003	11/27/2018	11/27/2019	1	Cooler	Annex, in hallway adjacent to room 130	WF-11272018-001003	12/9/2018	FT-FY19-122018-001003-A	<1	FT-FY19-122018-001003-B	<1
WS- 001004	4/23/2018	4/23/2019	1	Cooler	Annex, in hallway adjacent to room 117	WF-04232018-001004	12/9/2018	FT-FY19-122018-001004-A	<1	FT-FY19-122018-001004-B	<1
WS- 001005	4/23/2018	4/23/2019	2	Cooler	Annex, in hallway adjacent to room 218	WF-04232018-001005	12/9/2018	FT-FY19-122018-001005-A	<1	FT-FY19-122018-001005-B	<1
WS- 001006	4/23/2018	4/23/2019	2	Cooler	Annex, in hallway adjacent to staff restroom 226	WF-04232018-001006	12/9/2018	FT-FY19-122018-001006-A	<1	FT-FY19-122018-001006-B	<1
WS- 001008	4/23/2018	4/23/2019	1	Cooler	In hallway adjacent to operations office	WF-04232018-001008	12/9/2018	FT-FY19-122018-001008-A	<1	FT-FY19-122018-001008-B	<1
WS- 001009	4/23/2018	4/23/2019	1	Cooler	In hallway adjacent to custodians' office	WF-04232018-001009	12/9/2018	FT-FY19-122018-001009-A	<1	FT-FY19-122018-001009-B	<1
WS- 001010	10/23/2018	10/23/2019	1	Combo Faucet	In classroom 100	Left WF-10232018-001010	12/9/2018	FT-FY19-122018-001010-A	<1	FT-FY19-122018-001010-B	<1
WS- 001011	4/23/2018	4/23/2019	1	Combo Fountain	In classroom 100	Right WF-04232018-001011	12/9/2018	FT-FY19-122018-001011-A	<1	FT-FY19-122018-001011-B	<1
WS- 001012	4/23/2018	4/23/2019	1	Combo Fountain	In classroom 101	Right WF-04232018-001012	12/9/2018	FT-FY19-122018-001012-A	<1	FT-FY19-122018-001012-B	<1
WS- 001013	10/23/2018	10/23/2019	1	Combo Faucet	In classroom 101	Left WF-10232018-001013	12/9/2018	FT-FY19-122018-001013-A	<1	FT-FY19-122018-001013-B	<1
WS- 001014	4/23/2018	4/23/2019	2	Cooler	In hallway adjacent to room 200	WF-04232018-001014	12/9/2018	FT-FY19-122018-001014-A	<1	FT-FY19-122018-001014-B	<1
WS- 001015	4/23/2018	4/23/2019	2	Cooler	In hallway adjacent to room 212	WF-04232018-001015	12/9/2018	FT-FY19-122018-001015-A	<1	FT-FY19-122018-001015-B	<1
WS- 001016	10/23/2018	10/23/2019	2	Combo Faucet	In classroom 200	Left WF-10232018-001016	12/9/2018	FT-FY19-122018-001016-A	<1	FT-FY19-122018-001016-B	<1
WS- 001017	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 200	Right WF-04232018-001017	12/9/2018	FT-FY19-122018-001017-A	<1	FT-FY19-122018-001017-B	<1
WS- 001018	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 201	Right WF-04232018-001018	12/9/2018	FT-FY19-122018-001018-A	<1	FT-FY19-122018-001018-B	<1
WS- 001019	10/23/2018	10/23/2019	2	Combo Faucet	In classroom 201	Left WF-10232018-001019	12/9/2018	FT-FY19-122018-001019-A	<1	FT-FY19-122018-001019-B	<1
WS- 001020	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 217	Right WF-04232018-001020	12/9/2018	FT-FY19-122018-001020-A	<1	FT-FY19-122018-001020-B	<1
WS- 001021	10/23/2018	10/23/2019	2	Combo Faucet	In classroom 217	Left WF-10232018-001021	12/9/2018	FT-FY19-122018-001021-A	<1	FT-FY19-122018-001021-B	<1
WS- 001022	4/23/2018	4/23/2019	2	Combo Fountain	In classroom 216	Right WF-04232018-001022	12/9/2018	FT-FY19-122018-001022-A	<1	FT-FY19-122018-001022-B	<1
WS- 001023	10/23/2018	10/23/2019	2	Combo Faucet	In classroom 216	Left WF-10232018-001023	12/9/2018	FT-FY19-122018-001023-A	<1	FT-FY19-122018-001023-B	<1
WS- 001024	11/27/2018	11/27/2019	3	Cooler	In hallway adjacent to room 308	WF-11272018-001024	12/9/2018	FT-FY19-122018-001024-A	<1	FT-FY19-122018-001024-B	<1
WS- 001025	4/23/2018	4/23/2019	3	Cooler	In hallway adjacent to room 300	WF-04232018-001025	12/9/2018	FT-FY19-122018-001025-A	<1	FT-FY19-122018-001025-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 001027	1	Food Prep Sink	In kitchen room 110	Right	12/9/2018	FT-FY19-122018-001027-A	<1	FT-FY19-122018-001027-B	<1