



TUBMAN ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	TUBMAN ELEMENTARY SCHOOL	WS- 002714	12/14/2016	1	Break Room	In staff lounge	FT-112016-002714-A	< 1	FT-112016-002714-B	< 1
2	TUBMAN ELEMENTARY SCHOOL	WS- 002716	12/14/2016	1	Break Room	In break room 128A	FT-112016-002716-A	< 1	FT-112016-002716-B	< 1
3	TUBMAN ELEMENTARY SCHOOL	WS- 002723	12/14/2016	1	Combo Faucet	In classroom 108	FT-122016-002723-A	< 1	FT-122016-002723-B	< 1
4	TUBMAN ELEMENTARY SCHOOL	WS- 008231	12/14/2016	1	Combo Faucet	In classroom 115	FT-122016-008231-A	< 1	FT-122016-008231-B	< 1
5	TUBMAN ELEMENTARY SCHOOL	WS- 008238	12/14/2016	1	Combo Faucet	In classroom 121	FT-122016-008238-A	< 1	FT-122016-008238-B	< 1

Greater than 1 ppb - Devices Shut Off and Corrective Action Taken										
1	TUBMAN ELEMENTARY SCHOOL	WS- 002717	12/14/2016	1	Break Room	In break room 128A	FT-112016-002717-A	21	FT-112016-002717-B	1.2
2	TUBMAN ELEMENTARY SCHOOL	WS- 002720	12/14/2016	1	Combo Faucet	In classroom 106	FT-122016-002720-A	4.2	FT-122016-002720-B	< 1
3	TUBMAN ELEMENTARY SCHOOL	WS- 002725	12/14/2016	1	Combo Faucet	In classroom 111	FT-122016-002725-A	8.4	FT-122016-002725-B	< 1
4	TUBMAN ELEMENTARY SCHOOL	WS- 003988	12/14/2016	1	Combo Faucet	In classroom 110	FT-122016-003988-A	3.4	FT-122016-003988-B	< 1
5	TUBMAN ELEMENTARY SCHOOL	WS- 003990	12/14/2016	1	Combo Faucet	In classroom 113	FT-122016-003990-A	2.4	FT-122016-003990-B	< 1
6	TUBMAN ELEMENTARY SCHOOL	WS- 008232	12/14/2016	1	Combo Faucet	In classroom 114	FT-122016-008232-A	2.8	FT-122016-008232-B	< 1
7	TUBMAN ELEMENTARY SCHOOL	WS- 008239	12/14/2016	1	Combo Faucet	In classroom 122	FT-122016-008239-A	1.1	FT-122016-008239-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Less than 1 ppb - Device Returned to Service										
1	TUBMAN ELEMENTARY SCHOOL	WS- 002717	1/25/2017	1	Break Room	In break room 128A	FT-112016-002717-A	< 1	FT-112016-002717-B	< 1

Greater than 1 ppb - Devices Remain Shut Off, Continued Remediation										
1	TUBMAN ELEMENTARY SCHOOL	WS- 002720	1/25/2017	1	Combo Faucet	In classroom 106	FT-122016-002720-A	14	FT-122016-002720-B	< 1
2	TUBMAN ELEMENTARY SCHOOL	WS- 002725	1/25/2017	1	Combo Faucet	In classroom 111	FT-122016-002725-A	9.6	FT-122016-002725-B	2.5
3	TUBMAN ELEMENTARY SCHOOL	WS- 003988	1/25/2017	1	Combo Faucet	In classroom 110	FT-122016-003988-A	3.1	FT-122016-003988-B	< 1
4	TUBMAN ELEMENTARY SCHOOL	WS- 003990	1/25/2017	1	Combo Faucet	In classroom 113	FT-122016-003990-A	8	FT-122016-003990-B	1.2
5	TUBMAN ELEMENTARY SCHOOL	WS- 008232	1/25/2017	1	Combo Faucet	In classroom 114	FT-122016-008232-A	13	FT-122016-008232-B	< 1
6	TUBMAN ELEMENTARY SCHOOL	WS- 008239	1/25/2017	1	Combo Faucet	In classroom 122	FT-122016-008239-A	4.1	FT-122016-008239-B	< 1

Second Filter Re-Test (After Device Replacement)

Less than 1 ppb - Device Returned to Service										
1	TUBMAN ELEMENTARY SCHOOL	WS- 002720	3/14/2017	1	Combo Faucet	In classroom 106	FT-122016-002720-A	< 1	FT-122016-002720-B	< 1
2	TUBMAN ELEMENTARY SCHOOL	WS- 002725	3/14/2017	1	Combo Faucet	In classroom 111	FT-122016-002725-A	< 1	FT-122016-002725-B	< 1

DCPS ECE Sink and DCPS Requested Sink Filtration

3	TUBMAN ELEMENTARY SCHOOL	WS- 003988	3/14/2017	1	Combo Faucet	In classroom 110	FT-122016-003988-A	< 1	FT-122016-003988-B	< 1
4	TUBMAN ELEMENTARY SCHOOL	WS- 003990	3/14/2017	1	Combo Faucet	In classroom 113	FT-122016-003990-A	< 1	FT-122016-003990-B	< 1

Greater than 1 ppb - Devices Remain Shut Off, Continued Remediation

1	TUBMAN ELEMENTARY SCHOOL	WS- 008232	3/14/2017	1	Combo Faucet	In classroom 114	FT-122016-008232-A	1.2	FT-122016-008232-B	< 1
2	TUBMAN ELEMENTARY SCHOOL	WS- 008239	3/14/2017	1	Combo Faucet	In classroom 122	FT-122016-008239-A	1.8	FT-122016-008239-B	< 1

Filter Re-Test (Post Consultation; After Dual Supply Faucet Installation)

Less than 5 ppb - Devices Returned to Service

1	TUBMAN ELEMENTARY SCHOOL	WS- 008232	8/11/2017	1	Combo Faucet	In classroom 114	FT-122016-008232-A	< 1	FT-122016-008232-B	< 1
2	TUBMAN ELEMENTARY SCHOOL	WS- 008239	8/11/2017	1	Combo Faucet	In classroom 122	FT-122016-008239-A	1.2	FT-122016-008239-B	< 1