



Tubman ES Lead in Water Test Results

FY27 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-016750	8/4/2026	8/4/2027	3	Combo Fountain	In room 326	WF-08042026-016750	8/21/2026	FT-FY27-08062026-016750-A	1.2	FT-FY27-08062026-016750-B	<1
WS-016752	8/4/2026	8/4/2027	3	Combo Fountain	In room 336	WF-08042026-016752	8/21/2026	FT-FY27-08062026-016752-A	<1	FT-FY27-08062026-016752-B	<1
WS-016754	8/4/2026	8/4/2027	3	Combo Fountain	In room 338	WF-08042026-016754	8/21/2026	FT-FY27-08062026-016754-A	<1	FT-FY27-08062026-016754-B	<1
WS-016755	8/4/2026	8/4/2027	1	Combo Faucet	In room 120 Low Left	WF-08042026-016755	8/21/2026	FT-FY27-08062026-016755-A	<1	FT-FY27-08062026-016755-B	<1
WS-016756	8/4/2026	8/4/2027	1	Combo Fountain	In room 120 Low Left	WF-08042026-016756	8/21/2026	FT-FY27-08062026-016756-A	<1	FT-FY27-08062026-016756-B	<1
WS-016758	8/4/2026	8/4/2027	1	Combo Fountain	In room 120 High Right	WF-08042026-016758	8/21/2026	FT-FY27-08062026-016758-A	<1	FT-FY27-08062026-016758-B	<1
WS-016760	8/4/2026	8/4/2027	2	Combo Fountain	In room 213	WF-08042026-016760	8/21/2026	FT-FY27-08062026-016760-A	<1	FT-FY27-08062026-016760-B	<1
WS-016762	8/4/2026	8/4/2027	3	Combo Fountain	In room 301 first clockwise from entry	WF-08042026-016762	8/21/2026	FT-FY27-08062026-016762-A	1.8	FT-FY27-08062026-016762-B	<1
WS-016764	8/4/2026	8/4/2027	3	Combo Fountain	In room 301 second clockwise from entry	WF-08042026-016764	8/21/2026	FT-FY27-08062026-016764-A	<1	FT-FY27-08062026-016764-B	<1
WS-016766	8/4/2026	8/4/2027	3	Combo Fountain	In room 301 third clockwise from entry	WF-08042026-016766	8/21/2026	FT-FY27-08062026-016766-A	<1	FT-FY27-08062026-016766-B	<1
WS-016768	8/4/2026	8/4/2027	3	Combo Fountain	In room 301 fourth clockwise from entry	WF-08042026-016768	8/21/2026	FT-FY27-08062026-016768-A	<1	FT-FY27-08062026-016768-B	<1
WS-016770	8/4/2026	8/4/2027	3	Combo Fountain	In room 340	WF-08042026-016770	8/21/2026	FT-FY27-08062026-016770-A	<1	FT-FY27-08062026-016770-B	<1
WS-016771	8/4/2026	8/4/2027	1	Combo Fountain	In room 117 Low Right	WF-08042026-016771	8/21/2026	FT-FY27-08062026-016771-A	<1	FT-FY27-08062026-016771-B	<1
WS-016772	8/4/2026	8/4/2027	1	Combo Faucet	In room 117 Low Right	WF-08042026-016772	8/21/2026	FT-FY27-08062026-016772-A	<1	FT-FY27-08062026-016772-B	<1
WS-016773	8/4/2026	8/4/2027	1	Combo Fountain	In room 129 teacher collaboration	WF-08042026-016773	8/21/2026	FT-FY27-08062026-016773-A	1	FT-FY27-08062026-016773-B	<1
WS-016774	8/4/2026	8/4/2027	1	Combo Fountain	In room 139 High Left	WF-08042026-016774	8/21/2026	FT-FY27-08062026-016774-A	<1	FT-FY27-08062026-016774-B	<1
WS-016775	8/4/2026	8/4/2027	1	Combo Fountain	In room 139 Low Right	WF-08042026-016775	8/21/2026	FT-FY27-08062026-016775-A	<1	FT-FY27-08062026-016775-B	<1
WS-016776	8/4/2026	8/4/2027	1	Combo Fountain	In room 109	WF-08042026-016776	8/21/2026	FT-FY27-08062026-016776-A	<1	FT-FY27-08062026-016776-B	<1
WS- 006729	8/4/2026	8/4/2027	1	Bottle Filler	In cafeteria	WF-08042026-006729	8/21/2026	FT-FY27-08062026-006729-A	<1	FT-FY27-08062026-006729-B	<1
WS- 006730	8/4/2026	8/4/2027	1	Cooler	In cafeteria High Left	WF-08042026-006730	8/21/2026	FT-FY27-08062026-006730-A	<1	FT-FY27-08062026-006730-B	<1
WS- 006731	8/4/2026	8/4/2027	1	Cooler	In cafeteria Low Right	WF-08042026-006731	8/21/2026	FT-FY27-08062026-006731-A	<1	FT-FY27-08062026-006731-B	<1
WS- 006732	8/4/2026	8/4/2027	1	Bottle Filler	In room G101 gym	WF-08042026-006732	8/21/2026	FT-FY27-08062026-006732-A	<1	FT-FY27-08062026-006732-B	<1
WS- 006733	8/4/2026	8/4/2027	1	Cooler	In room G101 gym High Left	WF-08042026-006733	8/21/2026	FT-FY27-08062026-006733-A	<1	FT-FY27-08062026-006733-B	<1
WS- 006734	8/4/2026	8/4/2027	1	Cooler	In room G101 gym Low Right	WF-08042026-006734	8/21/2026	FT-FY27-08062026-006734-A	<1	FT-FY27-08062026-006734-B	<1
WS- 006735	8/4/2026	8/4/2027	1	Health Suite	In room 103D health suite	WF-08042026-006735	8/21/2026	FT-FY27-08062026-006735-A	<1	FT-FY27-08062026-006735-B	<1
WS- 006736	8/4/2026	8/4/2027	1	Combo Fountain	In room 103D health suite	WF-08042026-006736	8/21/2026	FT-FY27-08062026-006736-A	<1	FT-FY27-08062026-006736-B	<1
WS- 006738	8/4/2026	8/4/2027	1	Break Room	In room 111 admin workroom	WF-08042026-006738	8/21/2026	FT-FY27-08062026-006738-A	<1	FT-FY27-08062026-006738-B	<1
WS- 006739	8/4/2026	8/4/2027	1	Combo Fountain	In room 111 admin workroom	WF-08042026-006739	8/21/2026	FT-FY27-08062026-006739-A	<1	FT-FY27-08062026-006739-B	<1
WS- 006740	8/4/2026	8/4/2027	1	Bottle Filler	In room 116	WF-08042026-006740	8/21/2026	FT-FY27-08062026-006740-A	<1	FT-FY27-08062026-006740-B	<1
WS- 006741	8/4/2026	8/4/2027	1	Cooler	In room 116	WF-08042026-006741	8/21/2026	FT-FY27-08062026-006741-A	<1	FT-FY27-08062026-006741-B	<1
WS- 006742	8/4/2026	8/4/2027	1	Combo Faucet	In room 116	WF-08042026-006742	8/21/2026	FT-FY27-08062026-006742-A	<1	FT-FY27-08062026-006742-B	<1
WS- 006743	8/4/2026	8/4/2027	1	Combo Fountain	In room 116	WF-08042026-006743	8/21/2026	FT-FY27-08062026-006743-A	<1	FT-FY27-08062026-006743-B	<1
WS- 006745	8/4/2026	8/4/2027	1	Combo Fountain	In room 117 High Left	WF-08042026-006745	8/21/2026	FT-FY27-08062026-006745-A	<1	FT-FY27-08062026-006745-B	<1
WS- 006746	8/4/2026	8/4/2027	1	Combo Faucet	In room 119 Low Left	WF-08042026-006746	8/21/2026	FT-FY27-08062026-006746-A	<1	FT-FY27-08062026-006746-B	<1

WS- 006747	8/4/2026	8/4/2027	1	Combo Fountain	In room 119	Low Left	WF-08042026-006747	8/21/2026	FT-FY27-08062026-006747-A	<1	FT-FY27-08062026-006747-B	<1
WS- 006749	8/4/2026	8/4/2027	1	Combo Fountain	In room 119	High Right	WF-08042026-006749	8/21/2026	FT-FY27-08062026-006749-A	<1	FT-FY27-08062026-006749-B	<1
WS- 006750	8/4/2026	8/4/2027	1	Combo Faucet	In room 121	Low Left	WF-08042026-006750	8/21/2026	FT-FY27-08062026-006750-A	<1	FT-FY27-08062026-006750-B	<1
WS- 006751	8/4/2026	8/4/2027	1	Combo Fountain	In room 121	Low Left	WF-08042026-006751	8/21/2026	FT-FY27-08062026-006751-A	<1	FT-FY27-08062026-006751-B	<1
WS- 006753	8/4/2026	8/4/2027	1	Combo Fountain	In room 121	High Right	WF-08042026-006753	8/21/2026	FT-FY27-08062026-006753-A	1.5	FT-FY27-08062026-006753-B	<1
WS- 006754	8/4/2026	8/4/2027	1	Combo Faucet	In room 124	Low Left	WF-08042026-006754	8/21/2026	FT-FY27-08062026-006754-A	<1	FT-FY27-08062026-006754-B	<1
WS- 006755	8/4/2026	8/4/2027	1	Combo Fountain	In room 124	Low Left	WF-08042026-006755	8/21/2026	FT-FY27-08062026-006755-A	<1	FT-FY27-08062026-006755-B	<1
WS- 006757	8/4/2026	8/4/2027	1	Combo Fountain	In room 124	High Right	WF-08042026-006757	8/21/2026	FT-FY27-08062026-006757-A	<1	FT-FY27-08062026-006757-B	<1
WS- 006758	8/4/2026	8/4/2027	1	Combo Faucet	In room 126	Low Left	WF-08042026-006758	8/21/2026	FT-FY27-08062026-006758-A	<1	FT-FY27-08062026-006758-B	<1
WS- 006759	8/4/2026	8/4/2027	1	Combo Fountain	In room 126	Low Left	WF-08042026-006759	8/21/2026	FT-FY27-08062026-006759-A	<1	FT-FY27-08062026-006759-B	<1
WS- 006761	8/4/2026	8/4/2027	1	Combo Fountain	In room 126	High Right	WF-08042026-006761	8/21/2026	FT-FY27-08062026-006761-A	<1	FT-FY27-08062026-006761-B	<1
WS- 006762	8/4/2026	8/4/2027	1	Combo Faucet	In room 125	Low Left	WF-08042026-006762	8/21/2026	FT-FY27-08062026-006762-A	1.8	FT-FY27-08062026-006762-B	<1
WS- 006763	8/4/2026	8/4/2027	1	Combo Fountain	In room 125	Low Left	WF-08042026-006763	8/21/2026	FT-FY27-08062026-006763-A	2.8	FT-FY27-08062026-006763-B	<1
WS- 006765	8/4/2026	8/4/2027	1	Combo Fountain	In room 125	High Right	WF-08042026-006765	8/21/2026	FT-FY27-08062026-006765-A	<1	FT-FY27-08062026-006765-B	<1
WS- 006766	8/4/2026	8/4/2027	1	Break Room	In room 129 teacher collaboration		WF-08042026-006766	8/21/2026	FT-FY27-08062026-006766-A	<1	FT-FY27-08062026-006766-B	<1
WS- 006767	8/4/2026	8/4/2027	1	Bottle Filler	In hallway across from room 129		WF-08042026-006767	8/21/2026	FT-FY27-08062026-006767-A	<1	FT-FY27-08062026-006767-B	<1
WS- 006768	8/4/2026	8/4/2027	1	Cooler	In hallway across from room 129	High Left	WF-08042026-006768	8/21/2026	FT-FY27-08062026-006768-A	<1	FT-FY27-08062026-006768-B	<1
WS- 006769	8/4/2026	8/4/2027	1	Cooler	In hallway across from room 129	Low Right	WF-08042026-006769	8/21/2026	FT-FY27-08062026-006769-A	<1	FT-FY27-08062026-006769-B	<1
WS- 006770	8/4/2026	8/4/2027	1	Combo Faucet	In room 133	Low Left	WF-08042026-006770	8/21/2026	FT-FY27-08062026-006770-A	<1	FT-FY27-08062026-006770-B	<1
WS- 006771	8/4/2026	8/4/2027	1	Combo Fountain	In room 133	Low Left	WF-08042026-006771	8/21/2026	FT-FY27-08062026-006771-A	<1	FT-FY27-08062026-006771-B	<1
WS- 006773	8/4/2026	8/4/2027	1	Combo Fountain	In room 133	High Right	WF-08042026-006773	8/21/2026	FT-FY27-08062026-006773-A	<1	FT-FY27-08062026-006773-B	<1
WS- 006774	8/4/2026	8/4/2027	1	Combo Faucet	In room 137	Low Left	WF-08042026-006774	8/21/2026	FT-FY27-08062026-006774-A	<1	FT-FY27-08062026-006774-B	<1
WS- 006775	8/4/2026	8/4/2027	1	Combo Fountain	In room 137	Low Left	WF-08042026-006775	8/21/2026	FT-FY27-08062026-006775-A	<1	FT-FY27-08062026-006775-B	<1
WS- 006777	8/4/2026	8/4/2027	1	Combo Fountain	In room 137	High Right	WF-08042026-006777	8/21/2026	FT-FY27-08062026-006777-A	<1	FT-FY27-08062026-006777-B	<1
WS- 006780	8/4/2026	8/4/2027	1	Combo Faucet	In room 136	Low Left	WF-08042026-006780	8/21/2026	FT-FY27-08062026-006780-A	<1	FT-FY27-08062026-006780-B	<1
WS- 006781	8/4/2026	8/4/2027	1	Combo Fountain	In room 136	Low Left	WF-08042026-006781	8/21/2026	FT-FY27-08062026-006781-A	<1	FT-FY27-08062026-006781-B	<1
WS- 006783	8/4/2026	8/4/2027	1	Combo Fountain	In room 136	High Right	WF-08042026-006783	8/21/2026	FT-FY27-08062026-006783-A	<1	FT-FY27-08062026-006783-B	<1
WS- 006784	8/4/2026	8/4/2027	1	Combo Faucet	In room 132	Low Left	WF-08042026-006784	8/21/2026	FT-FY27-08062026-006784-A	<1	FT-FY27-08062026-006784-B	<1
WS- 006785	8/4/2026	8/4/2027	1	Combo Fountain	In room 132	Low Left	WF-08042026-006785	8/21/2026	FT-FY27-08062026-006785-A	<1	FT-FY27-08062026-006785-B	<1
WS- 006787	8/4/2026	8/4/2027	1	Combo Fountain	In room 132	High Right	WF-08042026-006787	8/21/2026	FT-FY27-08062026-006787-A	<1	FT-FY27-08062026-006787-B	<1
WS- 006788	8/4/2026	8/4/2027	2	Combo Faucet	In room 236	Low Left	WF-08042026-006788	8/21/2026	FT-FY27-08062026-006788-A	<1	FT-FY27-08062026-006788-B	<1
WS- 006789	8/4/2026	8/4/2027	2	Combo Fountain	In room 236	Low Left	WF-08042026-006789	8/21/2026	FT-FY27-08062026-006789-A	<1	FT-FY27-08062026-006789-B	<1
WS- 006791	8/4/2026	8/4/2027	2	Combo Fountain	In room 236	High Right	WF-08042026-006791	8/21/2026	FT-FY27-08062026-006791-A	<1	FT-FY27-08062026-006791-B	<1
WS- 006792	8/4/2026	8/4/2027	2	Bottle Filler	In room 247 music		WF-08042026-006792	8/21/2026	FT-FY27-08062026-006792-A	<1	FT-FY27-08062026-006792-B	<1
WS- 006793	8/4/2026	8/4/2027	2	Cooler	In room 247 music	High Left	WF-08042026-006793	8/21/2026	FT-FY27-08062026-006793-A	<1	FT-FY27-08062026-006793-B	<1
WS- 006794	8/4/2026	8/4/2027	2	Cooler	In room 247 music	Low Right	WF-08042026-006794	8/21/2026	FT-FY27-08062026-006794-A	<1	FT-FY27-08062026-006794-B	<1
WS- 006796	8/4/2026	8/4/2027	2	Combo Fountain	In room 247 music		WF-08042026-006796	8/21/2026	FT-FY27-08062026-006796-A	<1	FT-FY27-08062026-006796-B	<1
WS- 006797	8/4/2026	8/4/2027	2	Bottle Filler	In room 245 music		WF-08042026-006797	8/21/2026	FT-FY27-08062026-006797-A	<1	FT-FY27-08062026-006797-B	<1
WS- 006798	8/4/2026	8/4/2027	2	Cooler	In room 245 music	High Left	WF-08042026-006798	8/21/2026	FT-FY27-08062026-006798-A	<1	FT-FY27-08062026-006798-B	<1
WS- 006799	8/4/2026	8/4/2027	2	Cooler	In room 245 music	Low Right	WF-08042026-006799	8/21/2026	FT-FY27-08062026-006799-A	<1	FT-FY27-08062026-006799-B	<1
WS- 006801	8/4/2026	8/4/2027	2	Combo Fountain	In room 245 music		WF-08042026-006801	8/21/2026	FT-FY27-08062026-006801-A	<1	FT-FY27-08062026-006801-B	<1

WS- 006806	8/4/2026	8/4/2027	2	Combo Fountain	In room 201C makerspace		WF-08042026-006806	8/21/2026	FT-FY27-08062026-006806-A	<1	FT-FY27-08062026-006806-B	<1
WS- 006808	8/4/2026	8/4/2027	2	Combo Fountain	In room 201B office		WF-08042026-006808	8/21/2026	FT-FY27-08062026-006808-A	<1	FT-FY27-08062026-006808-B	<1
WS- 006810	8/4/2026	8/4/2027	2	Combo Fountain	In room 203 art	Low Left	WF-08042026-006810	8/21/2026	FT-FY27-08062026-006810-A	<1	FT-FY27-08062026-006810-B	<1
WS- 006812	8/4/2026	8/4/2027	2	Combo Fountain	In room 203 art	High Right	WF-08042026-006812	8/21/2026	FT-FY27-08062026-006812-A	<1	FT-FY27-08062026-006812-B	<1
WS- 006814	8/4/2026	8/4/2027	2	Combo Fountain	In room 202 art	Low Left	WF-08042026-006814	8/21/2026	FT-FY27-08062026-006814-A	<1	FT-FY27-08062026-006814-B	<1
WS- 006816	8/4/2026	8/4/2027	2	Combo Fountain	In room 202 art	High Right	WF-08042026-006816	8/21/2026	FT-FY27-08062026-006816-A	<1	FT-FY27-08062026-006816-B	<1
WS- 006818	8/4/2026	8/4/2027	2	Combo Fountain	In room 212 OT/PT		WF-08042026-006818	8/21/2026	FT-FY27-08062026-006818-A	<1	FT-FY27-08062026-006818-B	<1
WS- 006820	8/4/2026	8/4/2027	2	Combo Fountain	In room 208 OT/PT		WF-08042026-006820	8/21/2026	FT-FY27-08062026-006820-A	<1	FT-FY27-08062026-006820-B	<1
WS- 006822	8/4/2026	8/4/2027	2	Combo Fountain	In room 207		WF-08042026-006822	8/21/2026	FT-FY27-08062026-006822-A	<1	FT-FY27-08062026-006822-B	<1
WS- 006824	8/4/2026	8/4/2027	2	Combo Fountain	In room 215		WF-08042026-006824	8/21/2026	FT-FY27-08062026-006824-A	<1	FT-FY27-08062026-006824-B	<1
WS- 006826	8/4/2026	8/4/2027	2	Combo Fountain	In room 222		WF-08042026-006826	8/21/2026	FT-FY27-08062026-006826-A	<1	FT-FY27-08062026-006826-B	<1
WS- 006829	8/4/2026	8/4/2027	2	Combo Fountain	In room 224		WF-08042026-006829	8/21/2026	FT-FY27-08062026-006829-A	<1	FT-FY27-08062026-006829-B	<1
WS- 006831	8/4/2026	8/4/2027	2	Combo Fountain	In room 221		WF-08042026-006831	8/21/2026	FT-FY27-08062026-006831-A	<1	FT-FY27-08062026-006831-B	<1
WS- 006832	8/4/2026	8/4/2027	2	Break Room	In room 227 teacher collaboration		WF-08042026-006832	8/21/2026	FT-FY27-08062026-006832-A	<1	FT-FY27-08062026-006832-B	<1
WS- 006833	8/4/2026	8/4/2027	2	Combo Fountain	In room 227 teacher collaboration		WF-08042026-006833	8/21/2026	FT-FY27-08062026-006833-A	<1	FT-FY27-08062026-006833-B	<1
WS- 006835	8/4/2026	8/4/2027	2	Combo Fountain	In room 229	Low Left	WF-08042026-006835	8/21/2026	FT-FY27-08062026-006835-A	<1	FT-FY27-08062026-006835-B	<1
WS- 006837	8/4/2026	8/4/2027	2	Combo Fountain	In room 229	High Right	WF-08042026-006837	8/21/2026	FT-FY27-08062026-006837-A	<1	FT-FY27-08062026-006837-B	<1
WS- 006838	8/4/2026	8/4/2027	2	Bottle Filler	In hallway adjacent to room 228		WF-08042026-006838	8/21/2026	FT-FY27-08062026-006838-A	<1	FT-FY27-08062026-006838-B	<1
WS- 006839	8/4/2026	8/4/2027	2	Cooler	In hallway adjacent to room 228	High Left	WF-08042026-006839	8/21/2026	FT-FY27-08062026-006839-A	<1	FT-FY27-08062026-006839-B	<1
WS- 006840	8/4/2026	8/4/2027	2	Cooler	In hallway adjacent to room 228	Low Right	WF-08042026-006840	8/21/2026	FT-FY27-08062026-006840-A	<1	FT-FY27-08062026-006840-B	<1
WS- 006842	8/4/2026	8/4/2027	2	Combo Fountain	In room 233	Low Left	WF-08042026-006842	8/21/2026	FT-FY27-08062026-006842-A	<1	FT-FY27-08062026-006842-B	<1
WS- 006844	8/4/2026	8/4/2027	2	Combo Fountain	In room 233	High Right	WF-08042026-006844	8/21/2026	FT-FY27-08062026-006844-A	<1	FT-FY27-08062026-006844-B	<1
WS- 006846	8/4/2026	8/4/2027	2	Combo Fountain	In room 235	High Left	WF-08042026-006846	8/21/2026	FT-FY27-08062026-006846-A	<1	FT-FY27-08062026-006846-B	<1
WS- 006848	8/4/2026	8/4/2027	2	Combo Fountain	In room 235	Low Right	WF-08042026-006848	8/21/2026	FT-FY27-08062026-006848-A	<1	FT-FY27-08062026-006848-B	<1
WS- 006850	8/4/2026	8/4/2027	3	Combo Fountain	In room 337		WF-08042026-006850	8/21/2026	FT-FY27-08062026-006850-A	<1	FT-FY27-08062026-006850-B	<1
WS- 006851	8/4/2026	8/4/2027	3	Bottle Filler	In hallway across from room 324		WF-08042026-006851	8/21/2026	FT-FY27-08062026-006851-A	<1	FT-FY27-08062026-006851-B	<1
WS- 006852	8/4/2026	8/4/2027	3	Cooler	In hallway across from room 324	High Left	WF-08042026-006852	8/21/2026	FT-FY27-08062026-006852-A	<1	FT-FY27-08062026-006852-B	<1
WS- 006853	8/4/2026	8/4/2027	3	Cooler	In hallway across from room 324	Low Right	WF-08042026-006853	8/21/2026	FT-FY27-08062026-006853-A	<1	FT-FY27-08062026-006853-B	<1
WS- 006855	8/4/2026	8/4/2027	3	Combo Fountain	In room 319		WF-08042026-006855	8/21/2026	FT-FY27-08062026-006855-A	<1	FT-FY27-08062026-006855-B	<1
WS- 006857	8/4/2026	8/4/2027	3	Combo Fountain	In room 317		WF-08042026-006857	8/21/2026	FT-FY27-08062026-006857-A	<1	FT-FY27-08062026-006857-B	<1
WS- 006859	8/4/2026	8/4/2027	3	Combo Fountain	In room 309		WF-08042026-006859	8/21/2026	FT-FY27-08062026-006859-A	<1	FT-FY27-08062026-006859-B	<1
WS- 006861	8/4/2026	8/4/2027	3	Combo Fountain	In room 307		WF-08042026-006861	8/21/2026	FT-FY27-08062026-006861-A	1.9	FT-FY27-08062026-006861-B	<1
WS- 006863	8/4/2026	8/4/2027	3	Combo Fountain	In room 302		WF-08042026-006863	8/21/2026	FT-FY27-08062026-006863-A	<1	FT-FY27-08062026-006863-B	<1
WS- 006865	8/4/2026	8/4/2027	3	Combo Fountain	In room 308		WF-08042026-006865	8/21/2026	FT-FY27-08062026-006865-A	<1	FT-FY27-08062026-006865-B	<1
WS- 006867	8/4/2026	8/4/2027	3	Combo Fountain	In room 310		WF-08042026-006867	8/21/2026	FT-FY27-08062026-006867-A	2.2	FT-FY27-08062026-006867-B	<1
WS- 006869	8/4/2026	8/4/2027	3	Combo Fountain	In room 318		WF-08042026-006869	8/21/2026	FT-FY27-08062026-006869-A	<1	FT-FY27-08062026-006869-B	<1
WS- 006870	8/4/2026	8/4/2027	3	Break Room	In room 324 teacher collaboration		WF-08042026-006870	8/21/2026	FT-FY27-08062026-006870-A	<1	FT-FY27-08062026-006870-B	<1
WS- 006871	8/4/2026	8/4/2027	3	Combo Fountain	In room 324 teacher collaboration		WF-08042026-006871	8/21/2026	FT-FY27-08062026-006871-A	<1	FT-FY27-08062026-006871-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006724	8/4/2026	8/4/2027	1	Food Prep Sink	In kitchen in back area	WF-08042026-006724	8/21/2026	FT-FY27-08062026-006724-A	1.2	FT-FY27-08062026-006724-B	<1