



Tubman ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002701	5/15/2018	5/15/2019	1	Bottle Filler	In hallway across from room 119	WF-05152018-002701	8/29/2018	FT-FY19-082018-002701-A	< 1	FT-FY19-082018-002701-B	< 1
WS- 002708	5/15/2018	5/15/2019	3	Cooler	In hallway adjacent to room 300	WF-05152018-002708	8/29/2018	FT-FY19-082018-002708-A	< 1	FT-FY19-082018-002708-B	1.4
WS- 002710	5/15/2018	5/15/2019	2	Cooler	In hallway adjacent to room 206	WF-05152018-002710	8/29/2018	FT-FY19-082018-002710-A	< 1	FT-FY19-082018-002710-B	< 1
WS- 002711	5/15/2018	5/15/2019	2	Cooler	In hallway adjacent to room 200	WF-05152018-002711	8/29/2018	FT-FY19-082018-002711-A	< 1	FT-FY19-082018-002711-B	< 1
WS- 002712	5/15/2018	5/15/2019	1	Combo Fountain	In health suite	WF-05152018-002712	8/29/2018	FT-FY19-082018-002712-A	< 1	FT-FY19-082018-002712-B	< 1
WS- 002713	5/15/2018	5/15/2019	1	Health Suite	In health suite	WF-05152018-002713	8/29/2018	FT-FY19-082018-002713-A	< 1	FT-FY19-082018-002713-B	< 1
WS- 002714	5/15/2018	5/15/2019	1	Break Room	In staff lounge	WF-05152018-002714	8/29/2018	FT-FY19-082018-002714-A	< 1	FT-FY19-082018-002714-B	< 1
WS- 002716	5/15/2018	5/15/2019	1	Break Room	In break room 128A	WF-05152018-002716	8/29/2018	FT-FY19-082018-002716-A	< 1	FT-FY19-082018-002716-B	< 1
WS- 002717	5/15/2018	5/15/2019	1	Break Room	In break room 128A	WF-05152018-002717	8/29/2018	FT-FY19-082018-002717-A	< 1	FT-FY19-082018-002717-B	< 1
WS- 002719	5/15/2018	5/15/2019	1	Cooler	In hallway adjacent to room 101	WF-05152018-002719	8/29/2018	FT-FY19-082018-002719-A	< 1	FT-FY19-082018-002719-B	< 1
WS- 002720	10/18/2017	10/18/2018	1	Combo Faucet	In classroom 106	WF-102017-002720	8/29/2018	FT-FY19-082018-002720-A	< 1	FT-FY19-082018-002720-B	< 1
WS- 002721	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 106	WF-05152018-002721	8/29/2018	FT-FY19-082018-002721-A	< 1	FT-FY19-082018-002721-B	< 1
WS- 002722	5/15/2018	5/15/2019	1	Cooler	In hallway adjacent to room 110	WF-05152018-002722	8/29/2018	FT-FY19-082018-002722-A	< 1	FT-FY19-082018-002722-B	< 1
WS- 002723	10/18/2017	10/18/2018	1	Combo Faucet	In classroom 108	WF-102017-002723	8/29/2018	FT-FY19-082018-002723-A	< 1	FT-FY19-082018-002723-B	< 1
WS- 002724	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 108	WF-05152018-002724	8/29/2018	FT-FY19-082018-002724-A	< 1	FT-FY19-082018-002724-B	< 1
WS- 002725	10/18/2017	10/18/2018	1	Combo Faucet	In classroom 111	WF-102017-002725	8/29/2018	FT-FY19-082018-002725-A	< 1	FT-FY19-082018-002725-B	< 1
WS- 002726	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 111	WF-05152018-002726	8/29/2018	FT-FY19-082018-002726-A	< 1	FT-FY19-082018-002726-B	< 1
WS- 002741	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 121	WF-05152018-002741	8/29/2018	FT-FY19-082018-002741-A	< 1	FT-FY19-082018-002741-B	< 1
WS- 003988	10/18/2017	10/18/2018	1	Combo Faucet	In classroom 110	WF-102017-003988	8/29/2018	FT-FY19-082018-003988-A	< 1	FT-FY19-082018-003988-B	< 1
WS- 003989	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 110	WF-05152018-003989	8/29/2018	FT-FY19-082018-003989-A	< 1	FT-FY19-082018-003989-B	< 1
WS- 003990	10/18/2017	10/18/2018	1	Combo Faucet	In classroom 113	WF-102017-003990	8/29/2018	FT-FY19-082018-003990-A	< 1	FT-FY19-082018-003990-B	< 1
WS- 008229	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 113	WF-05152018-008229	8/29/2018	FT-FY19-082018-008229-A	< 1	FT-FY19-082018-008229-B	< 1
WS- 008230	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 115	WF-05152018-008230	8/29/2018	FT-FY19-082018-008230-A	< 1	FT-FY19-082018-008230-B	< 1
WS- 008231	10/18/2017	10/18/2018	1	Combo Faucet	In classroom 115	WF-102017-008231	8/29/2018	FT-FY19-082018-008231-A	< 1	FT-FY19-082018-008231-B	< 1
WS- 008232	10/18/2017	10/18/2018	1	Combo Faucet	In classroom 114	WF-102017-008232	8/29/2018	FT-FY19-082018-008232-A	< 1	FT-FY19-082018-008232-B	< 1
WS- 008233	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 114	WF-05152018-008233	8/29/2018	FT-FY19-082018-008233-A	< 1	FT-FY19-082018-008233-B	< 1
WS- 008234	5/15/2018	5/15/2019	1	Cooler	In hallway across from room 119	WF-05152018-008234	8/29/2018	FT-FY19-082018-008234-A	< 1	FT-FY19-082018-008234-B	< 1
WS- 008235	8/17/2018	8/17/2019	1	Classroom Faucet	In classroom 120	WF-08172018-008235	8/29/2018	FT-FY19-082018-008235-A	< 1	FT-FY19-082018-008235-B	< 1
WS- 008236	5/15/2018	5/15/2019	1	Combo Fountain	In classroom 122	WF-05152018-008236	8/29/2018	FT-FY19-082018-008236-A	< 1	FT-FY19-082018-008236-B	< 1
WS- 008238	10/18/2017	10/18/2018	1	Combo Faucet	In classroom 121	WF-102017-008238	8/29/2018	FT-FY19-082018-008238-A	< 1	FT-FY19-082018-008238-B	< 1
WS- 008239	10/18/2017	10/18/2018	1	Combo Faucet	In classroom 122	WF-102017-008239	8/29/2018	FT-FY19-082018-008239-A	< 1	FT-FY19-082018-008239-B	< 1
WS- 008240	5/15/2018	5/15/2019	1	Cooler	In hallway adjacent to room 132	WF-05152018-008240	8/29/2018	FT-FY19-082018-008240-A	< 1	FT-FY19-082018-008240-B	< 1
WS- 008241	5/15/2018	5/15/2019	1	Cooler	In hallway adjacent to dining room	WF-05152018-008241	8/29/2018	FT-FY19-082018-008241-A	< 1	FT-FY19-082018-008241-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002702	1	Food Prep Sink	In kitchen	8/29/2018	FT-FY19-082018-002702-A	< 1	FT-FY19-082018-002702-B	1.1