



# Tubman ES Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002701	5/6/2019	5/6/2020	1	Bottle Filler	In hallway across from room 119	WF-05062019-002701	12/30/2019	FT-FY20-122019-002701-A	<1	FT-FY20-122019-002701-B	<1
WS- 002704	5/6/2019	5/6/2020	1	Cooler	In multi-purpose room	WF-05062019-002704	12/30/2019	FT-FY20-122019-002704-A	<1	FT-FY20-122019-002704-B	<1
WS- 002705	5/6/2019	5/6/2020	1	Bottle Filler	In multi-purpose room (bottle filler)	WF-05062019-002705	12/30/2019	FT-FY20-122019-002705-A	<1	FT-FY20-122019-002705-B	<1
WS- 002708	5/6/2019	5/6/2020	3	Cooler	In hallway adjacent to room 300	WF-05062019-002708	12/30/2019	FT-FY20-122019-002708-A	<1	FT-FY20-122019-002708-B	<1
WS- 002710	5/6/2019	5/6/2020	2	Cooler	In hallway adjacent to room 206	WF-05062019-002710	12/30/2019	FT-FY20-122019-002710-A	<1	FT-FY20-122019-002710-B	<1
WS- 002711	5/6/2019	5/6/2020	2	Cooler	In hallway adjacent to room 200	WF-05062019-002711	12/30/2019	FT-FY20-122019-002711-A	<1	FT-FY20-122019-002711-B	<1
WS- 002712	5/6/2019	5/6/2020	1	Combo Fountain	In health suite	WF-05062019-002712	12/30/2019	FT-FY20-122019-002712-A	<1	FT-FY20-122019-002712-B	<1
WS- 002713	5/6/2019	5/6/2020	1	Health Suite	In health suite	WF-05062019-002713	12/30/2019	FT-FY20-122019-002713-A	<1	FT-FY20-122019-002713-B	<1
WS- 002714	5/6/2019	5/6/2020	1	Break Room	In staff lounge	WF-05062019-002714	12/30/2019	FT-FY20-122019-002714-A	<1	FT-FY20-122019-002714-B	<1
WS- 002716	5/6/2019	5/6/2020	1	Break Room	In break room 128A	WF-05062019-002716	12/30/2019	FT-FY20-122019-002716-A	<1	FT-FY20-122019-002716-B	<1
WS- 002717	5/6/2019	5/6/2020	1	Break Room	In break room 128A	WF-05062019-002717	12/30/2019	FT-FY20-122019-002717-A	<1	FT-FY20-122019-002717-B	<1
WS- 002720	9/18/2019	9/18/2020	1	Combo Faucet	In classroom 106	WF-09182019-002720	12/30/2019	FT-FY20-122019-002720-A	<1	FT-FY20-122019-002720-B	<1
WS- 002721	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 106	WF-05062019-002721	12/30/2019	FT-FY20-122019-002721-A	<1	FT-FY20-122019-002721-B	<1
WS- 002722	5/6/2019	5/6/2020	1	Cooler	In hallway adjacent to room 110	WF-05062019-002722	12/30/2019	FT-FY20-122019-002722-A	<1	FT-FY20-122019-002722-B	<1
WS- 002723	9/18/2019	9/18/2020	1	Combo Faucet	In classroom 108	WF-09182019-002723	12/30/2019	FT-FY20-122019-002723-A	<1	FT-FY20-122019-002723-B	<1
WS- 002724	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 108	WF-05062019-002724	12/30/2019	FT-FY20-122019-002724-A	<1	FT-FY20-122019-002724-B	<1
WS- 002725	9/18/2019	9/18/2020	1	Combo Faucet	In classroom 111	WF-09182019-002725	12/30/2019	FT-FY20-122019-002725-A	<1	FT-FY20-122019-002725-B	<1
WS- 002726	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 111	WF-05062019-002726	12/30/2019	FT-FY20-122019-002726-A	<1	FT-FY20-122019-002726-B	<1
WS- 002741	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 121	WF-05062019-002741	12/30/2019	FT-FY20-122019-002741-A	<1	FT-FY20-122019-002741-B	<1
WS- 003988	9/18/2019	9/18/2020	1	Combo Faucet	In classroom 110	WF-09182019-003988	12/30/2019	FT-FY20-122019-003988-A	<1	FT-FY20-122019-003988-B	<1
WS- 003989	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 110	WF-05062019-003989	12/30/2019	FT-FY20-122019-003989-A	<1	FT-FY20-122019-003989-B	<1
WS- 003990	9/18/2019	9/18/2020	1	Combo Faucet	In classroom 113	WF-09182019-003990	12/30/2019	FT-FY20-122019-003990-A	<1	FT-FY20-122019-003990-B	<1
WS- 008229	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 113	WF-05062019-008229	12/30/2019	FT-FY20-122019-008229-A	<1	FT-FY20-122019-008229-B	<1
WS- 008230	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 115	WF-05062019-008230	12/30/2019	FT-FY20-122019-008230-A	<1	FT-FY20-122019-008230-B	<1
WS- 008231	9/18/2019	9/18/2020	1	Combo Faucet	In classroom 115	WF-09182019-008231	12/30/2019	FT-FY20-122019-008231-A	<1	FT-FY20-122019-008231-B	<1
WS- 008232	9/18/2019	9/18/2020	1	Combo Faucet	In classroom 114	WF-09182019-008232	12/30/2019	FT-FY20-122019-008232-A	<1	FT-FY20-122019-008232-B	<1
WS- 008233	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 114	WF-05062019-008233	12/30/2019	FT-FY20-122019-008233-A	<1	FT-FY20-122019-008233-B	<1
WS- 008234	5/6/2019	5/6/2020	1	Cooler	In hallway across from room 119	WF-05062019-008234	12/30/2019	FT-FY20-122019-008234-A	<1	FT-FY20-122019-008234-B	<1
WS- 008235	9/18/2019	9/18/2020	1	Classroom Faucet	In classroom 120	WF-09182019-008235	12/30/2019	FT-FY20-122019-008235-A	<1	FT-FY20-122019-008235-B	<1
WS- 008236	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 122	WF-05062019-008236	12/30/2019	FT-FY20-122019-008236-A	<1	FT-FY20-122019-008236-B	<1
WS- 008238	9/18/2019	9/18/2020	1	Combo Faucet	In classroom 121	WF-09182019-008238	12/30/2019	FT-FY20-122019-008238-A	<1	FT-FY20-122019-008238-B	<1
WS- 008239	9/18/2019	9/18/2020	1	Combo Faucet	In classroom 122	WF-09182019-008239	12/30/2019	FT-FY20-122019-008239-A	1.4	FT-FY20-122019-008239-B	<1
WS- 008240	5/6/2019	5/6/2020	1	Cooler	In hallway adjacent to room 132	WF-05062019-008240	12/30/2019	FT-FY20-122019-008240-A	<1	FT-FY20-122019-008240-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002702	7/2/2019	7/2/2020	1	Food Prep Sink	In kitchen	Left	WF-07022019-002702	12/30/2019	FT-FY20-122019-002702-A	<1	FT-FY20-122019-002702-B	<1