



Tubman Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002701	9/29/2020	9/29/2021	1	Bottle Filler	In hallway across from room 119	WF-09292020-002701	2/10/2021	FT-FY21-012021-002701-A	<1	FT-FY21-012021-002701-B	<1
WS-002705	9/29/2020	9/29/2021	1	Bottle Filler	In multi-purpose room (bottle filler)	WF-09292020-002705	2/10/2021	FT-FY21-012021-002705-A	<1	FT-FY21-012021-002705-B	<1
WS-002707	9/29/2020	9/29/2021	3	Cooler	In hallway adjacent to room 306	WF-09292020-002707	2/10/2021	FT-FY21-012021-002707-A	<1	FT-FY21-012021-002707-B	<1
WS-002708	9/29/2020	9/29/2021	3	Cooler	In hallway adjacent to room 300	WF-09292020-002708	2/10/2021	FT-FY21-012021-002708-A	<1	FT-FY21-012021-002708-B	<1
WS-002709	9/29/2020	9/29/2021	2	Cooler	In hallway adjacent to room 208	WF-09292020-002709	2/10/2021	FT-FY21-012021-002709-A	<1	FT-FY21-012021-002709-B	<1
WS-002711	9/29/2020	9/29/2021	2	Cooler	In hallway adjacent to room 200	WF-09292020-002711	2/10/2021	FT-FY21-012021-002711-A	<1	FT-FY21-012021-002711-B	<1
WS-002712	9/29/2020	9/29/2021	1	Combo Fountain	In health suite	WF-09292020-002712	2/10/2021	FT-FY21-012021-002712-A	<1	FT-FY21-012021-002712-B	<1
WS-002713	9/29/2020	9/29/2021	1	Health Suite	In health suite	WF-09292020-002713	2/10/2021	FT-FY21-012021-002713-A	<1	FT-FY21-012021-002713-B	<1
WS-002714	9/29/2020	9/29/2021	1	Break Room	In staff lounge	WF-09292020-002714	2/10/2021	FT-FY21-012021-002714-A	<1	FT-FY21-012021-002714-B	<1
WS-002716	9/29/2020	9/29/2021	1	Break Room	In break room 128A	WF-09292020-002716	2/10/2021	FT-FY21-012021-002716-A	<1	FT-FY21-012021-002716-B	<1
WS-002720	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 106	WF-09102020-002720	2/10/2021	FT-FY21-012021-002720-A	<1	FT-FY21-012021-002720-B	<1
WS-002721	9/29/2020	9/29/2021	1	Combo Fountain	In classroom 106	WF-09292020-002721	2/10/2021	FT-FY21-012021-002721-A	<1	FT-FY21-012021-002721-B	<1
WS-002723	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 108	WF-09102020-002723	2/10/2021	FT-FY21-012021-002723-A	<1	FT-FY21-012021-002723-B	<1
WS-002724	9/29/2020	9/29/2021	1	Combo Fountain	In classroom 108	WF-09292020-002724	2/10/2021	FT-FY21-012021-002724-A	<1	FT-FY21-012021-002724-B	<1
WS-002725	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 111	WF-09102020-002725	2/10/2021	FT-FY21-012021-002725-A	<1	FT-FY21-012021-002725-B	<1
WS-002726	9/29/2020	9/29/2021	1	Combo Fountain	In classroom 111	WF-09292020-002726	2/10/2021	FT-FY21-012021-002726-A	<1	FT-FY21-012021-002726-B	<1
WS-002741	9/29/2020	9/29/2021	1	Combo Fountain	In classroom 121	WF-09292020-002741	2/10/2021	FT-FY21-012021-002741-A	<1	FT-FY21-012021-002741-B	<1
WS-003988	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 110	WF-09102020-003988	2/10/2021	FT-FY21-012021-003988-A	<1	FT-FY21-012021-003988-B	<1
WS-003989	9/29/2020	9/29/2021	1	Combo Fountain	In classroom 110	WF-09292020-003989	2/10/2021	FT-FY21-012021-003989-A	<1	FT-FY21-012021-003989-B	<1
WS-003990	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 113	WF-09102020-003990	2/10/2021	FT-FY21-012021-003990-A	2.0	FT-FY21-012021-003990-B	<1
WS-008229	9/29/2020	9/29/2021	1	Combo Fountain	In classroom 113	WF-09292020-008229	2/10/2021	FT-FY21-012021-008229-A	<1	FT-FY21-012021-008229-B	<1
WS-008230	9/29/2020	9/29/2021	1	Combo Fountain	In classroom 115	WF-09292020-008230	2/10/2021	FT-FY21-012021-008230-A	<1	FT-FY21-012021-008230-B	<1
WS-008232	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 114	WF-09102020-008232	2/10/2021	FT-FY21-012021-008232-A	<1	FT-FY21-012021-008232-B	<1
WS-008233	9/29/2020	9/29/2021	1	Combo Fountain	In classroom 114	WF-09292020-008233	2/10/2021	FT-FY21-012021-008233-A	<1	FT-FY21-012021-008233-B	<1
WS-008235	9/10/2020	9/10/2021	1	Classroom Faucet	In classroom 120	WF-09102020-008235	2/10/2021	FT-FY21-012021-008235-A	<1	FT-FY21-012021-008235-B	<1
WS-008236	9/29/2020	9/29/2021	1	Combo Fountain	In classroom 122	WF-09292020-008236	2/10/2021	FT-FY21-012021-008236-A	<1	FT-FY21-012021-008236-B	<1
WS-008238	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 121	WF-09102020-008238	2/10/2021	FT-FY21-012021-008238-A	<1	FT-FY21-012021-008238-B	<1
WS-008239	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 122	WF-09102020-008239	2/10/2021	FT-FY21-012021-008239-A	<1	FT-FY21-012021-008239-B	<1
WS-008240	9/29/2020	9/29/2021	1	Cooler	In hallway adjacent to room 132	WF-09292020-008240	2/10/2021	FT-FY21-012021-008240-A	<1	FT-FY21-012021-008240-B	<1

FY21 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008231	9/10/2020	9/10/2021	1	Combo Faucet	In classroom 115	WF-09102020-008231	2/10/2021	FT-FY21-012021-008231-A	8.5	FT-FY21-012021-008231-B	<1

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008231	2/19/2021	2/19/2022	1	Combo Faucet	In classroom 115	WF-02192021-008231	3/7/2021	FT-FY21-022021-008231-A	<1	FT-FY21-022021-008231-B	<1