



# TUBMAN ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	TUBMAN ELEMENTARY SCHOOL	WS- 002702	8/20/2016	1	Food Prep Sink	In kitchen Left	FT-82016-002702-A	< 1	FT-82016-002702-B	< 1
2	TUBMAN ELEMENTARY SCHOOL	WS- 002704	8/20/2016	1	Cooler	In multi-purpose room	FT-82016-002704-A	< 1	FT-82016-002704-B	< 1
3	TUBMAN ELEMENTARY SCHOOL	WS- 002705	8/20/2016	1	Bottle Filler	In multi-purpose room (bottle filler)	FT-82016-002705-A	< 1	FT-82016-002705-B	< 1
4	TUBMAN ELEMENTARY SCHOOL	WS- 002706	8/20/2016	3	Cooler	In hallway adjacent to room 308	FT-82016-002706-A	< 1	FT-82016-002706-B	< 1
5	TUBMAN ELEMENTARY SCHOOL	WS- 002707	8/20/2016	3	Cooler	In hallway adjacent to room 306	FT-82016-002707-A	< 1	FT-82016-002707-B	< 1
6	TUBMAN ELEMENTARY SCHOOL	WS- 002708	8/20/2016	3	Cooler	In hallway adjacent to room 300	FT-82016-002708-A	< 1	FT-82016-002708-B	< 1
7	TUBMAN ELEMENTARY SCHOOL	WS- 002709	8/20/2016	2	Cooler	In hallway adjacent to room 208	FT-82016-002709-A	< 1	FT-82016-002709-B	< 1
8	TUBMAN ELEMENTARY SCHOOL	WS- 002710	8/20/2016	2	Cooler	In hallway adjacent to room 206	FT-82016-002710-A	< 1	FT-82016-002710-B	< 1
9	TUBMAN ELEMENTARY SCHOOL	WS- 002711	8/20/2016	2	Cooler	In hallway adjacent to room 200	FT-82016-002711-A	< 1	FT-82016-002711-B	< 1
10	TUBMAN ELEMENTARY SCHOOL	WS- 002712	8/20/2016	1	Fountain	In health suite	FT-82016-002712-A	< 1	FT-82016-002712-B	< 1
11	TUBMAN ELEMENTARY SCHOOL	WS- 002713	8/20/2016	1	Health Suite	In health suite	FT-82016-002713-A	< 1	FT-82016-002713-B	< 1
12	TUBMAN ELEMENTARY SCHOOL	WS- 002719	8/20/2016	1	Cooler	In hallway adjacent to room 101	FT-82016-002719-A	< 1	FT-82016-002719-B	< 1
13	TUBMAN ELEMENTARY SCHOOL	WS- 002721	8/20/2016	1	Fountain	In classroom 106	FT-82016-002721-A	< 1	FT-82016-002721-B	< 1
14	TUBMAN ELEMENTARY SCHOOL	WS- 002722	8/20/2016	1	Cooler	In hallway adjacent to room 110	FT-82016-002722-A	< 1	FT-82016-002722-B	< 1
15	TUBMAN ELEMENTARY SCHOOL	WS- 002723	8/20/2016	1	Classroom Faucet	In classroom 108	FT-82016-002723-A	< 1	FT-82016-002723-B	< 1
16	TUBMAN ELEMENTARY SCHOOL	WS- 002724	8/20/2016	1	Fountain	In classroom 108	FT-82016-002724-A	< 1	FT-82016-002724-B	< 1
17	TUBMAN ELEMENTARY SCHOOL	WS- 002726	8/20/2016	1	Fountain	In classroom 111	FT-82016-002726-A	< 1	FT-82016-002726-B	< 1
18	TUBMAN ELEMENTARY SCHOOL	WS- 002741	8/20/2016	1	Fountain	In classroom 121	FT-82016-002741-A	< 1	FT-82016-002741-B	< 1
19	TUBMAN ELEMENTARY SCHOOL	WS- 003989	8/20/2016	1	Fountain	In classroom 110	FT-82016-003989-A	< 1	FT-82016-003989-B	< 1
20	TUBMAN ELEMENTARY SCHOOL	WS- 008229	8/20/2016	1	Fountain	In classroom 113	FT-82016-008229-A	< 1	FT-82016-008229-B	< 1
21	TUBMAN ELEMENTARY SCHOOL	WS- 008230	8/20/2016	1	Fountain	In classroom 115	FT-82016-008230-A	< 1	FT-82016-008230-B	< 1
22	TUBMAN ELEMENTARY SCHOOL	WS- 008233	8/20/2016	1	Fountain	In classroom 114	FT-82016-008233-A	< 1	FT-82016-008233-B	< 1
23	TUBMAN ELEMENTARY SCHOOL	WS- 008234	8/20/2016	1	Cooler	In hallway across from room 119	FT-82016-008234-A	< 1	FT-82016-008234-B	< 1
24	TUBMAN ELEMENTARY SCHOOL	WS- 008235	8/20/2016	1	Cooler	In classroom 120	FT-82016-008235-A	< 1	FT-82016-008235-B	< 1
25	TUBMAN ELEMENTARY SCHOOL	WS- 008236	8/20/2016	1	Fountain	In classroom 122	FT-82016-008236-A	< 1	FT-82016-008236-B	< 1
26	TUBMAN ELEMENTARY SCHOOL	WS- 008237	8/20/2016	1	Cooler	In classroom 119	FT-82016-008237-A	< 1	FT-82016-008237-B	< 1
27	TUBMAN ELEMENTARY SCHOOL	WS- 008240	8/20/2016	1	Cooler	In hallway adjacent to room 132	FT-82016-008240-A	< 1	FT-82016-008240-B	< 1
28	TUBMAN ELEMENTARY SCHOOL	WS- 008241	8/20/2016	1	Cooler	In hallway adjacent to dining room	FT-82016-008241-A	< 1	FT-82016-008241-B	< 1