



Tubman ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002705	6/12/2017	6/12/2018	1	Bottle Filler	In multi-purpose room (bottle filler)	WF-62017-002705	11/2/2017	FT-FY18-102017-002705-A	<1	FT-FY18-102017-002705-B	<1
WS- 002708	6/12/2017	6/12/2018	3	Cooler	In hallway adjacent to room 300	WF-62017-002708	11/2/2017	FT-FY18-102017-002708-A	<1	FT-FY18-102017-002708-B	<1
WS- 002709	6/12/2017	6/12/2018	2	Cooler	In hallway adjacent to room 208	WF-62017-002709	11/2/2017	FT-FY18-102017-002709-A	<1	FT-FY18-102017-002709-B	<1
WS- 002712	6/12/2017	6/12/2018	1	Combo Fountain	In health suite	WF-62017-002712	11/2/2017	FT-FY18-102017-002712-A	<1	FT-FY18-102017-002712-B	<1
WS- 002716	6/12/2017	6/12/2018	1	Break Room	In break room 128A	WF-62017-002716	11/2/2017	FT-FY18-102017-002716-A	<1	FT-FY18-102017-002716-B	<1
WS- 002717	6/12/2017	6/12/2018	1	Break Room	In break room 128A	WF-62017-002717	11/2/2017	FT-FY18-102017-002717-A	<1	FT-FY18-102017-002717-B	<1
WS- 002725	10/18/2017	10/18/2018	1	Combo Faucet	In classroom 111	WF-102017-002725	11/2/2017	FT-FY18-102017-002725-A	2.5	FT-FY18-102017-002725-B	<1
WS- 003989	6/12/2017	6/12/2018	1	Combo Fountain	In classroom 110	WF-62017-003989	11/2/2017	FT-FY18-102017-003989-A	<1	FT-FY18-102017-003989-B	<1
WS- 003990	10/18/2017	10/18/2018	1	Combo Faucet	In classroom 113	WF-102017-003990	11/2/2017	FT-FY18-102017-003990-A	<1	FT-FY18-102017-003990-B	<1
WS- 008231	10/18/2017	10/18/2018	1	Combo Faucet	In classroom 115	WF-102017-008231	11/2/2017	FT-FY18-102017-008231-A	1.6	FT-FY18-102017-008231-B	<1
WS- 008235	6/12/2017	6/12/2018	1	Cooler	In classroom 120	WF-62017-008235	11/2/2017	FT-FY18-102017-008235-A	<1	FT-FY18-102017-008235-B	<1
WS- 008238	10/18/2017	10/18/2018	1	Combo Faucet	In classroom 121	WF-102017-008238	11/2/2017	FT-FY18-102017-008238-A	2	FT-FY18-102017-008238-B	<1
WS- 008240	6/12/2017	6/12/2018	1	Cooler	In hallway adjacent to room 132	WF-62017-008240	11/2/2017	FT-FY18-102017-008240-A	<1	FT-FY18-102017-008240-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002702	1	Food Prep Sink	In kitchen Left	11/2/2017	FT-FY18-102017-002702-A	3.5	FT-FY18-102017-002702-B	<1