



TUBMAN LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002702	Kitchen	1	In kitchen east wall Left	WT-042916-2719-A	< 1	WT-042916-2719-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002703	Kitchen	1	In kitchen east wall Right	WT-042916-2720-A	< 1	WT-042916-2720-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002704	Cooler	1	In all purpose room east wall	WT-042916-2721-A	< 1	WT-042916-2721-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002705	Other	1	In all purpose room east wall (bottle cooler)	WT-042916-2722-A	< 1	WT-042916-2722-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002706	Cooler	3	In hallway adjacent to room 308	WT-042916-2723-A	< 1	WT-042916-2723-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002707	Cooler	3	In hallway adjacent to room 306	WT-042916-2724-A	< 1	WT-042916-2724-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002708	Cooler	3	In hallway adjacent to room 300	WT-042916-2725-A	< 1	WT-042916-2725-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002709	Cooler	3	In hallway adjacent to room 208	WT-042916-2726-A	< 1	WT-042916-2726-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002710	Cooler	2	In hallway adjacent to room 206	WT-042916-2727-A	< 1	WT-042916-2727-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002711	Cooler	2	In hallway adjacent to 200	WT-042916-2728-A	< 1	WT-042916-2728-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002712	Fountain	1	In health suite	WT-042916-2729-A	< 1	WT-042916-2729-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002713	Health Suite	1	In health suite	WT-042916-2730-A	11.5	WT-042916-2730-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002714	Break Room	1	In staff lounge room	WT-042916-2731-A	< 1	WT-042916-2731-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002715	Break Room	1	In staff lounge room (spray nozzle)	WT-042916-2732-A	< 1	WT-042916-2732-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002716	Classroom	1	In classroom 128A	WT-042916-2733-A	4.5	WT-042916-2733-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002717	Fountain	1	In classroom 128A	WT-042916-2734-A	1.5	WT-042916-2734-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002718	Other	1	In classroom 128A (ice maker)	WT-042916-2735-A	< 1	WT-042916-2735-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002719	Cooler	1	In hallway adjacent to room 101	WT-042916-2736-A	< 1	WT-042916-2736-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002720	Classroom	1	In classroom 106	WT-042916-2737-A	1.1	WT-042916-2737-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002721	Fountain	1	In classroom 106 Right	WT-042916-2738-A	< 1	WT-042916-2738-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002722	Cooler	1	In hallway adjacent to room 110	WT-042916-2739-A	60.4	WT-042916-2739-B	7.5	Filtered	6/14/2016	<1	<1
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002723	Classroom	1	In classroom 108	WT-042916-2740-A	< 1	WT-042916-2740-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002724	Fountain	1	In classroom 108	WT-042916-2741-A	< 1	WT-042916-2741-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002725	Fountain	1	In classroom 111	WT-042916-2742-A	< 1	WT-042916-2742-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002726	Fountain	1	In classroom 111	WT-042916-2743-A	< 1	WT-042916-2743-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002739	Cooler	1	In hallway between room 119 and 117	WT-042916-2756-A	< 1	WT-042916-2756-B	1.5				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002740	Classroom	1	In classroom across from classroom 122	WT-042916-2757-A	< 1	WT-042916-2757-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-002741	Fountain	1	In classroom 121	WT-042916-2758-A	< 1	WT-042916-2758-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-003988	Classroom	1	In classroom 110	WT-042916-4005-A	2.7	WT-042916-4005-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-003989	Fountain	1	In classroom 110	WT-042916-4006-A	< 1	WT-042916-4006-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-003990	Classroom	1	In classroom 113	WT-042916-4007-A	5.5	WT-042916-4007-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-008229	Fountain	1	In classroom 113	WT-042916-8246-A	< 1	WT-042916-8246-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-008230	Fountain	1	In classroom 115	WT-042916-8247-A	< 1	WT-042916-8247-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-008231	Classroom	1	In classroom 115	WT-042916-8248-A	< 1	WT-042916-8248-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-008232	Classroom	1	In classroom no 114	WT-042916-8249-A	1.6	WT-042916-8249-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-008233	Fountain	1	In classroom 114	WT-042916-8250-A	< 1	WT-042916-8250-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-008234	Fountain	1	In hallway adjacent to exit	WT-042916-8251-A	< 1	WT-042916-8251-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-008235	Cooler	1	In classroom 120	WT-042916-8252-A	< 1	WT-042916-8252-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-008236	Fountain	1	In classroom no 122 Right	WT-042916-8253-A	< 1	WT-042916-8253-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-008237	Fountain	1	In classroom 119	WT-042916-8254-A	< 1	WT-042916-8254-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-008238	Fountain	1	In classroom 121	WT-042916-8255-A	< 1	WT-042916-8255-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-008239	Fountain	1	In classroom 122 Mid	WT-042916-8256-A	1.1	WT-042916-8256-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-008240	Cooler	1	In hallway adjacent 132	WT-042916-8257-A	< 1	WT-042916-8257-B	< 1				
TUBMAN ELEMENTARY SCHOOL	5/10/2016	WS-008241	Cooler	1	In hallway adjacent to dining room	WT-042916-8258-A	< 1	WT-042916-8258-B	< 1				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.