



Turkey Thicket RC Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005503	6/19/2017	6/19/2018	1	Cooler	In pool area across from men's locker room High	WF-62017-005503	2/6/2018	FT-FY18--62017-005503-A	<1	FT-FY18--62017-005503-B	<1
WS- 005507	6/19/2017	6/19/2018	1	Cooler	In lobby adjacent to weights and exercise room 118 High	WF-62017-005507	2/6/2018	FT-FY18--62017-005507-A	<1	FT-FY18--62017-005507-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005505	6/19/2017	6/19/2018	1	Sink	In kitchen 104	WF-62017-005505	2/6/2018	FT-FY18--62017-005505-A	<1	FT-FY18--62017-005505-B	<1
WS- 005506	6/19/2017	6/19/2018	1	Sink	In multi-purpose room 102	WF-62017-005506	2/6/2018	FT-FY18--62017-005506-A	<1	FT-FY18--62017-005506-B	<1