



# Turkey Thicket RC Lead in Water Test Results

## FY26 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005505	11/17/2025	11/17/2026	1	Food Prep Sink	In kitchen 104	WF-11172025-005505	3/4/2026	FT-FY26-01282026-005505-A	<2	FT-FY26-01282026-005505-B	<2
WS- 005506	11/17/2025	11/17/2026	1	Food Prep Sink	In multi-purpose room 102	WF-11172025-005506	3/4/2026	FT-FY26-01282026-005506-A	<2	FT-FY26-01282026-005506-B	<2
WS- 005507	4/10/2025	4/10/2026	1	Cooler	In lobby adjacent to weights and exercise room 118 High	WF-04102025-005507	3/4/2026	FT-FY26-01282026-005507-A	<2	FT-FY26-01282026-005507-B	<2
WS- 005508	4/10/2025	4/10/2026	1	Cooler	In lobby adjacent to weights and exercise room 119 Low	WF-04102025-005508	3/4/2026	FT-FY26-01282026-005508-A	<2	FT-FY26-01282026-005508-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.