



TURKEY THICKET REC LEAD WATER TEST RESULTS May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	TURKEY THICKET RECREATION CENTER	5/21/2016	WS- 005502	Utility	1	In custodian closet 133 (water source)	WT-042916-5519- A	1.1	WT-042916-5519- B	< 1				
2	TURKEY THICKET RECREATION CENTER	5/21/2016	WS- 005503	Cooler	1	In pool area across from men's shower	High WT-042916-5520- A	< 1	WT-042916-5520- B	< 1				
3	TURKEY THICKET RECREATION CENTER	5/21/2016	WS- 005504	Cooler	1	In pool area across from men's shower	Low WT-042916-5521- A	< 1	WT-042916-5521- B	< 1				
4	TURKEY THICKET RECREATION CENTER	5/21/2016	WS- 005505	Kitchen	1	In kitchen 104	WT-042916-5522- A	< 1	WT-042916-5522- B	< 1				
5	TURKEY THICKET RECREATION CENTER	5/21/2016	WS- 005506	Classroom	1	In multipurpose room 102	WT-042916-5523- A	< 1	WT-042916-5523- B	< 1				
6	TURKEY THICKET RECREATION CENTER	5/21/2016	WS- 005507	Cooler	1	In lobby adjacent to the weights and exercise room 118	High WT-042916-5524- A	< 1	WT-042916-5524- B	< 1				
7	TURKEY THICKET RECREATION CENTER	5/21/2016	WS- 005508	Cooler	1	In lobby adjacent to the weights and exercise room 118	Low WT-042916-5525- A	< 1	WT-042916-5525- B	< 1				
8	TURKEY THICKET RECREATION CENTER	5/21/2016	WS- 005509	Fountain	Ground Floor	Exterior common area adjacent parking lot	Low WT-042916-5526- A	< 1	WT-042916-5526- B	< 1				
9	TURKEY THICKET RECREATION CENTER	5/21/2016	WS- 005510	Fountain	Ground Floor	Exterior common area adjacent parking lot	High WT-042916-5527- A	< 1	WT-042916-5527- B	< 1				
10	TURKEY THICKET RECREATION CENTER	5/21/2016	WS- 005511	Fountain	Ground Floor	Exterior playground area adjacent tennis courts	High WT-042916-5528- A	< 1	WT-042916-5528- B	< 1				
11	TURKEY THICKET RECREATION CENTER	5/21/2016	WS- 005512	Fountain	Ground Floor	Exterior playground area adjacent tennis courts	Low WT-042916-5529- A	< 1	WT-042916-5529- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.