



Turner Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003762	3/15/2021	3/15/2022	1	Cooler	In hallway adjacent to room 110	WF-03152021-003762	2/9/2022	FT-FY22-01182022-003762-A	<1	FT-FY22-01182022-003762-B	<1
WS-003842	3/15/2021	3/15/2022	1	Cooler	In hallway adjacent to room 102	WF-03152021-003842	2/9/2022	FT-FY22-01182022-003842-A	<1	FT-FY22-01182022-003842-B	<1
WS-003843	3/15/2021	3/15/2022	1	Cooler	In hallway adjacent to room 102	WF-03152021-003843	2/9/2022	FT-FY22-01182022-003843-A	<1	FT-FY22-01182022-003843-B	<1
WS-003844	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 106	WF-03152021-003844	2/9/2022	FT-FY22-01182022-003844-A	2.3	FT-FY22-01182022-003844-B	<1
WS-003845	8/23/2021	8/23/2022	1	Combo Faucet	In classroom 106	WF-08232021-003845	2/9/2022	FT-FY22-01182022-003845-A	<1	FT-FY22-01182022-003845-B	<1
WS-003846	8/23/2021	8/23/2022	1	Classroom Faucet	In classroom 106	WF-08232021-003846	2/9/2022	FT-FY22-01182022-003846-A	<1	FT-FY22-01182022-003846-B	<1
WS-003847	8/23/2021	8/23/2022	1	Classroom Faucet	In classroom 107	WF-08232021-003847	2/9/2022	FT-FY22-01182022-003847-A	<1	FT-FY22-01182022-003847-B	<1
WS-003848	8/23/2021	8/23/2022	1	Combo Faucet	In classroom 107	WF-08232021-003848	2/9/2022	FT-FY22-01182022-003848-A	<1	FT-FY22-01182022-003848-B	<1
WS-003849	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 107	WF-03152021-003849	2/9/2022	FT-FY22-01182022-003849-A	<1	FT-FY22-01182022-003849-B	<1
WS-003850	8/23/2021	8/23/2022	1	Classroom Faucet	In classroom 108	WF-08232021-003850	2/9/2022	FT-FY22-01182022-003850-A	<1	FT-FY22-01182022-003850-B	<1
WS-003851	8/23/2021	8/23/2022	1	Combo Faucet	In classroom 108	WF-08232021-003851	2/9/2022	FT-FY22-01182022-003851-A	<1	FT-FY22-01182022-003851-B	<1
WS-003852	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 108	WF-03152021-003852	2/9/2022	FT-FY22-01182022-003852-A	<1	FT-FY22-01182022-003852-B	<1
WS-003853	3/15/2021	3/15/2022	1	Cooler	In hallway adjacent to room 110	WF-03152021-003853	2/9/2022	FT-FY22-01182022-003853-A	1.3	FT-FY22-01182022-003853-B	<1
WS-003854	3/15/2021	3/15/2022	1	Bottle Filler	In hallway adjacent to room 110 (bottle filler)	WF-03152021-003854	2/9/2022	FT-FY22-01182022-003854-A	<1	FT-FY22-01182022-003854-B	<1
WS-003855	8/23/2021	8/23/2022	1	Combo Faucet	In classroom 109B	WF-08232021-003855	2/9/2022	FT-FY22-01182022-003855-A	<1	FT-FY22-01182022-003855-B	<1
WS-003856	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 109B	WF-03152021-003856	2/9/2022	FT-FY22-01182022-003856-A	<1	FT-FY22-01182022-003856-B	<1
WS-003857	8/23/2021	8/23/2022	1	Combo Faucet	In classroom 109A	WF-08232021-003857	2/9/2022	FT-FY22-01182022-003857-A	<1	FT-FY22-01182022-003857-B	<1
WS-003858	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 109A	WF-03152021-003858	2/9/2022	FT-FY22-01182022-003858-A	<1	FT-FY22-01182022-003858-B	<1
WS-003859	3/15/2021	3/15/2022	1	Other	Laundry room sink (outside sign says Health Suite)	WF-03152021-003859	2/9/2022	FT-FY22-01182022-003859-A	<1	FT-FY22-01182022-003859-B	<1
WS-003860	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 113	WF-03152021-003860	2/9/2022	FT-FY22-01182022-003860-A	<1	FT-FY22-01182022-003860-B	<1
WS-003861	8/23/2021	8/23/2022	1	Combo Faucet	In classroom 113	WF-08232021-003861	2/9/2022	FT-FY22-01182022-003861-A	<1	FT-FY22-01182022-003861-B	<1
WS-003862	8/23/2021	8/23/2022	1	Classroom Faucet	In classroom 113	WF-08232021-003862	2/9/2022	FT-FY22-01182022-003862-A	<1	FT-FY22-01182022-003862-B	<1
WS-003863	8/23/2021	8/23/2022	1	Classroom Faucet	In classroom 112	WF-08232021-003863	2/9/2022	FT-FY22-01182022-003863-A	<1	FT-FY22-01182022-003863-B	<1
WS-003864	8/23/2021	8/23/2022	1	Combo Faucet	In classroom 112	WF-08232021-003864	2/9/2022	FT-FY22-01182022-003864-A	<1	FT-FY22-01182022-003864-B	<1
WS-003865	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 112	WF-03152021-003865	2/9/2022	FT-FY22-01182022-003865-A	<1	FT-FY22-01182022-003865-B	<1
WS-003866	3/15/2021	3/15/2022	1	Cooler	In hallway adjacent to elevator	WF-03152021-003866	2/9/2022	FT-FY22-01182022-003866-A	<1	FT-FY22-01182022-003866-B	<1
WS-003867	3/15/2021	3/15/2022	1	Cooler	In hallway adjacent to elevator	WF-03152021-003867	2/9/2022	FT-FY22-01182022-003867-A	<1	FT-FY22-01182022-003867-B	<1
WS-003868	8/23/2021	8/23/2022	1	Classroom Faucet	In classroom 116	WF-08232021-003868	2/9/2022	FT-FY22-01182022-003868-A	<1	FT-FY22-01182022-003868-B	<1
WS-003869	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 116	WF-03152021-003869	2/9/2022	FT-FY22-01182022-003869-A	<1	FT-FY22-01182022-003869-B	<1
WS-003870	8/23/2021	8/23/2022	1	Combo Faucet	In classroom 116	WF-08232021-003870	2/9/2022	FT-FY22-01182022-003870-A	<1	FT-FY22-01182022-003870-B	<1
WS-003871	8/23/2021	8/23/2022	1	Classroom Faucet	In classroom 117	WF-08232021-003871	2/9/2022	FT-FY22-01182022-003871-A	<1	FT-FY22-01182022-003871-B	<1
WS-003872	8/23/2021	8/23/2022	1	Combo Faucet	In classroom 117	WF-08232021-003872	2/9/2022	FT-FY22-01182022-003872-A	<1	FT-FY22-01182022-003872-B	<1
WS-003873	3/15/2021	3/15/2022	1	Combo Fountain	In classroom 117	WF-03152021-003873	2/9/2022	FT-FY22-01182022-003873-A	<1	FT-FY22-01182022-003873-B	<1
WS-003874	3/15/2021	3/15/2022	1	Health Suite	In health suite	WF-03152021-003874	2/9/2022	FT-FY22-01182022-003874-A	<1	FT-FY22-01182022-003874-B	<1
WS-003875	3/15/2021	3/15/2022	1	Cooler	In hallway adjacent to stairwell A	WF-03152021-003875	2/9/2022	FT-FY22-01182022-003875-A	<1	FT-FY22-01182022-003875-B	<1
WS-003876	3/15/2021	3/15/2022	1	Cooler	In hallway adjacent to stairwell A	WF-03152021-003876	2/9/2022	FT-FY22-01182022-003876-A	<1	FT-FY22-01182022-003876-B	<1

WS-003883	3/15/2021	3/15/2022	1	Cooler	In hallway adjacent to room 131	High	Left	WF-03152021-003883	2/9/2022	FT-FY22-01182022-003883-A	<1	FT-FY22-01182022-003883-B	<1
WS-003884	3/15/2021	3/15/2022	1	Cooler	In hallway adjacent to room 131	Low	Right	WF-03152021-003884	2/9/2022	FT-FY22-01182022-003884-A	<1	FT-FY22-01182022-003884-B	<1
WS-003885	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to stairwell A	High	Left	WF-03152021-003885	2/9/2022	FT-FY22-01182022-003885-A	<1	FT-FY22-01182022-003885-B	<1
WS-003886	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to stairwell A	Low	Right	WF-03152021-003886	2/9/2022	FT-FY22-01182022-003886-A	<1	FT-FY22-01182022-003886-B	<1
WS-003894	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to stairwell B	High	Left	WF-03152021-003894	2/9/2022	FT-FY22-01182022-003894-A	<1	FT-FY22-01182022-003894-B	<1
WS-003895	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to stairwell B	Low	Right	WF-03152021-003895	2/9/2022	FT-FY22-01182022-003895-A	<1	FT-FY22-01182022-003895-B	<1
WS-003896	3/15/2021	3/15/2022	2	Break Room	In staff lounge 213			WF-03152021-003896	2/9/2022	FT-FY22-01182022-003896-A	<1	FT-FY22-01182022-003896-B	<1
WS-003897	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to media center	High	Left	WF-03152021-003897	2/9/2022	FT-FY22-01182022-003897-A	<1	FT-FY22-01182022-003897-B	<1
WS-003898	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to media center	Low	Right	WF-03152021-003898	2/9/2022	FT-FY22-01182022-003898-A	<1	FT-FY22-01182022-003898-B	<1
WS-003899	8/23/2021	8/23/2022	2	Classroom Faucet	In classroom 206			WF-08232021-003899	2/9/2022	FT-FY22-01182022-003899-A	<1	FT-FY22-01182022-003899-B	<1
WS-003900	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to room 202	High	Left	WF-03152021-003900	2/9/2022	FT-FY22-01182022-003900-A	<1	FT-FY22-01182022-003900-B	<1
WS-003901	3/15/2021	3/15/2022	2	Cooler	In hallway adjacent to room 202	Low	Right	WF-03152021-003901	2/9/2022	FT-FY22-01182022-003901-A	<1	FT-FY22-01182022-003901-B	<1
WS-003902	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to room 302	High	Left	WF-03152021-003902	2/9/2022	FT-FY22-01182022-003902-A	<1	FT-FY22-01182022-003902-B	<1
WS-003903	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to room 302	Low	Right	WF-03152021-003903	2/9/2022	FT-FY22-01182022-003903-A	<1	FT-FY22-01182022-003903-B	<1
WS-003908	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to room 313	High	Left	WF-03152021-003908	2/9/2022	FT-FY22-01182022-003908-A	<1	FT-FY22-01182022-003908-B	<1
WS-003909	8/23/2021	8/23/2022	1	Classroom Faucet	In classroom 107, in bathroom			WF-08232021-003909	2/9/2022	FT-FY22-01182022-003909-A	<1	FT-FY22-01182022-003909-B	<1
WS-003912	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to room 313	Low	Right	WF-03152021-003912	2/9/2022	FT-FY22-01182022-003912-A	<1	FT-FY22-01182022-003912-B	<1
WS-003913	3/15/2021	3/15/2022	3	Break Room	In break room 316			WF-03152021-003913	2/9/2022	FT-FY22-01182022-003913-A	<1	FT-FY22-01182022-003913-B	<1
WS-003915	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to room 316	Low	Right	WF-03152021-003915	2/9/2022	FT-FY22-01182022-003915-A	<1	FT-FY22-01182022-003915-B	<1
WS-003924	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to stairwell A	High	Left	WF-03152021-003924	2/9/2022	FT-FY22-01182022-003924-A	<1	FT-FY22-01182022-003924-B	<1
WS-003925	3/15/2021	3/15/2022	3	Cooler	In hallway adjacent to stairwell A	Low	Right	WF-03152021-003925	2/9/2022	FT-FY22-01182022-003925-A	<1	FT-FY22-01182022-003925-B	<1
WS-003926	3/15/2021	3/15/2022	Basement	Combo Fountain	In art room B06 first clockwise from entry door			WF-03152021-003926	2/9/2022	FT-FY22-01182022-003926-A	<1	FT-FY22-01182022-003926-B	<1
WS-004533	8/23/2021	8/23/2022	1	Classroom Faucet	In classroom 108, in bathroom			WF-08232021-004533	2/9/2022	FT-FY22-01182022-004533-A	<1	FT-FY22-01182022-004533-B	<1
WS-004534	8/23/2021	8/23/2022	1	Classroom Faucet	In classroom 109, in bathroom			WF-08232021-004534	2/9/2022	FT-FY22-01182022-004534-A	<1	FT-FY22-01182022-004534-B	<1
WS-004535	8/23/2021	8/23/2022	1	Classroom Faucet	In classroom 113, in bathroom			WF-08232021-004535	2/9/2022	FT-FY22-01182022-004535-A	<1	FT-FY22-01182022-004535-B	<1
WS-004536	8/23/2021	8/23/2022	1	Classroom Faucet	In classroom 112, in bathroom			WF-08232021-004536	2/9/2022	FT-FY22-01182022-004536-A	<1	FT-FY22-01182022-004536-B	<1
WS-004537	8/23/2021	8/23/2022	1	Classroom Faucet	In classroom 116, in bathroom			WF-08232021-004537	2/9/2022	FT-FY22-01182022-004537-A	<1	FT-FY22-01182022-004537-B	<1
WS-004538	8/23/2021	8/23/2022	1	Classroom Faucet	In classroom 117, in bathroom			WF-08232021-004538	2/9/2022	FT-FY22-01182022-004538-A	<1	FT-FY22-01182022-004538-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-003878	1/10/2022	1/10/2023	1	Food Prep Sink	In servery room in kitchen on south wall	WF-01102022-003878	2/9/2022	FT-FY22-01182022-003878-A	<1	FT-FY22-01182022-003878-B	<1	