



Turner Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003840	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 106, in bathroom	WF-09012020-003840	3/3/2021	FT-FY21-022021-003840-A	<1	FT-FY21-022021-003840-B	<1
WS-003842	3/23/2020	3/23/2021	1	Cooler	In hallway adjacent to room 102 High Left	WF-03232020-003842	3/3/2021	FT-FY21-022021-003842-A	<1	FT-FY21-022021-003842-B	<1
WS-003843	3/23/2020	3/23/2021	1	Cooler	In hallway adjacent to room 102 Low Right	WF-03232020-003843	3/3/2021	FT-FY21-022021-003843-A	<1	FT-FY21-022021-003843-B	<1
WS-003844	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 106 Left	WF-03232020-003844	3/3/2021	FT-FY21-022021-003844-A	<1	FT-FY21-022021-003844-B	<1
WS-003845	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 106 Mid	WF-09012020-003845	3/3/2021	FT-FY21-022021-003845-A	1.9	FT-FY21-022021-003845-B	<1
WS-003846	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 106 Right	WF-09012020-003846	3/3/2021	FT-FY21-022021-003846-A	4.6	FT-FY21-022021-003846-B	<1
WS-003847	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 107 Left	WF-09012020-003847	3/3/2021	FT-FY21-022021-003847-A	<1	FT-FY21-022021-003847-B	<1
WS-003848	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 107 Mid	WF-09012020-003848	3/3/2021	FT-FY21-022021-003848-A	<1	FT-FY21-022021-003848-B	<1
WS-003849	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 107 Right	WF-03232020-003849	3/3/2021	FT-FY21-022021-003849-A	<1	FT-FY21-022021-003849-B	<1
WS-003850	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 108 Left	WF-09012020-003850	3/3/2021	FT-FY21-022021-003850-A	3.2	FT-FY21-022021-003850-B	<1
WS-003851	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 108 Mid	WF-09012020-003851	3/3/2021	FT-FY21-022021-003851-A	1.1	FT-FY21-022021-003851-B	<1
WS-003852	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 108 Right	WF-03232020-003852	3/3/2021	FT-FY21-022021-003852-A	<1	FT-FY21-022021-003852-B	<1
WS-003854	3/23/2020	3/23/2021	1	Bottle Filler	In hallway adjacent to room 110 (bottle filler)	WF-03232020-003854	3/3/2021	FT-FY21-022021-003854-A	<1	FT-FY21-022021-003854-B	<1
WS-003855	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 109B Left	WF-09012020-003855	3/3/2021	FT-FY21-022021-003855-A	<1	FT-FY21-022021-003855-B	<1
WS-003856	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 109B Right	WF-03232020-003856	3/3/2021	FT-FY21-022021-003856-A	<1	FT-FY21-022021-003856-B	<1
WS-003857	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 109A Left	WF-09012020-003857	3/3/2021	FT-FY21-022021-003857-A	<1	FT-FY21-022021-003857-B	<1
WS-003858	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 109A Right	WF-03232020-003858	3/3/2021	FT-FY21-022021-003858-A	<1	FT-FY21-022021-003858-B	<1
WS-003859	3/23/2020	3/23/2021	1	Other	Laundry room sink (outside sign says Health Suite) Mid	WF-03232020-003859	3/3/2021	FT-FY21-022021-003859-A	<1	FT-FY21-022021-003859-B	<1
WS-003860	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 113 Left	WF-03232020-003860	3/3/2021	FT-FY21-022021-003860-A	<1	FT-FY21-022021-003860-B	<1
WS-003861	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 113 Mid	WF-09012020-003861	3/3/2021	FT-FY21-022021-003861-A	<1	FT-FY21-022021-003861-B	<1
WS-003862	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 113 Right	WF-09012020-003862	3/3/2021	FT-FY21-022021-003862-A	<1	FT-FY21-022021-003862-B	<1
WS-003863	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 112 Mid	WF-09012020-003863	3/3/2021	FT-FY21-022021-003863-A	<1	FT-FY21-022021-003863-B	<1
WS-003864	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 112 Left	WF-09012020-003864	3/3/2021	FT-FY21-022021-003864-A	<1	FT-FY21-022021-003864-B	<1
WS-003865	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 112 Right	WF-03232020-003865	3/3/2021	FT-FY21-022021-003865-A	<1	FT-FY21-022021-003865-B	<1
WS-003866	3/23/2020	3/23/2021	1	Cooler	In hallway adjacent to elevator High Left	WF-03232020-003866	3/3/2021	FT-FY21-022021-003866-A	<1	FT-FY21-022021-003866-B	<1
WS-003867	3/23/2020	3/23/2021	1	Cooler	In hallway adjacent to elevator Low Right	WF-03232020-003867	3/3/2021	FT-FY21-022021-003867-A	<1	FT-FY21-022021-003867-B	<1
WS-003868	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 116 Left	WF-09012020-003868	3/3/2021	FT-FY21-022021-003868-A	<1	FT-FY21-022021-003868-B	<1
WS-003869	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 116 Low Right	WF-03232020-003869	3/3/2021	FT-FY21-022021-003869-A	<1	FT-FY21-022021-003869-B	<1
WS-003870	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 116 Mid	WF-09012020-003870	3/3/2021	FT-FY21-022021-003870-A	<1	FT-FY21-022021-003870-B	<1
WS-003871	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 117 Left	WF-09012020-003871	3/3/2021	FT-FY21-022021-003871-A	<1	FT-FY21-022021-003871-B	<1
WS-003872	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 117 Mid	WF-09012020-003872	3/3/2021	FT-FY21-022021-003872-A	<1	FT-FY21-022021-003872-B	<1
WS-003873	3/23/2020	3/23/2021	1	Combo Fountain	In classroom 117 Low Right	WF-03232020-003873	3/3/2021	FT-FY21-022021-003873-A	<1	FT-FY21-022021-003873-B	<1

WS-003874	3/23/2020	3/23/2021	1	Health Suite	In health suite			WF-03232020-003874	3/3/2021	FT-FY21-022021-003874-A	1.0	FT-FY21-022021-003874-B	<1
WS-003875	3/23/2020	3/23/2021	1	Cooler	In hallway adjacent to stairwell A	Low	Right	WF-03232020-003875	3/3/2021	FT-FY21-022021-003875-A	<1	FT-FY21-022021-003875-B	<1
WS-003876	3/23/2020	3/23/2021	1	Cooler	In hallway adjacent to stairwell A	High	Left	WF-03232020-003876	3/3/2021	FT-FY21-022021-003876-A	<1	FT-FY21-022021-003876-B	<1
WS-003883	3/23/2020	3/23/2021	1	Cooler	In hallway adjacent to room 131	High	Left	WF-03232020-003883	3/3/2021	FT-FY21-022021-003883-A	<1	FT-FY21-022021-003883-B	<1
WS-003884	3/23/2020	3/23/2021	1	Cooler	In hallway adjacent to room 131	Low	Right	WF-03232020-003884	3/3/2021	FT-FY21-022021-003884-A	<1	FT-FY21-022021-003884-B	<1
WS-003885	3/23/2020	3/23/2021	2	Cooler	In hallway adjacent to stairwell A	High	Left	WF-03232020-003885	3/3/2021	FT-FY21-022021-003885-A	<1	FT-FY21-022021-003885-B	<1
WS-003886	3/23/2020	3/23/2021	2	Cooler	In hallway adjacent to stairwell A	Low	Right	WF-03232020-003886	3/3/2021	FT-FY21-022021-003886-A	<1	FT-FY21-022021-003886-B	<1
WS-003894	3/23/2020	3/23/2021	2	Cooler	In hallway adjacent to stairwell B	High	Left	WF-03232020-003894	3/3/2021	FT-FY21-022021-003894-A	<1	FT-FY21-022021-003894-B	<1
WS-003895	3/23/2020	3/23/2021	2	Cooler	In hallway adjacent to stairwell B	Low	Right	WF-03232020-003895	3/3/2021	FT-FY21-022021-003895-A	<1	FT-FY21-022021-003895-B	<1
WS-003896	3/23/2020	3/23/2021	2	Break Room	In staff lounge 213			WF-03232020-003896	3/3/2021	FT-FY21-022021-003896-A	<1	FT-FY21-022021-003896-B	<1
WS-003897	3/23/2020	3/23/2021	2	Cooler	In hallway adjacent to media center	High	Left	WF-03232020-003897	3/3/2021	FT-FY21-022021-003897-A	<1	FT-FY21-022021-003897-B	<1
WS-003898	3/23/2020	3/23/2021	2	Cooler	In hallway adjacent to media center	Low	Right	WF-03232020-003898	3/3/2021	FT-FY21-022021-003898-A	<1	FT-FY21-022021-003898-B	<1
WS-003899	9/1/2020	9/1/2021	2	Classroom Faucet	In classroom 206			WF-09012020-003899	3/3/2021	FT-FY21-022021-003899-A	<1	FT-FY21-022021-003899-B	<1
WS-003900	3/23/2020	3/23/2021	2	Cooler	In hallway adjacent to room 202	High	Left	WF-03232020-003900	3/3/2021	FT-FY21-022021-003900-A	<1	FT-FY21-022021-003900-B	<1
WS-003901	3/23/2020	3/23/2021	2	Cooler	In hallway adjacent to room 202	Low	Right	WF-03232020-003901	3/3/2021	FT-FY21-022021-003901-A	<1	FT-FY21-022021-003901-B	<1
WS-003902	3/23/2020	3/23/2021	3	Cooler	In hallway adjacent to room 302	High	Left	WF-03232020-003902	3/3/2021	FT-FY21-022021-003902-A	<1	FT-FY21-022021-003902-B	<1
WS-003903	3/23/2020	3/23/2021	3	Cooler	In hallway adjacent to room 302	Low	Right	WF-03232020-003903	3/3/2021	FT-FY21-022021-003903-A	<1	FT-FY21-022021-003903-B	<1
WS-003908	3/23/2020	3/23/2021	3	Cooler	In hallway adjacent to room 313	High	Left	WF-03232020-003908	3/3/2021	FT-FY21-022021-003908-A	<1	FT-FY21-022021-003908-B	<1
WS-003909	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 107, in bathroom			WF-09012020-003909	3/3/2021	FT-FY21-022021-003909-A	<1	FT-FY21-022021-003909-B	<1
WS-003912	3/23/2020	3/23/2021	3	Cooler	In hallway adjacent to room 313	Low	Right	WF-03232020-003912	3/3/2021	FT-FY21-022021-003912-A	<1	FT-FY21-022021-003912-B	<1
WS-003913	3/23/2020	3/23/2021	3	Break Room	In break room 316			WF-03232020-003913	3/3/2021	FT-FY21-022021-003913-A	<1	FT-FY21-022021-003913-B	<1
WS-003914	3/23/2020	3/23/2021	3	Cooler	In hallway adjacent to room 316	High	Left	WF-03232020-003914	3/3/2021	FT-FY21-022021-003914-A	<1	FT-FY21-022021-003914-B	<1
WS-003915	3/23/2020	3/23/2021	3	Cooler	In hallway adjacent to room 316	Low	Right	WF-03232020-003915	3/3/2021	FT-FY21-022021-003915-A	<1	FT-FY21-022021-003915-B	<1
WS-003924	3/23/2020	3/23/2021	3	Cooler	In hallway adjacent to stairwell A	High	Left	WF-03232020-003924	3/3/2021	FT-FY21-022021-003924-A	<1	FT-FY21-022021-003924-B	<1
WS-003925	3/23/2020	3/23/2021	3	Cooler	In hallway adjacent to stairwell A	Low	Right	WF-03232020-003925	3/3/2021	FT-FY21-022021-003925-A	<1	FT-FY21-022021-003925-B	<1
WS-003926	3/23/2020	3/23/2021	Basement	Combo Fountain	In art room B06 first clockwise from entry door			WF-03232020-003926	3/3/2021	FT-FY21-022021-003926-A	<1	FT-FY21-022021-003926-B	<1
WS-004533	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 108, in bathroom			WF-09012020-004533	3/3/2021	FT-FY21-022021-004533-A	1.6	FT-FY21-022021-004533-B	<1
WS-004534	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 109, in bathroom			WF-09012020-004534	3/3/2021	FT-FY21-022021-004534-A	<1	FT-FY21-022021-004534-B	<1
WS-004535	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 113, in bathroom			WF-09012020-004535	3/3/2021	FT-FY21-022021-004535-A	<1	FT-FY21-022021-004535-B	<1
WS-004536	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 112, in bathroom			WF-09012020-004536	3/3/2021	FT-FY21-022021-004536-A	<1	FT-FY21-022021-004536-B	<1
WS-004537	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 116, in bathroom			WF-09012020-004537	3/3/2021	FT-FY21-022021-004537-A	<1	FT-FY21-022021-004537-B	<1
WS-004538	9/1/2020	9/1/2021	1	Classroom Faucet	In classroom 117, in bathroom			WF-09012020-004538	3/3/2021	FT-FY21-022021-004538-A	<1	FT-FY21-022021-004538-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-003878	1/19/2021	1/19/2022	1	Food Prep Sink	In servery room in kitchen on south wall	WF-01192021-003878	3/3/2021	FT-FY21-022021-003878-A	<1	FT-FY21-022021-003878-B	<1	