



Turner Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003762	3/7/2022	3/7/2023	1	Cooler	In hallway adjacent to room 110	Low Right	WF-03072022-003762	11/4/2022	FT-FY23-10102022-003762-A	<1	FT-FY23-10102022-003762-B	<1
WS- 003840	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 106, in bathroom		WF-08152022-003840	11/4/2022	FT-FY23-10102022-003840-A	<1	FT-FY23-10102022-003840-B	<1
WS- 003842	3/7/2022	3/7/2023	1	Cooler	In hallway adjacent to room 102	High Left	WF-03072022-003842	11/4/2022	FT-FY23-10102022-003842-A	<1	FT-FY23-10102022-003842-B	<1
WS- 003843	3/7/2022	3/7/2023	1	Cooler	In hallway adjacent to room 102	Low Right	WF-03072022-003843	11/4/2022	FT-FY23-10102022-003843-A	<1	FT-FY23-10102022-003843-B	<1
WS- 003844	3/7/2022	3/7/2023	1	Combo Fountain	In classroom 106	Left	WF-03072022-003844	11/4/2022	FT-FY23-10102022-003844-A	<1	FT-FY23-10102022-003844-B	<1
WS- 003845	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 106	Mid	WF-08152022-003845	11/4/2022	FT-FY23-10102022-003845-A	<1	FT-FY23-10102022-003845-B	<1
WS- 003846	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 106	Right	WF-08152022-003846	11/4/2022	FT-FY23-10102022-003846-A	<1	FT-FY23-10102022-003846-B	<1
WS- 003847	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 107	Left	WF-08152022-003847	11/4/2022	FT-FY23-10102022-003847-A	<1	FT-FY23-10102022-003847-B	<1
WS- 003848	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 107	Mid	WF-08152022-003848	11/4/2022	FT-FY23-10102022-003848-A	<1	FT-FY23-10102022-003848-B	<1
WS- 003849	3/7/2022	3/7/2023	1	Combo Fountain	In classroom 107	Right	WF-03072022-003849	11/4/2022	FT-FY23-10102022-003849-A	<1	FT-FY23-10102022-003849-B	<1
WS- 003850	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 108	Left	WF-08152022-003850	11/4/2022	FT-FY23-10102022-003850-A	<1	FT-FY23-10102022-003850-B	<1
WS- 003851	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 108	Mid	WF-08152022-003851	11/4/2022	FT-FY23-10102022-003851-A	<1	FT-FY23-10102022-003851-B	<1
WS- 003852	3/7/2022	3/7/2023	1	Combo Fountain	In classroom 108	Right	WF-03072022-003852	11/4/2022	FT-FY23-10102022-003852-A	<1	FT-FY23-10102022-003852-B	<1
WS- 003853	3/7/2022	3/7/2023	1	Cooler	In hallway adjacent to room 110	High Left	WF-03072022-003853	11/4/2022	FT-FY23-10102022-003853-A	<1	FT-FY23-10102022-003853-B	<1
WS- 003854	3/7/2022	3/7/2023	1	Bottle Filler	In hallway adjacent to room 110 (bottle filler)		WF-03072022-003854	11/4/2022	FT-FY23-10102022-003854-A	<1	FT-FY23-10102022-003854-B	<1
WS- 003855	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 109B	Left	WF-08152022-003855	11/4/2022	FT-FY23-10102022-003855-A	<1	FT-FY23-10102022-003855-B	<1
WS- 003856	3/7/2022	3/7/2023	1	Combo Fountain	In classroom 109B	Right	WF-03072022-003856	11/4/2022	FT-FY23-10102022-003856-A	<1	FT-FY23-10102022-003856-B	<1
WS- 003857	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 109A	Left	WF-08152022-003857	11/4/2022	FT-FY23-10102022-003857-A	<1	FT-FY23-10102022-003857-B	<1
WS- 003858	3/7/2022	3/7/2023	1	Combo Fountain	In classroom 109A	Right	WF-03072022-003858	11/4/2022	FT-FY23-10102022-003858-A	<1	FT-FY23-10102022-003858-B	<1
WS- 003859	3/7/2022	3/7/2023	1	Other	Laundry room sink	Mid	WF-03072022-003859	11/4/2022	FT-FY23-10102022-003859-A	<1	FT-FY23-10102022-003859-B	<1
WS- 003860	3/7/2022	3/7/2023	1	Combo Fountain	In classroom 113	Left	WF-03072022-003860	11/4/2022	FT-FY23-10102022-003860-A	<1	FT-FY23-10102022-003860-B	<1
WS- 003861	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 113	Mid	WF-08152022-003861	11/4/2022	FT-FY23-10102022-003861-A	<1	FT-FY23-10102022-003861-B	<1
WS- 003862	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 113	Right	WF-08152022-003862	11/4/2022	FT-FY23-10102022-003862-A	<1	FT-FY23-10102022-003862-B	<1
WS- 003863	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 112	Mid	WF-08152022-003863	11/4/2022	FT-FY23-10102022-003863-A	<1	FT-FY23-10102022-003863-B	<1
WS- 003864	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 112	Left	WF-08152022-003864	11/4/2022	FT-FY23-10102022-003864-A	<1	FT-FY23-10102022-003864-B	<1
WS- 003865	3/7/2022	3/7/2023	1	Combo Fountain	In classroom 112	Right	WF-03072022-003865	11/4/2022	FT-FY23-10102022-003865-A	<1	FT-FY23-10102022-003865-B	<1
WS- 003866	3/7/2022	3/7/2023	1	Cooler	In hallway adjacent to elevator	High Left	WF-03072022-003866	11/4/2022	FT-FY23-10102022-003866-A	<1	FT-FY23-10102022-003866-B	<1
WS- 003867	3/7/2022	3/7/2023	1	Cooler	In hallway adjacent to elevator	Low Right	WF-03072022-003867	11/4/2022	FT-FY23-10102022-003867-A	<1	FT-FY23-10102022-003867-B	<1
WS- 003868	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 116	Left	WF-08152022-003868	11/4/2022	FT-FY23-10102022-003868-A	<1	FT-FY23-10102022-003868-B	<1
WS- 003869	3/7/2022	3/7/2023	1	Combo Fountain	In classroom 116	Low Right	WF-03072022-003869	11/4/2022	FT-FY23-10102022-003869-A	<1	FT-FY23-10102022-003869-B	<1
WS- 003870	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 116	Mid	WF-08152022-003870	11/4/2022	FT-FY23-10102022-003870-A	<1	FT-FY23-10102022-003870-B	<1
WS- 003871	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 117	Left	WF-08152022-003871	11/4/2022	FT-FY23-10102022-003871-A	<1	FT-FY23-10102022-003871-B	<1
WS- 003872	8/15/2022	8/15/2023	1	Combo Faucet	In classroom 117	Mid	WF-08152022-003872	11/4/2022	FT-FY23-10102022-003872-A	<1	FT-FY23-10102022-003872-B	<1
WS- 003873	3/7/2022	3/7/2023	1	Combo Fountain	In classroom 117	Low Right	WF-03072022-003873	11/4/2022	FT-FY23-10102022-003873-A	<1	FT-FY23-10102022-003873-B	<1
WS- 003874	3/7/2022	3/7/2023	1	Health Suite	In health suite		WF-03072022-003874	11/4/2022	FT-FY23-10102022-003874-A	<1	FT-FY23-10102022-003874-B	<1

WS-003875	3/7/2022	3/7/2023	1	Cooler	In hallway adjacent to stairwell A	Low	Right	WF-03072022-003875	11/4/2022	FT-FY23-10102022-003875-A	<1	FT-FY23-10102022-003875-B	<1
WS-003876	3/7/2022	3/7/2023	1	Cooler	In hallway adjacent to stairwell A	High	Left	WF-03072022-003876	11/4/2022	FT-FY23-10102022-003876-A	<1	FT-FY23-10102022-003876-B	<1
WS-003883	3/7/2022	3/7/2023	1	Cooler	In hallway adjacent to room 131	High	Left	WF-03072022-003883	11/4/2022	FT-FY23-10102022-003883-A	<1	FT-FY23-10102022-003883-B	<1
WS-003884	3/7/2022	3/7/2023	1	Cooler	In hallway adjacent to room 131	Low	Right	WF-03072022-003884	11/4/2022	FT-FY23-10102022-003884-A	<1	FT-FY23-10102022-003884-B	<1
WS-003885	3/7/2022	3/7/2023	2	Cooler	In hallway adjacent to stairwell A	High	Left	WF-03072022-003885	11/4/2022	FT-FY23-10102022-003885-A	<1	FT-FY23-10102022-003885-B	<1
WS-003886	3/7/2022	3/7/2023	2	Cooler	In hallway adjacent to stairwell A	Low	Right	WF-03072022-003886	11/4/2022	FT-FY23-10102022-003886-A	<1	FT-FY23-10102022-003886-B	<1
WS-003894	3/7/2022	3/7/2023	2	Cooler	In hallway adjacent to stairwell B	High	Left	WF-03072022-003894	11/4/2022	FT-FY23-10102022-003894-A	<1	FT-FY23-10102022-003894-B	<1
WS-003895	3/7/2022	3/7/2023	2	Cooler	In hallway adjacent to stairwell B	Low	Right	WF-03072022-003895	11/4/2022	FT-FY23-10102022-003895-A	<1	FT-FY23-10102022-003895-B	<1
WS-003896	3/7/2022	3/7/2023	2	Break Room	In staff lounge 213			WF-03072022-003896	11/4/2022	FT-FY23-10102022-003896-A	<1	FT-FY23-10102022-003896-B	<1
WS-003897	3/7/2022	3/7/2023	2	Cooler	In hallway adjacent to media center	High	Left	WF-03072022-003897	11/4/2022	FT-FY23-10102022-003897-A	<1	FT-FY23-10102022-003897-B	<1
WS-003898	3/7/2022	3/7/2023	2	Cooler	In hallway adjacent to media center	Low	Right	WF-03072022-003898	11/4/2022	FT-FY23-10102022-003898-A	<1	FT-FY23-10102022-003898-B	<1
WS-003899	8/15/2022	8/15/2023	2	Classroom Faucet	In classroom 206			WF-08152022-003899	11/4/2022	FT-FY23-10102022-003899-A	<1	FT-FY23-10102022-003899-B	<1
WS-003900	3/7/2022	3/7/2023	2	Cooler	In hallway adjacent to room 202	High	Left	WF-03072022-003900	11/4/2022	FT-FY23-10102022-003900-A	<1	FT-FY23-10102022-003900-B	<1
WS-003901	3/7/2022	3/7/2023	2	Cooler	In hallway adjacent to room 202	Low	Right	WF-03072022-003901	11/4/2022	FT-FY23-10102022-003901-A	<1	FT-FY23-10102022-003901-B	<1
WS-003902	3/7/2022	3/7/2023	3	Cooler	In hallway adjacent to room 302	High	Left	WF-03072022-003902	11/4/2022	FT-FY23-10102022-003902-A	<1	FT-FY23-10102022-003902-B	<1
WS-003903	3/7/2022	3/7/2023	3	Cooler	In hallway adjacent to room 302	Low	Right	WF-03072022-003903	11/4/2022	FT-FY23-10102022-003903-A	<1	FT-FY23-10102022-003903-B	<1
WS-003908	3/7/2022	3/7/2023	3	Cooler	In hallway adjacent to room 313	High	Left	WF-03072022-003908	11/4/2022	FT-FY23-10102022-003908-A	<1	FT-FY23-10102022-003908-B	<1
WS-003909	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 107, in bathroom			WF-08152022-003909	11/4/2022	FT-FY23-10102022-003909-A	<1	FT-FY23-10102022-003909-B	<1
WS-003912	3/7/2022	3/7/2023	3	Cooler	In hallway adjacent to room 313	Low	Right	WF-03072022-003912	11/4/2022	FT-FY23-10102022-003912-A	<1	FT-FY23-10102022-003912-B	<1
WS-003913	3/7/2022	3/7/2023	3	Break Room	In break room 316			WF-03072022-003913	11/4/2022	FT-FY23-10102022-003913-A	<1	FT-FY23-10102022-003913-B	<1
WS-003924	3/7/2022	3/7/2023	3	Cooler	In hallway adjacent to stairwell A	High	Left	WF-03072022-003924	11/4/2022	FT-FY23-10102022-003924-A	<1	FT-FY23-10102022-003924-B	<1
WS-003925	3/7/2022	3/7/2023	3	Cooler	In hallway adjacent to stairwell A	Low	Right	WF-03072022-003925	11/4/2022	FT-FY23-10102022-003925-A	<1	FT-FY23-10102022-003925-B	<1
WS-003926	3/7/2022	3/7/2023	Basement	Combo Fountain	In art room B06 first clockwise from entry door			WF-03072022-003926	11/4/2022	FT-FY23-10102022-003926-A	<1	FT-FY23-10102022-003926-B	<1
WS-004533	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 108, in bathroom			WF-08152022-004533	11/4/2022	FT-FY23-10102022-004533-A	<1	FT-FY23-10102022-004533-B	<1
WS-004534	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 109, in bathroom			WF-08152022-004534	11/4/2022	FT-FY23-10102022-004534-A	<1	FT-FY23-10102022-004534-B	<1
WS-004535	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 113, in bathroom			WF-08152022-004535	11/4/2022	FT-FY23-10102022-004535-A	<1	FT-FY23-10102022-004535-B	<1
WS-004536	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 112, in bathroom			WF-08152022-004536	11/4/2022	FT-FY23-10102022-004536-A	<1	FT-FY23-10102022-004536-B	<1
WS-004537	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 116, in bathroom			WF-08152022-004537	11/4/2022	FT-FY23-10102022-004537-A	<1	FT-FY23-10102022-004537-B	<1
WS-004538	8/15/2022	8/15/2023	1	Classroom Faucet	In classroom 117, in bathroom			WF-08152022-004538	11/4/2022	FT-FY23-10102022-004538-A	<1	FT-FY23-10102022-004538-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003878	1/10/2022	1/10/2023	1	Food Prep Sink	In servery room in kitchen on south wall	WF-01102022-003878	11/4/2022	FT-FY23-10102022-003878-A	<1	FT-FY23-10102022-003878-B	<1