



Turner Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003762	3/1/2023	3/1/2024	1	Cooler	In hallway adjacent to room 110	Low Right	WF-03012023-003762	11/28/2023	FT-FY24-10102023-003762-A	<1	FT-FY24-10102023-003762-B	<1
WS- 003844	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 106	Left	WF-03012023-003844	11/28/2023	FT-FY24-10102023-003844-A	1.0	FT-FY24-10102023-003844-B	<1
WS- 003845	8/8/2023	8/8/2024	1	Combo Faucet	In classroom 106	Mid	WF-08082023-003845	11/28/2023	FT-FY24-10102023-003845-A	1.0	FT-FY24-10102023-003845-B	<1
WS- 003846	8/8/2023	8/8/2024	1	Classroom Faucet	In classroom 106	Right	WF-08082023-003846	11/28/2023	FT-FY24-10102023-003846-A	3.6	FT-FY24-10102023-003846-B	<1
WS- 003847	8/8/2023	8/8/2024	1	Classroom Faucet	In classroom 107	Left	WF-08082023-003847	11/28/2023	FT-FY24-10102023-003847-A	4.8	FT-FY24-10102023-003847-B	<1
WS- 003848	8/8/2023	8/8/2024	1	Combo Faucet	In classroom 107	Mid	WF-08082023-003848	11/28/2023	FT-FY24-10102023-003848-A	1.1	FT-FY24-10102023-003848-B	<1
WS- 003849	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 107	Right	WF-03012023-003849	11/28/2023	FT-FY24-10102023-003849-A	<1	FT-FY24-10102023-003849-B	<1
WS- 003850	8/8/2023	8/8/2024	1	Classroom Faucet	In classroom 108	Left	WF-08082023-003850	11/28/2023	FT-FY24-10102023-003850-A	2.2	FT-FY24-10102023-003850-B	<1
WS- 003851	8/8/2023	8/8/2024	1	Combo Faucet	In classroom 108	Mid	WF-08082023-003851	11/28/2023	FT-FY24-10102023-003851-A	1.1	FT-FY24-10102023-003851-B	<1
WS- 003852	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 108	Right	WF-03012023-003852	11/28/2023	FT-FY24-10102023-003852-A	2.7	FT-FY24-10102023-003852-B	<1
WS- 003853	3/1/2023	3/1/2024	1	Cooler	In hallway adjacent to room 110	High Left	WF-03012023-003853	11/28/2023	FT-FY24-10102023-003853-A	<1	FT-FY24-10102023-003853-B	<1
WS- 003854	3/1/2023	3/1/2024	1	Bottle Filler	In hallway adjacent to room 110 (bottle filler)		WF-03012023-003854	11/28/2023	FT-FY24-10102023-003854-A	<1	FT-FY24-10102023-003854-B	<1
WS- 003855	8/8/2023	8/8/2024	1	Combo Faucet	In classroom 109B	Left	WF-08082023-003855	11/28/2023	FT-FY24-10102023-003855-A	2.7	FT-FY24-10102023-003855-B	<1
WS- 003856	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 109B	Right	WF-03012023-003856	11/28/2023	FT-FY24-10102023-003856-A	3.3	FT-FY24-10102023-003856-B	1.1
WS- 003857	8/8/2023	8/8/2024	1	Combo Faucet	In classroom 109A	Left	WF-08082023-003857	11/28/2023	FT-FY24-10102023-003857-A	1.6	FT-FY24-10102023-003857-B	<1
WS- 003858	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 109A	Right	WF-03012023-003858	11/28/2023	FT-FY24-10102023-003858-A	2.7	FT-FY24-10102023-003858-B	<1
WS- 003859	3/1/2023	3/1/2024	1	Other	Laundry room sink (outside sign says Health Suite)	Mid	WF-03012023-003859	11/28/2023	FT-FY24-10102023-003859-A	<1	FT-FY24-10102023-003859-B	<1
WS- 003860	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 113	Left	WF-03012023-003860	11/28/2023	FT-FY24-10102023-003860-A	2.4	FT-FY24-10102023-003860-B	1.2
WS- 003862	8/8/2023	8/8/2024	1	Classroom Faucet	In classroom 113	Right	WF-08082023-003862	11/28/2023	FT-FY24-10102023-003862-A	1.4	FT-FY24-10102023-003862-B	<1
WS- 003863	8/8/2023	8/8/2024	1	Classroom Faucet	In classroom 112	Mid	WF-08082023-003863	11/28/2023	FT-FY24-10102023-003863-A	3.1	FT-FY24-10102023-003863-B	<1
WS- 003864	8/8/2023	8/8/2024	1	Combo Faucet	In classroom 112	Left	WF-08082023-003864	11/28/2023	FT-FY24-10102023-003864-A	4.0	FT-FY24-10102023-003864-B	<1
WS- 003865	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 112	Right	WF-03012023-003865	11/28/2023	FT-FY24-10102023-003865-A	<1	FT-FY24-10102023-003865-B	<1
WS- 003866	3/1/2023	3/1/2024	1	Cooler	In hallway adjacent to elevator	High Left	WF-03012023-003866	11/28/2023	FT-FY24-10102023-003866-A	<1	FT-FY24-10102023-003866-B	<1
WS- 003867	3/1/2023	3/1/2024	1	Cooler	In hallway adjacent to elevator	Low Right	WF-03012023-003867	11/28/2023	FT-FY24-10102023-003867-A	<1	FT-FY24-10102023-003867-B	<1
WS- 003868	8/8/2023	8/8/2024	1	Classroom Faucet	In classroom 116	Left	WF-08082023-003868	11/28/2023	FT-FY24-10102023-003868-A	<1	FT-FY24-10102023-003868-B	<1
WS- 003869	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 116	Low Right	WF-03012023-003869	11/28/2023	FT-FY24-10102023-003869-A	1.2	FT-FY24-10102023-003869-B	1.0
WS- 003870	8/8/2023	8/8/2024	1	Combo Faucet	In classroom 116	Mid	WF-08082023-003870	11/28/2023	FT-FY24-10102023-003870-A	1.3	FT-FY24-10102023-003870-B	<1
WS- 003871	8/8/2023	8/8/2024	1	Classroom Faucet	In classroom 117	Left	WF-08082023-003871	11/28/2023	FT-FY24-10102023-003871-A	1.6	FT-FY24-10102023-003871-B	<1
WS- 003872	8/8/2023	8/8/2024	1	Combo Faucet	In classroom 117	Mid	WF-08082023-003872	11/28/2023	FT-FY24-10102023-003872-A	1.3	FT-FY24-10102023-003872-B	<1
WS- 003873	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 117	Low Right	WF-03012023-003873	11/28/2023	FT-FY24-10102023-003873-A	1.4	FT-FY24-10102023-003873-B	1.0
WS- 003874	3/1/2023	3/1/2024	1	Health Suite	In health suite		WF-03012023-003874	11/28/2023	FT-FY24-10102023-003874-A	<1	FT-FY24-10102023-003874-B	<1
WS- 003875	3/1/2023	3/1/2024	1	Cooler	In hallway adjacent to stairwell A	Low Right	WF-03012023-003875	11/28/2023	FT-FY24-10102023-003875-A	<1	FT-FY24-10102023-003875-B	<1
WS- 003876	3/1/2023	3/1/2024	1	Cooler	In hallway adjacent to stairwell A	High Left	WF-03012023-003876	11/28/2023	FT-FY24-10102023-003876-A	<1	FT-FY24-10102023-003876-B	<1
WS- 003883	3/1/2023	3/1/2024	1	Cooler	In hallway adjacent to room 131	High Left	WF-03012023-003883	11/28/2023	FT-FY24-10102023-003883-A	<1	FT-FY24-10102023-003883-B	<1

WS-003884	3/1/2023	3/1/2024	1	Cooler	In hallway adjacent to room 131	Low Right	WF-03012023-003884	11/28/2023	FT-FY24-10102023-003884-A	<1	FT-FY24-10102023-003884-B	<1
WS-003885	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to stairwell A	High Left	WF-03012023-003885	11/28/2023	FT-FY24-10102023-003885-A	<1	FT-FY24-10102023-003885-B	<1
WS-003886	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to stairwell A	Low Right	WF-03012023-003886	11/28/2023	FT-FY24-10102023-003886-A	<1	FT-FY24-10102023-003886-B	<1
WS-003894	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to stairwell B	High Left	WF-03012023-003894	11/28/2023	FT-FY24-10102023-003894-A	<1	FT-FY24-10102023-003894-B	<1
WS-003895	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to stairwell B	Low Right	WF-03012023-003895	11/28/2023	FT-FY24-10102023-003895-A	<1	FT-FY24-10102023-003895-B	<1
WS-003896	3/1/2023	3/1/2024	2	Break Room	In staff lounge 213		WF-03012023-003896	11/28/2023	FT-FY24-10102023-003896-A	1.8	FT-FY24-10102023-003896-B	1.2
WS-003897	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to media center	High Left	WF-03012023-003897	11/28/2023	FT-FY24-10102023-003897-A	<1	FT-FY24-10102023-003897-B	<1
WS-003898	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to media center	Low Right	WF-03012023-003898	11/28/2023	FT-FY24-10102023-003898-A	<1	FT-FY24-10102023-003898-B	<1
WS-003899	8/8/2023	8/8/2024	2	Classroom Faucet	In classroom 206		WF-08082023-003899	11/28/2023	FT-FY24-10102023-003899-A	2.0	FT-FY24-10102023-003899-B	<1
WS-003900	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to room 202	High Left	WF-03012023-003900	11/28/2023	FT-FY24-10102023-003900-A	1.0	FT-FY24-10102023-003900-B	<1
WS-003901	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to room 202	Low Right	WF-03012023-003901	11/28/2023	FT-FY24-10102023-003901-A	<1	FT-FY24-10102023-003901-B	<1
WS-003902	3/1/2023	3/1/2024	3	Cooler	In hallway adjacent to room 302	High Left	WF-03012023-003902	11/28/2023	FT-FY24-10102023-003902-A	<1	FT-FY24-10102023-003902-B	<1
WS-003903	3/1/2023	3/1/2024	3	Cooler	In hallway adjacent to room 302	Low Right	WF-03012023-003903	11/28/2023	FT-FY24-10102023-003903-A	<1	FT-FY24-10102023-003903-B	<1
WS-003909	8/8/2023	8/8/2024	1	Classroom Faucet	In classroom 107, in bathroom		WF-08082023-003909	11/28/2023	FT-FY24-10102023-003909-A	<1	FT-FY24-10102023-003909-B	1.0
WS-003912	3/1/2023	3/1/2024	3	Cooler	In hallway adjacent to room 313	Low Right	WF-03012023-003912	11/28/2023	FT-FY24-10102023-003912-A	<1	FT-FY24-10102023-003912-B	2.2
WS-003913	3/1/2023	3/1/2024	3	Break Room	In break room 316		WF-03012023-003913	11/28/2023	FT-FY24-10102023-003913-A	<1	FT-FY24-10102023-003913-B	<1
WS-003924	3/1/2023	3/1/2024	3	Cooler	In hallway adjacent to stairwell A	High Left	WF-03012023-003924	11/28/2023	FT-FY24-10102023-003924-A	1.3	FT-FY24-10102023-003924-B	<1
WS-003925	3/1/2023	3/1/2024	3	Cooler	In hallway adjacent to stairwell A	Low Right	WF-03012023-003925	11/28/2023	FT-FY24-10102023-003925-A	<1	FT-FY24-10102023-003925-B	<1
WS-003926	3/1/2023	3/1/2024	Basement	Combo Fountain	In art room B06 first clockwise from entry door		WF-03012023-003926	11/28/2023	FT-FY24-10102023-003926-A	<1	FT-FY24-10102023-003926-B	<1
WS-004533	8/8/2023	8/8/2024	1	Classroom Faucet	In classroom 108, in bathroom		WF-08082023-004533	11/28/2023	FT-FY24-10102023-004533-A	<1	FT-FY24-10102023-004533-B	<1
WS-004534	8/8/2023	8/8/2024	1	Classroom Faucet	In classroom 109, in bathroom		WF-08082023-004534	11/28/2023	FT-FY24-10102023-004534-A	1.6	FT-FY24-10102023-004534-B	<1
WS-004536	8/8/2023	8/8/2024	1	Classroom Faucet	In classroom 112, in bathroom		WF-08082023-004536	11/28/2023	FT-FY24-10102023-004536-A	2.5	FT-FY24-10102023-004536-B	<1
WS-004537	8/8/2023	8/8/2024	1	Classroom Faucet	In classroom 116, in bathroom		WF-08082023-004537	11/28/2023	FT-FY24-10102023-004537-A	1.1	FT-FY24-10102023-004537-B	<1
WS-004538	8/8/2023	8/8/2024	1	Classroom Faucet	In classroom 117, in bathroom		WF-08082023-004538	11/28/2023	FT-FY24-10102023-004538-A	2.3	FT-FY24-10102023-004538-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003878	12/21/2022	12/21/2023	1	Food Prep Sink	In servery room in kitchen on south wall	WF-12212022-003878	11/28/2023	FT-FY24-10102023-003878-A	<1	FT-FY24-10102023-003878-B	<1