



Turner ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003762	4/1/2019	4/1/2020	1	Cooler	In hallway adjacent to room 110	Low Right	WF-04012019-003762	11/3/2019	FT-FY20-102019-003762-A	<1	FT-FY20-102019-003762-B	<1
WS- 003840	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 106, in bathroom		WF-09092019-003840	11/3/2019	FT-FY20-102019-003840-A	<1	FT-FY20-102019-003840-B	<1
WS- 003842	4/1/2019	4/1/2020	1	Cooler	In hallway adjacent to room 102	High Left	WF-04012019-003842	11/3/2019	FT-FY20-102019-003842-A	<1	FT-FY20-102019-003842-B	<1
WS- 003843	4/1/2019	4/1/2020	1	Cooler	In hallway adjacent to room 102	Low Right	WF-04012019-003843	11/3/2019	FT-FY20-102019-003843-A	<1	FT-FY20-102019-003843-B	<1
WS- 003844	4/1/2019	4/1/2020	1	Combo Fountain	In classroom 106	Left	WF-04012019-003844	11/3/2019	FT-FY20-102019-003844-A	<1	FT-FY20-102019-003844-B	<1
WS- 003845	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 106	Mid	WF-09092019-003845	11/3/2019	FT-FY20-102019-003845-A	<1	FT-FY20-102019-003845-B	<1
WS- 003846	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 106	Right	WF-09092019-003846	11/3/2019	FT-FY20-102019-003846-A	<1	FT-FY20-102019-003846-B	<1
WS- 003847	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 107	Left	WF-09092019-003847	11/3/2019	FT-FY20-102019-003847-A	1.6	FT-FY20-102019-003847-B	<1
WS- 003848	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 107	Mid	WF-09092019-003848	11/3/2019	FT-FY20-102019-003848-A	<1	FT-FY20-102019-003848-B	<1
WS- 003849	4/1/2019	4/1/2020	1	Combo Fountain	In classroom 107	Right	WF-04012019-003849	11/3/2019	FT-FY20-102019-003849-A	<1	FT-FY20-102019-003849-B	<1
WS- 003851	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 108	Mid	WF-09092019-003851	11/3/2019	FT-FY20-102019-003851-A	<1	FT-FY20-102019-003851-B	<1
WS- 003852	4/1/2019	4/1/2020	1	Combo Fountain	In classroom 108	Right	WF-04012019-003852	11/3/2019	FT-FY20-102019-003852-A	<1	FT-FY20-102019-003852-B	<1
WS- 003853	4/1/2019	4/1/2020	1	Cooler	In hallway adjacent to room 110	High Left	WF-04012019-003853	11/3/2019	FT-FY20-102019-003853-A	<1	FT-FY20-102019-003853-B	<1
WS- 003854	4/1/2019	4/1/2020	1	Bottle Filler	In hallway adjacent to room 110 (bottle filler)		WF-04012019-003854	11/3/2019	FT-FY20-102019-003854-A	<1	FT-FY20-102019-003854-B	<1
WS- 003855	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 109B	Left	WF-09092019-003855	11/3/2019	FT-FY20-102019-003855-A	<1	FT-FY20-102019-003855-B	<1
WS- 003856	4/1/2019	4/1/2020	1	Combo Fountain	In classroom 109B	Right	WF-04012019-003856	11/3/2019	FT-FY20-102019-003856-A	1.6	FT-FY20-102019-003856-B	<1
WS- 003857	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 109A	Left	WF-09092019-003857	11/3/2019	FT-FY20-102019-003857-A	1.1	FT-FY20-102019-003857-B	<1
WS- 003858	4/1/2019	4/1/2020	1	Combo Fountain	In classroom 109A	Right	WF-04012019-003858	11/3/2019	FT-FY20-102019-003858-A	1.2	FT-FY20-102019-003858-B	<1
WS- 003859	4/1/2019	4/1/2020	1	Other	Laundry room sink (outside sign says Health Suite)	Mid	WF-04012019-003859	11/3/2019	FT-FY20-102019-003859-A	<1	FT-FY20-102019-003859-B	<1
WS- 003860	4/1/2019	4/1/2020	1	Combo Fountain	In classroom 113	Left	WF-04012019-003860	11/3/2019	FT-FY20-102019-003860-A	<1	FT-FY20-102019-003860-B	<1
WS- 003861	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 113	Mid	WF-09092019-003861	11/3/2019	FT-FY20-102019-003861-A	<1	FT-FY20-102019-003861-B	<1
WS- 003862	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 113	Right	WF-09092019-003862	11/3/2019	FT-FY20-102019-003862-A	<1	FT-FY20-102019-003862-B	<1
WS- 003863	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 112	Mid	WF-09092019-003863	11/3/2019	FT-FY20-102019-003863-A	<1	FT-FY20-102019-003863-B	<1
WS- 003864	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 112	Left	WF-09092019-003864	11/3/2019	FT-FY20-102019-003864-A	1.6	FT-FY20-102019-003864-B	<1
WS- 003865	4/1/2019	4/1/2020	1	Combo Fountain	In classroom 112	Right	WF-04012019-003865	11/3/2019	FT-FY20-102019-003865-A	<1	FT-FY20-102019-003865-B	<1
WS- 003866	4/1/2019	4/1/2020	1	Cooler	In hallway adjacent to elevator	High Left	WF-04012019-003866	11/3/2019	FT-FY20-102019-003866-A	<1	FT-FY20-102019-003866-B	<1
WS- 003867	4/1/2019	4/1/2020	1	Cooler	In hallway adjacent to elevator	Low Right	WF-04012019-003867	11/3/2019	FT-FY20-102019-003867-A	<1	FT-FY20-102019-003867-B	<1
WS- 003868	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 116	Left	WF-09092019-003868	11/3/2019	FT-FY20-102019-003868-A	1.8	FT-FY20-102019-003868-B	<1
WS- 003869	4/1/2019	4/1/2020	1	Combo Fountain	In classroom 116	Low Right	WF-04012019-003869	11/3/2019	FT-FY20-102019-003869-A	<1	FT-FY20-102019-003869-B	<1
WS- 003870	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 116	Mid	WF-09092019-003870	11/3/2019	FT-FY20-102019-003870-A	<1	FT-FY20-102019-003870-B	<1
WS- 003871	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 117	Left	WF-09092019-003871	11/3/2019	FT-FY20-102019-003871-A	1.2	FT-FY20-102019-003871-B	<1
WS- 003872	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 117	Mid	WF-09092019-003872	11/3/2019	FT-FY20-102019-003872-A	1.2	FT-FY20-102019-003872-B	<1
WS- 003873	4/1/2019	4/1/2020	1	Combo Fountain	In classroom 117	Low Right	WF-04012019-003873	11/3/2019	FT-FY20-102019-003873-A	<1	FT-FY20-102019-003873-B	<1
WS- 003874	4/1/2019	4/1/2020	1	Health Suite	In health suite		WF-04012019-003874	11/3/2019	FT-FY20-102019-003874-A	<1	FT-FY20-102019-003874-B	<1
WS- 003875	4/1/2019	4/1/2020	1	Cooler	In hallway adjacent to stairwell A	Low Right	WF-04012019-003875	11/3/2019	FT-FY20-102019-003875-A	<1	FT-FY20-102019-003875-B	<1

WS-003876	4/1/2019	4/1/2020	1	Cooler	In hallway adjacent to stairwell A	High	Left	WF-04012019-003876	11/3/2019	FT-FY20-102019-003876-A	<1	FT-FY20-102019-003876-B	<1
WS-003883	4/1/2019	4/1/2020	1	Cooler	In hallway adjacent to room 131	High	Left	WF-04012019-003883	11/3/2019	FT-FY20-102019-003883-A	<1	FT-FY20-102019-003883-B	<1
WS-003884	4/1/2019	4/1/2020	1	Cooler	In hallway adjacent to room 131	Low	Right	WF-04012019-003884	11/3/2019	FT-FY20-102019-003884-A	<1	FT-FY20-102019-003884-B	<1
WS-003885	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent to stairwell A	High	Left	WF-04012019-003885	11/3/2019	FT-FY20-102019-003885-A	<1	FT-FY20-102019-003885-B	<1
WS-003886	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent to stairwell A	Low	Right	WF-04012019-003886	11/3/2019	FT-FY20-102019-003886-A	<1	FT-FY20-102019-003886-B	<1
WS-003894	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent to stairwell B	High	Left	WF-04012019-003894	11/3/2019	FT-FY20-102019-003894-A	<1	FT-FY20-102019-003894-B	<1
WS-003895	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent to stairwell B	Low	Right	WF-04012019-003895	11/3/2019	FT-FY20-102019-003895-A	<1	FT-FY20-102019-003895-B	<1
WS-003896	4/1/2019	4/1/2020	2	Break Room	In staff lounge 213			WF-04012019-003896	11/3/2019	FT-FY20-102019-003896-A	<1	FT-FY20-102019-003896-B	<1
WS-003897	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent to media center	High	Left	WF-04012019-003897	11/3/2019	FT-FY20-102019-003897-A	<1	FT-FY20-102019-003897-B	<1
WS-003898	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent to media center	Low	Right	WF-04012019-003898	11/3/2019	FT-FY20-102019-003898-A	<1	FT-FY20-102019-003898-B	<1
WS-003899	9/9/2019	9/9/2020	2	Classroom Faucet	In classroom 206			WF-09092019-003899	11/3/2019	FT-FY20-102019-003899-A	<1	FT-FY20-102019-003899-B	<1
WS-003900	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent to room 202	High	Left	WF-04012019-003900	11/3/2019	FT-FY20-102019-003900-A	<1	FT-FY20-102019-003900-B	<1
WS-003901	4/1/2019	4/1/2020	2	Cooler	In hallway adjacent to room 202	Low	Right	WF-04012019-003901	11/3/2019	FT-FY20-102019-003901-A	<1	FT-FY20-102019-003901-B	<1
WS-003902	4/1/2019	4/1/2020	3	Cooler	In hallway adjacent to room 302	High	Left	WF-04012019-003902	11/3/2019	FT-FY20-102019-003902-A	<1	FT-FY20-102019-003902-B	<1
WS-003903	4/1/2019	4/1/2020	3	Cooler	In hallway adjacent to room 302	Low	Right	WF-04012019-003903	11/3/2019	FT-FY20-102019-003903-A	<1	FT-FY20-102019-003903-B	<1
WS-003908	4/1/2019	4/1/2020	3	Cooler	In hallway adjacent to room 313	High	Left	WF-04012019-003908	11/3/2019	FT-FY20-102019-003908-A	<1	FT-FY20-102019-003908-B	<1
WS-003909	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 107, in bathroom			WF-09092019-003909	11/3/2019	FT-FY20-102019-003909-A	<1	FT-FY20-102019-003909-B	<1
WS-003912	4/1/2019	4/1/2020	3	Cooler	In hallway adjacent to room 313	Low	Right	WF-04012019-003912	11/3/2019	FT-FY20-102019-003912-A	<1	FT-FY20-102019-003912-B	<1
WS-003913	4/1/2019	4/1/2020	3	Break Room	In break room 316			WF-04012019-003913	11/3/2019	FT-FY20-102019-003913-A	<1	FT-FY20-102019-003913-B	<1
WS-003915	4/1/2019	4/1/2020	3	Cooler	In hallway adjacent to room 316	Low	Right	WF-04012019-003915	11/3/2019	FT-FY20-102019-003915-A	<1	FT-FY20-102019-003915-B	<1
WS-003924	4/1/2019	4/1/2020	3	Cooler	In hallway adjacent to stairwell A	High	Left	WF-04012019-003924	11/3/2019	FT-FY20-102019-003924-A	<1	FT-FY20-102019-003924-B	<1
WS-003925	4/1/2019	4/1/2020	3	Cooler	In hallway adjacent to stairwell A	Low	Right	WF-04012019-003925	11/3/2019	FT-FY20-102019-003925-A	<1	FT-FY20-102019-003925-B	<1
WS-003926	4/1/2019	4/1/2020	Basement	Combo Fountain	In art room B06 first clockwise from entry door			WF-04012019-003926	11/3/2019	FT-FY20-102019-003926-A	<1	FT-FY20-102019-003926-B	<1
WS-004533	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 108, in bathroom			WF-09092019-004533	11/3/2019	FT-FY20-102019-004533-A	<1	FT-FY20-102019-004533-B	<1
WS-004534	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 109, in bathroom			WF-09092019-004534	11/3/2019	FT-FY20-102019-004534-A	<1	FT-FY20-102019-004534-B	<1
WS-004535	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 113, in bathroom			WF-09092019-004535	11/3/2019	FT-FY20-102019-004535-A	<1	FT-FY20-102019-004535-B	<1
WS-004536	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 112, in bathroom			WF-09092019-004536	11/3/2019	FT-FY20-102019-004536-A	<1	FT-FY20-102019-004536-B	<1
WS-004537	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 116, in bathroom			WF-09092019-004537	11/3/2019	FT-FY20-102019-004537-A	<1	FT-FY20-102019-004537-B	<1
WS-004538	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 117, in bathroom			WF-09092019-004538	11/3/2019	FT-FY20-102019-004538-A	<1	FT-FY20-102019-004538-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003878	7/2/2019	7/2/2020	1	Food Prep Sink	In servery room in kitchen on south wall	WF-07022019-003878	11/3/2019	FT-FY20-102019-003878-A	<1	FT-FY20-102019-003878-B	<1

FY20 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-003850	9/9/2019	9/9/2020	1	Classroom Faucet	In classroom 108	Left	WF-09092019-003850	11/3/2019	FT-FY20-102019-003850-A	6.2	FT-FY20-102019-003850-B	<1