



TURNER LEAD WATER TEST RESULTS

May 15, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003933	Classroom	2	In classroom 212	WT-042916-3950-A	< 2	WT-042916-3950-B	< 2				
2	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003932	Classroom	Basement	In art room B06	WT-042916-3949-A	45.3	WT-042916-3949-B	3.4	Filtered	6/14/2016	<1	<1
3	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003931	Classroom	Basement	In art room	WT-042916-3948-A	14	WT-042916-3948-B	< 2				
4	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003930	Classroom	Basement	In art room	WT-042916-3947-A	< 2	WT-042916-3947-B	< 2				
5	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003929	Classroom	Basement	In art room	WT-042916-3946-A	< 2	WT-042916-3946-B	< 2				
6	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003928	Classroom	Basement	In art room	WT-042916-3945-A	< 2	WT-042916-3945-B	< 2				
7	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003927	Classroom	Basement	In art room	WT-042916-3944-A	< 2	WT-042916-3944-B	< 2				
8	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003926	Fountain	Basement	In art room	WT-042916-3943-A	< 1	WT-042916-3943-B	< 2				
9	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003925	Cooler	3	In hallway adjacent to stair A	WT-042916-3942-A	< 2	WT-042916-3942-B	< 2				
10	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003924	Cooler	3	In hallway adjacent to stair A	WT-042916-3941-A	< 2	WT-042916-3941-B	< 2				
11	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003923	Classroom	3	In classroom 324	WT-042916-3940-A	< 2	WT-042916-3940-B	< 2				
12	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003922	Classroom	3	In classroom 323	WT-042916-3939-A	< 2	WT-042916-3939-B	< 2				
13	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003921	Classroom	3	In classroom 322	WT-042916-3938-A	< 2	WT-042916-3938-B	< 2				
14	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003920	Classroom	3	In classroom 320	WT-042916-3937-A	< 2	WT-042916-3937-B	< 2				
15	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003919	Classroom	3	In classroom 321	WT-042916-3936-A	< 2	WT-042916-3936-B	< 2				
16	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003918	Classroom	3	In classroom 318	WT-042916-3935-A	< 2	WT-042916-3935-B	< 2				
17	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003917	Classroom	3	In classroom 319	WT-042916-3934-A	< 2	WT-042916-3934-B	< 2				
18	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003916	Classroom	3	In classroom 315	WT-042916-3933-A	< 2	WT-042916-3933-B	< 2				
19	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003915	Cooler	3	In hallway adjacent to room 316	WT-042916-3932-A	< 2	WT-042916-3932-B	< 2				
20	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003914	Cooler	3	In hallway adjacent to room 316	WT-042916-3931-A	< 2	WT-042916-3931-B	< 2				
21	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003913	Break Room	3	In breakroom 316	WT-042916-3930-A	< 2	WT-042916-3930-B	< 2				
22	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003912	Cooler	3	In hallway adjacent to room 313	WT-042916-3929-A	< 2	WT-042916-3929-B	< 2				
23	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003911	Classroom	3	In science lab adjacent to room 310	WT-042916-3928-A	< 2	WT-042916-3928-B	< 2				
24	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003910	Classroom	3	In science lab adjacent to room 310	WT-042916-3927-A	< 2	WT-042916-3927-B	< 2				
25	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003908	Cooler	3	In hallway adjacent to room 313	WT-042916-3925-A	< 2	WT-042916-3925-B	< 2				
26	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003907	Classroom	3	In science lab adjacent to room 310	WT-042916-3924-A	< 2	WT-042916-3924-B	< 2				
27	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003906	Classroom	3	In classroom 310	WT-042916-3923-A	< 2	WT-042916-3923-B	< 2				
28	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003905	Classroom	3	In classroom 309	WT-042916-3922-A	< 2	WT-042916-3922-B	< 2				
29	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003904	Classroom	3	In classroom 304	WT-042916-3921-A	< 2	WT-042916-3921-B	2.1				
30	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003903	Cooler	3	In hallway adjacent to room 302	WT-042916-3920-A	< 2	WT-042916-3920-B	< 2				
31	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003902	Cooler	3	In hallway adjacent to room 302	WT-042916-3919-A	< 2	WT-042916-3919-B	< 2				
32	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003901	Cooler	2	In hallway adjacent to room 202	WT-042916-3918-A	< 2	WT-042916-3918-B	< 2				
33	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003900	Cooler	2	In hallway adjacent to room 202	WT-042916-3917-A	< 2	WT-042916-3917-B	< 2				
34	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003899	Classroom	2	In classroom 206	WT-042916-3916-A	< 2	WT-042916-3916-B	< 2				
35	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003898	Cooler	2	In hallway adjacent to media center	WT-042916-3915-A	< 2	WT-042916-3915-B	< 2				
36	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003897	Cooler	2	In hallway adjacent to media center	WT-042916-3914-A	< 2	WT-042916-3914-B	< 2				
37	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003896	Break Room	2	In teacher's lounge 213	WT-042916-3913-A	< 2	WT-042916-3913-B	< 2				
38	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003895	Cooler	2	In hallway adjacent to stair B	WT-042916-3912-A	< 2	WT-042916-3912-B	< 2				
39	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003894	Cooler	2	In hallway adjacent to Stair B	WT-042916-3911-A	< 2	WT-042916-3911-B	< 2				
40	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003893	Classroom	2	In classroom 215	WT-042916-3910-A	< 2	WT-042916-3910-B	< 2				
41	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003892	Classroom	2	In classroom 216	WT-042916-3909-A	< 2	WT-042916-3909-B	< 2				
42	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003891	Classroom	2	In classroom 217	WT-042916-3908-A	< 2	WT-042916-3908-B	< 2				
43	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003890	Classroom	2	In classroom 218	WT-042916-3907-A	< 2	WT-042916-3907-B	< 2				
44	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003889	Classroom	2	In classroom 219	WT-042916-3906-A	< 2	WT-042916-3906-B	< 2				
45	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003888	Classroom	2	In classroom 220	WT-042916-3905-A	< 2	WT-042916-3905-B	< 2				
46	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003887	Classroom	2	In classroom 221	WT-042916-3904-A	< 2	WT-042916-3904-B	< 2				
47	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003886	Cooler	2	In hallway adjacent to stair A	WT-042916-3903-A	< 2	WT-042916-3903-B	< 2				
48	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003885	Cooler	2	In hallway adjacent to stair A	WT-042916-3902-A	< 2	WT-042916-3902-B	< 2				
49	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003884	Cooler	1	In hallway adjacent to room 131	WT-042916-3901-A	< 2	WT-042916-3901-B	< 2				
50	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003883	Cooler	1	In hallway adjacent to room 131	WT-042916-3900-A	< 2	WT-042916-3900-B	< 2				
51	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003882	Kitchen	1	In kitchen	WT-042916-3899-A	< 2	WT-042916-3899-B	< 2				
52	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003881	Kitchen	1	In kitchen southwest center wall	WT-042916-3898-A	< 2	WT-042916-3898-B	< 2				
53	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003880	Kitchen	1	In kitchen northeast wall	WT-042916-3897-A	< 2	WT-042916-3897-B	< 2				
54	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003879	Kitchen	1	In kitchen northeast wall - dish washing spray nozzle	WT-042916-3896-A	< 2	WT-042916-3896-B	< 2				
55	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003878	Kitchen	1	In kitchen northeast wall	WT-042916-3895-A	< 2	WT-042916-3895-B	< 2				
56	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003877	Kitchen	1	In kitchen south west wall	WT-042916-3894-A	< 2	WT-042916-3894-B	< 2				
57	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003876	Cooler	1	In hallway adjacent to stair A	WT-042916-3893-A	< 2	WT-042916-3893-B	< 2				
58	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003875	Cooler	1	In hallway adjacent to stair A	WT-042916-3892-A	< 2	WT-042916-3892-B	< 2				
59	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003874	Classroom	1	In health suite	WT-042916-3891-A	< 2	WT-042916-3891-B	< 2				



TURNER LEAD WATER TEST RESULTS

May 15, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
60	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003873	Fountain	1	In classroom 117	WT-042916-3890- A	249	WT-042916-3890- B	19.4	Filtered	6/14/2016	<1	<1
61	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003872	Classroom	1	In classroom 117	WT-042916-3889- A	98.6	WT-042916-3889- B	2.2	Filtered	6/14/2016	<1	<1
62	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003871	Classroom	1	In classroom 117	WT-042916-3888- A	< 2	WT-042916-3888- B	< 2				
63	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003870	Classroom	1	In classroom 116	WT-042916-3887- A	7.4	WT-042916-3887- B	< 2				
64	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003869	Fountain	1	In classroom 116	WT-042916-3886- A	18.5	WT-042916-3886- B	2.7	Filtered	6/14/2016	<1	<1
65	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003868	Classroom	1	In classroom 116	WT-042916-3885- A	< 2	WT-042916-3885- B	< 2				
66	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003867	Cooler	1	In hallway adjacent to elevator	WT-042916-3884- A	< 2	WT-042916-3884- B	< 2				
67	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003866	Cooler	1	In hallway adjacent to elevator	WT-042916-3883- A	< 2	WT-042916-3883- B	< 2				
68	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003865	Fountain	1	In classroom 112	WT-042916-3882- A	< 2	WT-042916-3882- B	< 2				
69	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003864	Classroom	1	In classroom 112	WT-042916-3881- A	< 2	WT-042916-3881- B	< 2				
70	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003863	Classroom	1	In classroom 112	WT-042916-3880- A	19	WT-042916-3880- B	< 2	Filtered	6/14/2016	<1	<1
71	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003862	Classroom	1	In classroom 113	WT-042916-3879- A	< 2	WT-042916-3879- B	< 2				
72	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003861	Classroom	1	In classroom 113	WT-042916-3878- A	< 2	WT-042916-3878- B	< 2				
73	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003860	Fountain	1	In classroom 113	WT-042916-3877- A	< 2	WT-042916-3877- B	< 2				
74	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003859	Classroom	1	In classroom 110	WT-042916-3876- A	< 2	WT-042916-3876- B	< 2				
75	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003858	Fountain	1	In classroom 109A	WT-042916-3875- A	< 2	WT-042916-3875- B	< 2				
76	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003857	Classroom	1	In classroom 109a	WT-042916-3874- A	< 2	WT-042916-3874- B	< 2				
77	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003856	Fountain	1	In classroom 109B	WT-042916-3873- A	2.1	WT-042916-3873- B	< 2				
78	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003855	Classroom	1	In classroom 109B	WT-042916-3872- A	< 2	WT-042916-3872- B	< 2				
79	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003854	Cooler	1	In hallway adjacent 110	WT-042916-3871- A	< 2	WT-042916-3871- B	< 2				
80	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003853	Fountain	1	In hallway adjacent to room 110	WT-042916-3870- A	< 2	WT-042916-3870- B	< 2				
81	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003852	Fountain	1	In class room 108	WT-042916-3869- A	< 2	WT-042916-3869- B	< 2				
82	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003851	Classroom	1	In classroom 108	WT-042916-3868- A	< 2	WT-042916-3868- B	< 2				
83	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003850	Classroom	1	In classroom 108	WT-042916-3867- A	2.3	WT-042916-3867- B	< 2				
84	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003849	Fountain	1	In classroom 107	WT-042916-3866- A	< 2	WT-042916-3866- B	< 2				
85	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003848	Classroom	1	In classroom 107	WT-042916-3865- A	< 2	WT-042916-3865- B	< 2				
86	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003847	Classroom	1	In classroom 107	WT-042916-3864- A	< 2	WT-042916-3864- B	< 2				
87	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003846	Classroom	1	In classroom 106	WT-042916-3863- A	< 2	WT-042916-3863- B	< 2				
88	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003845	Classroom	1	In classroom 106	WT-042916-3862- A	< 2	WT-042916-3862- B	< 2				
89	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003844	Fountain	1	In classroom 106	WT-042916-3861- A	5.5	WT-042916-3861- B	< 2				
90	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003843	Cooler	1	In hallway adjacent to room 102	WT-042916-3860- A	< 2	WT-042916-3860- B	< 2				
91	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003842	Cooler	1	In hallway adjacent to room 102	WT-042916-3859- A	< 2	WT-042916-3859- B	< 2				
92	TURNER ELEMENTARY SCHOOL	5/5/2016	WS- 003841	Utility	Basement	Main water line entrance boiler room	WT-042916-3858- A	2.3	WT-042916-3858- B	< 2				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.