



# TURNER LEAD WATER TEST RESULTS

May 15, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003933	Classroom	2	in classroom 212	WT-042916-3950- A	< 2	WT-042916-3950- B	< 2				
2	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003932	Classroom	Basement	In art room B06	WT-042916-3949- A	45.3	WT-042916-3949- B	3.4	Filter will be installed and then retested			
3	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003931	Classroom	Basement	In art room	WT-042916-3948- A	14	WT-042916-3948- B	< 2				
4	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003930	Classroom	Basement	In art room	WT-042916-3947- A	< 2	WT-042916-3947- B	< 2				
5	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003929	Classroom	Basement	In art room	WT-042916-3946- A	< 2	WT-042916-3946- B	< 2				
6	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003928	Classroom	Basement	In art room	WT-042916-3945- A	< 2	WT-042916-3945- B	< 2				
7	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003927	Classroom	Basement	In art room	WT-042916-3944- A	< 2	WT-042916-3944- B	< 2				
8	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003926	Fountain	Basement	In art room	WT-042916-3943- A	< 1	WT-042916-3943- B	< 2				
9	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003925	Cooler	3	In hallway adjacent to stair A	WT-042916-3942- A	< 2	WT-042916-3942- B	< 2				
10	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003924	Cooler	3	In hallway adjacent to stair A	WT-042916-3941- A	< 2	WT-042916-3941- B	< 2				
11	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003923	Classroom	3	In classroom 324	WT-042916-3940- A	< 2	WT-042916-3940- B	< 2				
12	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003922	Classroom	3	In classroom 323	WT-042916-3939- A	< 2	WT-042916-3939- B	< 2				
13	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003921	Classroom	3	In classroom 322	WT-042916-3938- A	< 2	WT-042916-3938- B	< 2				
14	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003920	Classroom	3	In classroom 320	WT-042916-3937- A	< 2	WT-042916-3937- B	< 2				
15	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003919	Classroom	3	In classroom 321	WT-042916-3936- A	< 2	WT-042916-3936- B	< 2				
16	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003918	Classroom	3	In classroom 318	WT-042916-3935- A	< 2	WT-042916-3935- B	< 2				
17	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003917	Classroom	3	In classroom 319	WT-042916-3934- A	< 2	WT-042916-3934- B	< 2				
18	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003916	Classroom	3	In classroom 315	WT-042916-3933- A	< 2	WT-042916-3933- B	< 2				
19	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003915	Cooler	3	In hallway adjacent to room 316	WT-042916-3932- A	< 2	WT-042916-3932- B	< 2				
20	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003914	Cooler	3	In hallway adjacent to room 316	WT-042916-3931- A	< 2	WT-042916-3931- B	< 2				
21	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003913	Break Room	3	In breakroom 316	WT-042916-3930- A	< 2	WT-042916-3930- B	< 2				
22	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003912	Cooler	3	In hallway adjacent to room 313	WT-042916-3929- A	< 2	WT-042916-3929- B	< 2				
23	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003911	Classroom	3	In science lab adjacent to room 310	WT-042916-3928- A	< 2	WT-042916-3928- B	< 2				
24	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003910	Classroom	3	In science lab adjacent to room 310	WT-042916-3927- A	< 2	WT-042916-3927- B	< 2				
25	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003908	Cooler	3	In hallway adjacent to room 313	WT-042916-3925- A	< 2	WT-042916-3925- B	< 2				
26	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003907	Classroom	3	In science lab adjacent to room 310	WT-042916-3924- A	< 2	WT-042916-3924- B	< 2				
27	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003906	Classroom	3	In classroom 310	WT-042916-3923- A	< 2	WT-042916-3923- B	< 2				
28	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003905	Classroom	3	In classroom 309	WT-042916-3922- A	< 2	WT-042916-3922- B	< 2				
29	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003904	Classroom	3	In classroom 304	WT-042916-3921- A	< 2	WT-042916-3921- B	2.1				
30	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003903	Cooler	3	In hallway adjacent to room 302	WT-042916-3920- A	< 2	WT-042916-3920- B	< 2				
31	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003902	Cooler	3	In hallway adjacent to room 302	WT-042916-3919- A	< 2	WT-042916-3919- B	< 2				
32	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003901	Cooler	2	In hallway adjacent to room 202	WT-042916-3918- A	< 2	WT-042916-3918- B	< 2				
33	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003900	Cooler	2	In hallway adjacent to room 202	WT-042916-3917- A	< 2	WT-042916-3917- B	< 2				
34	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003899	Classroom	2	In classroom 206	WT-042916-3916- A	< 2	WT-042916-3916- B	< 2				
35	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003898	Cooler	2	In hallway adjacent to media center	WT-042916-3915- A	< 2	WT-042916-3915- B	< 2				
36	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003897	Cooler	2	In hallway adjacent to media center	WT-042916-3914- A	< 2	WT-042916-3914- B	< 2				
37	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003896	Break Room	2	In teacher's lounge 213	WT-042916-3913- A	< 2	WT-042916-3913- B	< 2				
38	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003895	Cooler	2	In hallway adjacent to stair B	WT-042916-3912- A	< 2	WT-042916-3912- B	< 2				
39	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003894	Cooler	2	In hallway adjacent to Stair B	WT-042916-3911- A	< 2	WT-042916-3911- B	< 2				
40	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003893	Classroom	2	In classroom 215	WT-042916-3910- A	< 2	WT-042916-3910- B	< 2				
41	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003892	Classroom	2	In classroom 216	WT-042916-3909- A	< 2	WT-042916-3909- B	< 2				
42	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003891	Classroom	2	In classroom 217	WT-042916-3908- A	< 2	WT-042916-3908- B	< 2				
43	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003890	Classroom	2	In classroom 218	WT-042916-3907- A	< 2	WT-042916-3907- B	< 2				
44	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003889	Classroom	2	In classroom 219	WT-042916-3906- A	< 2	WT-042916-3906- B	< 2				
45	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003888	Classroom	2	In classroom 220	WT-042916-3905- A	< 2	WT-042916-3905- B	< 2				
46	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003887	Classroom	2	In classroom 221	WT-042916-3904- A	< 2	WT-042916-3904- B	< 2				
47	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003886	Cooler	2	In hallway adjacent to stair A	WT-042916-3903- A	< 2	WT-042916-3903- B	< 2				
48	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003885	Cooler	2	In hallway adjacent to stair A	WT-042916-3902- A	< 2	WT-042916-3902- B	< 2				
49	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003884	Cooler	1	In hallway adjacent to room 131	WT-042916-3901- A	< 2	WT-042916-3901- B	< 2				
50	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003883	Cooler	1	In hallway adjacent to room 131	WT-042916-3900- A	< 2	WT-042916-3900- B	< 2				
51	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003882	Kitchen	1	In kitchen	WT-042916-3899- A	< 2	WT-042916-3899- B	< 2				
52	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003881	Kitchen	1	In kitchen southwest center wall	WT-042916-3898- A	< 2	WT-042916-3898- B	< 2				
53	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003880	Kitchen	1	In kitchen northeast wall	WT-042916-3897- A	< 2	WT-042916-3897- B	< 2				
54	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003879	Kitchen	1	In kitchen northeast wall - dish washing spray nozzle	WT-042916-3896- A	< 2	WT-042916-3896- B	< 2				
55	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003878	Kitchen	1	In kitchen northeast wall	WT-042916-3895- A	< 2	WT-042916-3895- B	< 2				
56	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003877	Kitchen	1	In kitchen south west wall	WT-042916-3894- A	< 2	WT-042916-3894- B	< 2				
57	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003876	Cooler	1	In hallway adjacent to stair A	WT-042916-3893- A	< 2	WT-042916-3893- B	< 2				
58	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003875	Cooler	1	In hallway adjacent to stair A	WT-042916-3892- A	< 2	WT-042916-3892- B	< 2				
59	TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003874	Classroom	1	In health suite	WT-042916-3891- A	< 2	WT-042916-3891- B	< 2				



# TURNER LEAD WATER TEST RESULTS

May 15, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
60 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003873	Fountain	1	In classroom 117 Right Low	WT-042916-3890-A	249	WT-042916-3890-B	19.4	Filter will be installed and then retested			
61 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003872	Classroom	1	In classroom 117 Mid	WT-042916-3889-A	98.6	WT-042916-3889-B	2.2	Filter will be installed and then retested			
62 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003871	Classroom	1	In classroom 117 Left	WT-042916-3888-A	< 2	WT-042916-3888-B	< 2				
63 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003870	Classroom	1	In classroom 116 Mid	WT-042916-3887-A	7.4	WT-042916-3887-B	< 2				
64 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003869	Fountain	1	In classroom 116 Right Low	WT-042916-3886-A	18.5	WT-042916-3886-B	2.7	Filter will be installed and then retested			
65 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003868	Classroom	1	In classroom 116 Left	WT-042916-3885-A	< 2	WT-042916-3885-B	< 2				
66 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003867	Cooler	1	In hallway adjacent to elevator Right Low	WT-042916-3884-A	< 2	WT-042916-3884-B	< 2				
67 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003866	Cooler	1	In hallway adjacent to elevator Left High	WT-042916-3883-A	< 2	WT-042916-3883-B	< 2				
68 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003865	Fountain	1	In classroom 112 Right	WT-042916-3882-A	< 2	WT-042916-3882-B	< 2				
69 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003864	Classroom	1	In classroom 112 Mid	WT-042916-3881-A	< 2	WT-042916-3881-B	< 2				
70 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003863	Classroom	1	In classroom 112 Left	WT-042916-3880-A	19	WT-042916-3880-B	< 2	Filter will be installed and then retested			
71 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003862	Classroom	1	In classroom 113 Right	WT-042916-3879-A	< 2	WT-042916-3879-B	< 2				
72 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003861	Classroom	1	In classroom 113 Right	WT-042916-3878-A	< 2	WT-042916-3878-B	< 2				
73 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003860	Fountain	1	In classroom 113 Left	WT-042916-3877-A	< 2	WT-042916-3877-B	< 2				
74 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003859	Classroom	1	In classroom 110 Mid	WT-042916-3876-A	< 2	WT-042916-3876-B	< 2				
75 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003858	Fountain	1	In classroom 109A Right	WT-042916-3875-A	< 2	WT-042916-3875-B	< 2				
76 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003857	Classroom	1	In classroom 109A Left	WT-042916-3874-A	< 2	WT-042916-3874-B	< 2				
77 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003856	Fountain	1	In classroom 109B Right	WT-042916-3873-A	2.1	WT-042916-3873-B	< 2				
78 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003855	Classroom	1	In classroom 109B Left	WT-042916-3872-A	< 2	WT-042916-3872-B	< 2				
79 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003854	Cooler	1	In hallway adjacent 110 Right Low	WT-042916-3871-A	< 2	WT-042916-3871-B	< 2				
80 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003853	Fountain	1	In hallway adjacent to room 110 Left High	WT-042916-3870-A	< 2	WT-042916-3870-B	< 2				
81 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003852	Fountain	1	In class room 108 Right	WT-042916-3869-A	< 2	WT-042916-3869-B	< 2				
82 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003851	Classroom	1	In classroom 108 Mid	WT-042916-3868-A	< 2	WT-042916-3868-B	< 2				
83 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003850	Classroom	1	In classroom 108 Left	WT-042916-3867-A	2.3	WT-042916-3867-B	< 2				
84 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003849	Fountain	1	In classroom 107 Right	WT-042916-3866-A	< 2	WT-042916-3866-B	< 2				
85 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003848	Classroom	1	In classroom 107 Mid	WT-042916-3865-A	< 2	WT-042916-3865-B	< 2				
86 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003847	Classroom	1	In classroom 107 Left	WT-042916-3864-A	< 2	WT-042916-3864-B	< 2				
87 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003846	Classroom	1	In classroom 106 Right	WT-042916-3863-A	< 2	WT-042916-3863-B	< 2				
88 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003845	Classroom	1	In classroom 106 Mid	WT-042916-3862-A	< 2	WT-042916-3862-B	< 2				
89 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003844	Fountain	1	In classroom 106 Left	WT-042916-3861-A	5.5	WT-042916-3861-B	< 2				
90 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003843	Cooler	1	In hallway adjacent to room 102 Right Low	WT-042916-3860-A	< 2	WT-042916-3860-B	< 2				
91 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003842	Cooler	1	In hallway adjacent to room 102 Left High	WT-042916-3859-A	< 2	WT-042916-3859-B	< 2				
92 TURNER ELEMENTARY SCHOOL	5/5/2016	WS-003841	Utility	Basement	Main water line entrance boiler room	WT-042916-3858-A	2.3	WT-042916-3858-B	< 2				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.