



# TURNER ES LEAD WATER TEST RESULTS



## Initial Filter Test After Installation

| Building Location: Building Name | RECORD ID  | Date Analyzed | Floor | Device Type      | Device Location               | 1st Draw - Sample ID | Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ppb) |     |
|----------------------------------|------------|---------------|-------|------------------|-------------------------------|----------------------|-------------------------------|----------------------|-------------------------------|-----|
| 1 TURNER ELEMENTARY SCHOOL       | WS- 003913 | 12/21/2016    | 3     | Break Room       | In break room 316             | FT-102016-003913-A   | < 1                           | FT-102016-003913-B   | < 1                           |     |
| 2 TURNER ELEMENTARY SCHOOL       | WS- 003896 | 12/21/2016    | 2     | Break Room       | In staff lounge 213           | FT-102016-003896-A   | < 1                           | FT-102016-003896-B   | < 1                           |     |
| 3 TURNER ELEMENTARY SCHOOL       | WS- 003909 | 12/21/2016    | 1     | Classroom Faucet | In classroom 107, in bathroom | FT-122016-003909-A   | < 1                           | FT-122016-003909-B   | < 1                           |     |
| 4 TURNER ELEMENTARY SCHOOL       | WS- 004533 | 12/21/2016    | 1     | Classroom Faucet | In classroom 108, in bathroom | FT-122016-004533-A   | < 1                           | FT-122016-004533-B   | < 1                           |     |
| 5 TURNER ELEMENTARY SCHOOL       | WS- 003840 | 12/21/2016    | 1     | Classroom Faucet | In classroom 106, in bathroom | FT-122016-003840-A   | < 1                           | FT-122016-003840-B   | < 1                           |     |
| 6 TURNER ELEMENTARY SCHOOL       | WS- 003851 | 12/21/2016    | 1     | Combo Faucet     | In classroom 108              | Mid                  | FT-122016-003851-A            | < 1                  | FT-122016-003851-B            | < 1 |
| 7 TURNER ELEMENTARY SCHOOL       | WS- 003899 | 12/21/2016    | 2     | Classroom Faucet | In classroom 206              | FT-122016-003899-A   | < 1                           | FT-122016-003899-B   | < 1                           |     |
| 8 TURNER ELEMENTARY SCHOOL       | WS- 004537 | 12/21/2016    | 1     | Classroom Faucet | In classroom 116, in bathroom | FT-122016-004537-A   | < 1                           | FT-122016-004537-B   | < 1                           |     |
| 9 TURNER ELEMENTARY SCHOOL       | WS- 003847 | 12/21/2016    | 1     | Classroom Faucet | In classroom 107              | Left                 | FT-122016-003847-A            | < 1                  | FT-122016-003847-B            | < 1 |
| ## TURNER ELEMENTARY SCHOOL      | WS- 004535 | 12/21/2016    | 1     | Classroom Faucet | In classroom 113, in bathroom | FT-122016-004535-A   | < 1                           | FT-122016-004535-B   | < 1                           |     |
| ## TURNER ELEMENTARY SCHOOL      | WS- 004538 | 12/21/2016    | 1     | Classroom Faucet | In classroom 117, in bathroom | FT-122016-004538-A   | < 1                           | FT-122016-004538-B   | < 1                           |     |
| ## TURNER ELEMENTARY SCHOOL      | WS- 003850 | 12/21/2016    | 1     | Classroom Faucet | In classroom 108              | Left                 | FT-122016-003850-A            | < 1                  | FT-122016-003850-B            | < 1 |
| ## TURNER ELEMENTARY SCHOOL      | WS- 003870 | 12/21/2016    | 1     | Combo Faucet     | In classroom 116              | Mid                  | FT-122016-003870-A            | < 1                  | FT-122016-003870-B            | < 1 |
| ## TURNER ELEMENTARY SCHOOL      | WS- 003848 | 12/21/2016    | 1     | Combo Faucet     | In classroom 107              | Mid                  | FT-122016-003848-A            | < 1                  | FT-122016-003848-B            | < 1 |
| ## TURNER ELEMENTARY SCHOOL      | WS- 003845 | 12/21/2016    | 1     | Combo Faucet     | In classroom 106              | Mid                  | FT-122016-003845-A            | < 1                  | FT-122016-003845-B            | < 1 |
| ## TURNER ELEMENTARY SCHOOL      | WS- 003868 | 12/21/2016    | 1     | Classroom Faucet | In classroom 116              | Left                 | FT-122016-003868-A            | < 1                  | FT-122016-003868-B            | < 1 |
| ## TURNER ELEMENTARY SCHOOL      | WS- 003862 | 12/21/2016    | 1     | Classroom Faucet | In classroom 113              | Right                | FT-122016-003862-A            | < 1                  | FT-122016-003862-B            | < 1 |
| ## TURNER ELEMENTARY SCHOOL      | WS- 003846 | 12/21/2016    | 1     | Classroom Faucet | In classroom 106              | Right                | FT-122016-003846-A            | < 1                  | FT-122016-003846-B            | < 1 |
| ## TURNER ELEMENTARY SCHOOL      | WS- 003861 | 12/21/2016    | 1     | Combo Faucet     | In classroom 113              | Mid                  | FT-122016-003861-A            | < 1                  | FT-122016-003861-B            | < 1 |
| ## TURNER ELEMENTARY SCHOOL      | WS- 003863 | 12/21/2016    | 1     | Classroom Faucet | In classroom 112              | Mid                  | FT-122016-003863-A            | < 1                  | FT-122016-003863-B            | < 1 |
| ## TURNER ELEMENTARY SCHOOL      | WS- 003864 | 12/21/2016    | 1     | Combo Faucet     | In classroom 112              | Left                 | FT-122016-003864-A            | < 1                  | FT-122016-003864-B            | < 1 |
| ## TURNER ELEMENTARY SCHOOL      | WS- 003872 | 12/21/2016    | 1     | Combo Faucet     | In classroom 117              | Mid                  | FT-122016-003872-A            | < 1                  | FT-122016-003872-B            | < 1 |
| ## TURNER ELEMENTARY SCHOOL      | WS- 004536 | 12/21/2016    | 1     | Classroom Faucet | In classroom 112, in bathroom | FT-122016-004536-A   | < 1                           | FT-122016-004536-B   | < 1                           |     |
| ## TURNER ELEMENTARY SCHOOL      | WS- 003857 | 12/21/2016    | 1     | Combo Faucet     | In classroom 109A             | Left                 | FT-122016-003857-A            | < 1                  | FT-122016-003857-B            | < 1 |
| ## TURNER ELEMENTARY SCHOOL      | WS- 003855 | 12/21/2016    | 1     | Combo Faucet     | In classroom 109B             | Left                 | FT-122016-003855-A            | < 1                  | FT-122016-003855-B            | < 1 |
| ## TURNER ELEMENTARY SCHOOL      | WS- 004534 | 12/21/2016    | 1     | Classroom Faucet | In classroom 109, in bathroom | FT-122016-004534-A   | < 1                           | FT-122016-004534-B   | < 1                           |     |
| ## TURNER ELEMENTARY SCHOOL      | WS- 003871 | 12/21/2016    | 1     | Classroom Faucet | In classroom 117              | Left                 | FT-122016-003871-A            | < 1                  | FT-122016-003871-B            | < 1 |

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb