



Turner ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003762	4/9/2018	4/9/2019	1	Cooler	In hallway adjacent to room 110	Low Right	WF-04092018-003762	11/2/2018	FT-FY19-102018-003762-A	< 1	FT-FY19-102018-003762-B	< 1
WS- 003840	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 106, in bathroom		WF-09182018-003840	11/2/2018	FT-FY19-102018-003840-A	< 1	FT-FY19-102018-003840-B	< 1
WS- 003842	4/9/2018	4/9/2019	1	Cooler	In hallway adjacent to room 102	High Left	WF-04092018-003842	11/2/2018	FT-FY19-102018-003842-A	< 1	FT-FY19-102018-003842-B	< 1
WS- 003843	4/9/2018	4/9/2019	1	Cooler	In hallway adjacent to room 102	Low Right	WF-04092018-003843	11/2/2018	FT-FY19-102018-003843-A	< 1	FT-FY19-102018-003843-B	< 1
WS- 003844	4/9/2018	4/9/2019	1	Combo Fountain	In classroom 106	Left	WF-04092018-003844	11/2/2018	FT-FY19-102018-003844-A	< 1	FT-FY19-102018-003844-B	< 1
WS- 003845	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 106	Mid	WF-09182018-003845	11/2/2018	FT-FY19-102018-003845-A	< 1	FT-FY19-102018-003845-B	< 1
WS- 003846	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 106	Right	WF-09182018-003846	11/2/2018	FT-FY19-102018-003846-A	< 1	FT-FY19-102018-003846-B	< 1
WS- 003847	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 107	Left	WF-09182018-003847	11/2/2018	FT-FY19-102018-003847-A	< 1	FT-FY19-102018-003847-B	< 1
WS- 003848	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 107	Mid	WF-09182018-003848	11/2/2018	FT-FY19-102018-003848-A	< 1	FT-FY19-102018-003848-B	< 1
WS- 003849	4/9/2018	4/9/2019	1	Combo Fountain	In classroom 107	Right	WF-04092018-003849	11/2/2018	FT-FY19-102018-003849-A	< 1	FT-FY19-102018-003849-B	< 1
WS- 003850	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 108	Left	WF-09182018-003850	11/2/2018	FT-FY19-102018-003850-A	< 1	FT-FY19-102018-003850-B	< 1
WS- 003851	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 108	Mid	WF-09182018-003851	11/2/2018	FT-FY19-102018-003851-A	< 1	FT-FY19-102018-003851-B	< 1
WS- 003852	4/9/2018	4/9/2019	1	Combo Fountain	In classroom 108	Right	WF-04092018-003852	11/2/2018	FT-FY19-102018-003852-A	< 1	FT-FY19-102018-003852-B	< 1
WS- 003853	4/9/2018	4/9/2019	1	Cooler	In hallway adjacent to room 110	High Left	WF-04092018-003853	11/2/2018	FT-FY19-102018-003853-A	< 1	FT-FY19-102018-003853-B	< 1
WS- 003854	4/9/2018	4/9/2019	1	Bottle Filler	In hallway adjacent to room 110 (bottle filler)		WF-04092018-003854	11/2/2018	FT-FY19-102018-003854-A	< 1	FT-FY19-102018-003854-B	< 1
WS- 003855	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 109B	Left	WF-09182018-003855	11/2/2018	FT-FY19-102018-003855-A	< 1	FT-FY19-102018-003855-B	< 1
WS- 003856	4/9/2018	4/9/2019	1	Combo Fountain	In classroom 109B	Right	WF-04092018-003856	11/2/2018	FT-FY19-102018-003856-A	< 1	FT-FY19-102018-003856-B	< 1
WS- 003857	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 109A	Left	WF-09182018-003857	11/2/2018	FT-FY19-102018-003857-A	< 1	FT-FY19-102018-003857-B	< 1
WS- 003858	4/9/2018	4/9/2019	1	Combo Fountain	In classroom 109A	Right	WF-04092018-003858	11/2/2018	FT-FY19-102018-003858-A	< 1	FT-FY19-102018-003858-B	< 1
WS- 003860	4/9/2018	4/9/2019	1	Combo Fountain	In classroom 113	Left	WF-04092018-003860	11/2/2018	FT-FY19-102018-003860-A	< 1	FT-FY19-102018-003860-B	< 1
WS- 003861	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 113	Mid	WF-09182018-003861	11/2/2018	FT-FY19-102018-003861-A	< 1	FT-FY19-102018-003861-B	< 1
WS- 003862	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 113	Right	WF-09182018-003862	11/2/2018	FT-FY19-102018-003862-A	< 1	FT-FY19-102018-003862-B	< 1
WS- 003863	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 112	Mid	WF-09182018-003863	11/2/2018	FT-FY19-102018-003863-A	< 1	FT-FY19-102018-003863-B	< 1
WS- 003864	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 112	Left	WF-09182018-003864	11/2/2018	FT-FY19-102018-003864-A	< 1	FT-FY19-102018-003864-B	< 1
WS- 003865	4/9/2018	4/9/2019	1	Combo Fountain	In classroom 112	Right	WF-04092018-003865	11/2/2018	FT-FY19-102018-003865-A	< 1	FT-FY19-102018-003865-B	< 1
WS- 003866	4/9/2018	4/9/2019	1	Cooler	In hallway adjacent to elevator	High Left	WF-04092018-003866	11/2/2018	FT-FY19-102018-003866-A	< 1	FT-FY19-102018-003866-B	< 1
WS- 003867	4/9/2018	4/9/2019	1	Cooler	In hallway adjacent to elevator	Low Right	WF-04092018-003867	11/2/2018	FT-FY19-102018-003867-A	< 1	FT-FY19-102018-003867-B	< 1
WS- 003868	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 116	Left	WF-09182018-003868	11/2/2018	FT-FY19-102018-003868-A	< 1	FT-FY19-102018-003868-B	< 1
WS- 003869	4/9/2018	4/9/2019	1	Combo Fountain	In classroom 116	Low Right	WF-04092018-003869	11/2/2018	FT-FY19-102018-003869-A	< 1	FT-FY19-102018-003869-B	< 1
WS- 003870	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 116	Mid	WF-09182018-003870	11/2/2018	FT-FY19-102018-003870-A	< 1	FT-FY19-102018-003870-B	< 1
WS- 003871	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 117	Left	WF-09182018-003871	11/2/2018	FT-FY19-102018-003871-A	< 1	FT-FY19-102018-003871-B	< 1
WS- 003872	9/18/2018	9/18/2019	1	Combo Faucet	In classroom 117	Mid	WF-09182018-003872	11/2/2018	FT-FY19-102018-003872-A	< 1	FT-FY19-102018-003872-B	< 1
WS- 003873	4/9/2018	4/9/2019	1	Combo Fountain	In classroom 117	Low Right	WF-04092018-003873	11/2/2018	FT-FY19-102018-003873-A	< 1	FT-FY19-102018-003873-B	< 1
WS- 003874	4/9/2018	4/9/2019	1	Health Suite	In health suite		WF-04092018-003874	11/2/2018	FT-FY19-102018-003874-A	< 1	FT-FY19-102018-003874-B	< 1
WS- 003875	4/9/2018	4/9/2019	1	Cooler	In hallway adjacent to stairwell A	Low Right	WF-04092018-003875	11/2/2018	FT-FY19-102018-003875-A	< 1	FT-FY19-102018-003875-B	< 1

WS-003876	4/9/2018	4/9/2019	1	Cooler	In hallway adjacent to stairwell A	High Left	WF-04092018-003876	11/2/2018	FT-FY19-102018-003876-A	< 1	FT-FY19-102018-003876-B	< 1
WS-003883	4/9/2018	4/9/2019	1	Cooler	In hallway adjacent to room 131	High Left	WF-04092018-003883	11/2/2018	FT-FY19-102018-003883-A	< 1	FT-FY19-102018-003883-B	< 1
WS-003884	4/9/2018	4/9/2019	1	Cooler	In hallway adjacent to room 131	Low Right	WF-04092018-003884	11/2/2018	FT-FY19-102018-003884-A	< 1	FT-FY19-102018-003884-B	< 1
WS-003885	4/9/2018	4/9/2019	2	Cooler	In hallway adjacent to stairwell A	High Left	WF-04092018-003885	11/2/2018	FT-FY19-102018-003885-A	< 1	FT-FY19-102018-003885-B	< 1
WS-003886	4/9/2018	4/9/2019	2	Cooler	In hallway adjacent to stairwell A	Low Right	WF-04092018-003886	11/2/2018	FT-FY19-102018-003886-A	< 1	FT-FY19-102018-003886-B	< 1
WS-003894	4/9/2018	4/9/2019	2	Cooler	In hallway adjacent to stairwell B	High Left	WF-04092018-003894	11/2/2018	FT-FY19-102018-003894-A	< 1	FT-FY19-102018-003894-B	< 1
WS-003895	4/9/2018	4/9/2019	2	Cooler	In hallway adjacent to stairwell B	Low Right	WF-04092018-003895	11/2/2018	FT-FY19-102018-003895-A	< 1	FT-FY19-102018-003895-B	< 1
WS-003896	4/9/2018	4/9/2019	2	Break Room	In staff lounge 213		WF-04092018-003896	11/2/2018	FT-FY19-102018-003896-A	< 1	FT-FY19-102018-003896-B	< 1
WS-003897	4/9/2018	4/9/2019	2	Cooler	In hallway adjacent to media center	High Left	WF-04092018-003897	11/2/2018	FT-FY19-102018-003897-A	< 1	FT-FY19-102018-003897-B	< 1
WS-003898	4/9/2018	4/9/2019	2	Cooler	In hallway adjacent to media center	Low Right	WF-04092018-003898	11/2/2018	FT-FY19-102018-003898-A	< 1	FT-FY19-102018-003898-B	< 1
WS-003899	9/18/2018	9/18/2019	2	Classroom Faucet	In classroom 206		WF-09182018-003899	11/2/2018	FT-FY19-102018-003899-A	< 1	FT-FY19-102018-003899-B	< 1
WS-003900	4/9/2018	4/9/2019	2	Cooler	In hallway adjacent to room 202	High Left	WF-04092018-003900	11/2/2018	FT-FY19-102018-003900-A	< 1	FT-FY19-102018-003900-B	< 1
WS-003901	4/9/2018	4/9/2019	2	Cooler	In hallway adjacent to room 202	Low Right	WF-04092018-003901	11/2/2018	FT-FY19-102018-003901-A	< 1	FT-FY19-102018-003901-B	< 1
WS-003902	4/9/2018	4/9/2019	3	Cooler	In hallway adjacent to room 302	High Left	WF-04092018-003902	11/2/2018	FT-FY19-102018-003902-A	< 1	FT-FY19-102018-003902-B	< 1
WS-003903	4/9/2018	4/9/2019	3	Cooler	In hallway adjacent to room 302	Low Right	WF-04092018-003903	11/2/2018	FT-FY19-102018-003903-A	< 1	FT-FY19-102018-003903-B	< 1
WS-003908	4/9/2018	4/9/2019	3	Cooler	In hallway adjacent to room 313	High Left	WF-04092018-003908	11/2/2018	FT-FY19-102018-003908-A	< 1	FT-FY19-102018-003908-B	< 1
WS-003909	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 107, in bathroom		WF-09182018-003909	11/2/2018	FT-FY19-102018-003909-A	< 1	FT-FY19-102018-003909-B	< 1
WS-003912	4/9/2018	4/9/2019	3	Cooler	In hallway adjacent to room 313	Low Right	WF-04092018-003912	11/2/2018	FT-FY19-102018-003912-A	< 1	FT-FY19-102018-003912-B	< 1
WS-003913	4/9/2018	4/9/2019	3	Break Room	In break room 316		WF-04092018-003913	11/2/2018	FT-FY19-102018-003913-A	< 1	FT-FY19-102018-003913-B	< 1
WS-003914	4/9/2018	4/9/2019	3	Cooler	In hallway adjacent to room 316	High Left	WF-04092018-003914	11/2/2018	FT-FY19-102018-003914-A	< 1	FT-FY19-102018-003914-B	< 1
WS-003915	4/9/2018	4/9/2019	3	Cooler	In hallway adjacent to room 316	Low Right	WF-04092018-003915	11/2/2018	FT-FY19-102018-003915-A	< 1	FT-FY19-102018-003915-B	< 1
WS-003924	4/9/2018	4/9/2019	3	Cooler	In hallway adjacent to stairwell A	High Left	WF-04092018-003924	11/2/2018	FT-FY19-102018-003924-A	< 1	FT-FY19-102018-003924-B	< 1
WS-003925	4/9/2018	4/9/2019	3	Cooler	In hallway adjacent to stairwell A	Low Right	WF-04092018-003925	11/2/2018	FT-FY19-102018-003925-A	< 1	FT-FY19-102018-003925-B	< 1
WS-003926	4/9/2018	4/9/2019	Basement	Combo Fountain	In art room B06 first clockwise from entry door		WF-04092018-003926	11/2/2018	FT-FY19-102018-003926-A	< 1	FT-FY19-102018-003926-B	< 1
WS-004533	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 108, in bathroom		WF-09182018-004533	11/2/2018	FT-FY19-102018-004533-A	< 1	FT-FY19-102018-004533-B	< 1
WS-004534	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 109, in bathroom		WF-09182018-004534	11/2/2018	FT-FY19-102018-004534-A	< 1	FT-FY19-102018-004534-B	< 1
WS-004535	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 113, in bathroom		WF-09182018-004535	11/2/2018	FT-FY19-102018-004535-A	< 1	FT-FY19-102018-004535-B	< 1
WS-004536	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 112, in bathroom		WF-09182018-004536	11/2/2018	FT-FY19-102018-004536-A	< 1	FT-FY19-102018-004536-B	< 1
WS-004537	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 116, in bathroom		WF-09182018-004537	11/2/2018	FT-FY19-102018-004537-A	< 1	FT-FY19-102018-004537-B	< 1
WS-004538	9/18/2018	9/18/2019	1	Classroom Faucet	In classroom 117, in bathroom		WF-09182018-004538	11/2/2018	FT-FY19-102018-004538-A	< 1	FT-FY19-102018-004538-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation								
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003878	1	Food Prep Sink	In servery room in kitchen on south wall	11/2/2018	FT-FY19-102018-003878-A	< 1	FT-FY19-102018-003878-B	< 1