



# Tyler ES Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009998	3/19/2019	3/19/2020	Basement	Cooler	In lunch room High Left	WF-03192019-009998	12/16/2019	FT-FY20-112019-009998-A	<1	FT-FY20-112019-009998-B	<1
WS- 010001	3/19/2019	3/19/2020	1	Cooler	In hallway adjacent to room 120 High Left	WF-03192019-010001	12/16/2019	FT-FY20-112019-010001-A	<1	FT-FY20-112019-010001-B	<1
WS- 010002	3/19/2019	3/19/2020	1	Cooler	In hallway adjacent to room 120 Low Right	WF-03192019-010002	12/16/2019	FT-FY20-112019-010002-A	<1	FT-FY20-112019-010002-B	<1
WS- 010003	3/19/2019	3/19/2020	1	Break Room	In staff lounge 118	WF-03192019-010003	12/16/2019	FT-FY20-112019-010003-A	<1	FT-FY20-112019-010003-B	<1
WS- 010008	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 110	WF-10012019-010008	12/16/2019	FT-FY20-112019-010008-A	<1	FT-FY20-112019-010008-B	<1
WS- 010009	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 109	WF-10012019-010009	12/16/2019	FT-FY20-112019-010009-A	<1	FT-FY20-112019-010009-B	<1
WS- 010010	3/19/2019	3/19/2020	1	Health Suite	In health suite 107	WF-03192019-010010	12/16/2019	FT-FY20-112019-010010-A	<1	FT-FY20-112019-010010-B	<1
WS- 010011	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 124	WF-10012019-010011	12/16/2019	FT-FY20-112019-010011-A	<1	FT-FY20-112019-010011-B	<1
WS- 010012	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 125	WF-10012019-010012	12/16/2019	FT-FY20-112019-010012-A	<1	FT-FY20-112019-010012-B	<1
WS- 010013	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 127	WF-10012019-010013	12/16/2019	FT-FY20-112019-010013-A	<1	FT-FY20-112019-010013-B	<1
WS- 010014	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 145	WF-10012019-010014	12/16/2019	FT-FY20-112019-010014-A	<1	FT-FY20-112019-010014-B	<1
WS- 010015	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 129	WF-10012019-010015	12/16/2019	FT-FY20-112019-010015-A	<1	FT-FY20-112019-010015-B	<1
WS- 010016	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 144	WF-10012019-010016	12/16/2019	FT-FY20-112019-010016-A	<1	FT-FY20-112019-010016-B	<1
WS- 010017	3/19/2019	3/19/2020	1	Cooler	In hallway adjacent to room 144 Low Right	WF-03192019-010017	12/16/2019	FT-FY20-112019-010017-A	<1	FT-FY20-112019-010017-B	<1
WS- 010018	3/19/2019	3/19/2020	1	Cooler	In hallway adjacent to room 144 High Left	WF-03192019-010018	12/16/2019	FT-FY20-112019-010018-A	<1	FT-FY20-112019-010018-B	<1
WS- 010019	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 142	WF-10012019-010019	12/16/2019	FT-FY20-112019-010019-A	<1	FT-FY20-112019-010019-B	<1
WS- 010020	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 131	WF-10012019-010020	12/16/2019	FT-FY20-112019-010020-A	<1	FT-FY20-112019-010020-B	<1
WS- 010021	3/19/2019	3/19/2020	1	Cooler	In hallway adjacent to room 138 Low Right	WF-03192019-010021	12/16/2019	FT-FY20-112019-010021-A	<1	FT-FY20-112019-010021-B	<1
WS- 010022	3/19/2019	3/19/2020	1	Cooler	In hallway adjacent to room 138 High Left	WF-03192019-010022	12/16/2019	FT-FY20-112019-010022-A	<1	FT-FY20-112019-010022-B	<1
WS- 010024	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 132	WF-10012019-010024	12/16/2019	FT-FY20-112019-010024-A	<1	FT-FY20-112019-010024-B	<1
WS- 010025	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 135	WF-10012019-010025	12/16/2019	FT-FY20-112019-010025-A	<1	FT-FY20-112019-010025-B	<1
WS- 010026	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 134	WF-10012019-010026	12/16/2019	FT-FY20-112019-010026-A	<1	FT-FY20-112019-010026-B	<1
WS- 010031	3/19/2019	3/19/2020	2	Cooler	In hallway adjacent to room 211 High Left	WF-03192019-010031	12/16/2019	FT-FY20-112019-010031-A	<1	FT-FY20-112019-010031-B	<1
WS- 010032	3/19/2019	3/19/2020	2	Cooler	In hallway across from boys' restroom Low Left	WF-03192019-010032	12/16/2019	FT-FY20-112019-010032-A	<1	FT-FY20-112019-010032-B	<1
WS- 010044	3/19/2019	3/19/2020	3	Cooler	In hallway adjacent to room 304	WF-03192019-010044	12/16/2019	FT-FY20-112019-010044-A	<1	FT-FY20-112019-010044-B	<1
WS- 010077	3/19/2019	3/19/2020	3	Cooler	In hallway adjacent to room 306 High Left	WF-03192019-010077	12/16/2019	FT-FY20-112019-010077-A	<1	FT-FY20-112019-010077-B	<1
WS- 010078	10/1/2019	10/1/2020	1	Classroom Faucet	In classroom 137	WF-10012019-010078	12/16/2019	FT-FY20-112019-010078-A	<1	FT-FY20-112019-010078-B	<1
WS- 010088	3/19/2019	3/19/2020	Basement	Cooler	In lunch room Low Right	WF-03192019-010088	12/16/2019	FT-FY20-112019-010088-A	<1	FT-FY20-112019-010088-B	<1
WS- 010089	3/19/2019	3/19/2020	Basement	Bottle Filler	In lunch room	WF-03192019-010089	12/16/2019	FT-FY20-112019-010089-A	<1	FT-FY20-112019-010089-B	<1
WS- 010091	3/19/2019	3/19/2020	2	Cooler	In hallway adjacent to room 211 Low Right	WF-03192019-010091	12/16/2019	FT-FY20-112019-010091-A	<1	FT-FY20-112019-010091-B	<1
WS- 010092	3/19/2019	3/19/2020	2	Cooler	In hallway across from boys' restroom High Right	WF-03192019-010092	12/16/2019	FT-FY20-112019-010092-A	<1	FT-FY20-112019-010092-B	<1

WS- 010094	3/19/2019	3/19/2020	3	Cooler	In hallway adjacent to room 306	Low	Right	WF-03192019-010094	12/16/2019	FT-FY20-112019-010094-A	<1	FT-FY20-112019-010094-B	<1
WS- 010095	3/19/2019	3/19/2020	3	Bottle Filler	In hallway adjacent to room 306			WF-03192019-010095	12/16/2019	FT-FY20-112019-010095-A	<1	FT-FY20-112019-010095-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009999	7/15/2019	7/15/2020	Basement	Food Prep Sink	In kitchen	Right	WF-07152019-009999	12/16/2019	FT-FY20-112019-009999-A	<1	FT-FY20-112019-009999-B	<1
WS- 010000	7/15/2019	7/15/2020	Basement	Food Prep Sink	In kitchen	Left	WF-07152019-010000	12/16/2019	FT-FY20-112019-010000-A	<1	FT-FY20-112019-010000-B	<1