



# Tyler Elementary School Lead in Water Test Results

## FY23 Filter Test

| Less than 5ppb - Devices requiring no remediation |                       |                        |       |                  |                                       |            |                     |               |                           |                                  |                           |                                  |
|---|-----------------------|------------------------|-------|------------------|---------------------------------------|------------|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|
| Record ID   | Filter Installed Date | Filter Expiration Date | Floor | Device Type      | Device Location                       |            | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID      | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID      | FT Final Result - 2nd Draw (ppb) |
| WS- 010001  | 2/21/2022             | 2/21/2023              | 1     | Cooler           | In hallway adjacent to room 120       | High Left  | WF-02212022-010001  | 12/1/2022     | FT-FY23-11042022-010001-A | <1                               | FT-FY23-11042022-010001-B | <1                               |
| WS- 010002  | 2/21/2022             | 2/21/2023              | 1     | Cooler           | In hallway adjacent to room 120       | Low Right  | WF-02212022-010002  | 12/1/2022     | FT-FY23-11042022-010002-A | <1                               | FT-FY23-11042022-010002-B | <1                               |
| WS- 010003  | 2/21/2022             | 2/21/2023              | 1     | Break Room       | In staff lounge 118                   |            | WF-02212022-010003  | 12/1/2022     | FT-FY23-11042022-010003-A | <1                               | FT-FY23-11042022-010003-B | <1                               |
| WS- 010006  | 2/21/2022             | 2/21/2023              | 1     | Cooler           | In hallway adjacent to main office    | High Left  | WF-02212022-010006  | 12/1/2022     | FT-FY23-11042022-010006-A | <1                               | FT-FY23-11042022-010006-B | <1                               |
| WS- 010008  | 9/8/2022              | 9/8/2023               | 1     | Classroom Faucet | In classroom 110                      |            | WF-09082022-010008  | 12/1/2022     | FT-FY23-11042022-010008-A | <1                               | FT-FY23-11042022-010008-B | <1                               |
| WS- 010009  | 9/8/2022              | 9/8/2023               | 1     | Classroom Faucet | In classroom 109                      |            | WF-09082022-010009  | 12/1/2022     | FT-FY23-11042022-010009-A | <1                               | FT-FY23-11042022-010009-B | <1                               |
| WS- 010010  | 2/21/2022             | 2/21/2023              | 1     | Health Suite     | In health suite 107                   |            | WF-02212022-010010  | 12/1/2022     | FT-FY23-11042022-010010-A | <1                               | FT-FY23-11042022-010010-B | <1                               |
| WS- 010011  | 9/8/2022              | 9/8/2023               | 1     | Classroom Faucet | In classroom 124                      |            | WF-09082022-010011  | 12/1/2022     | FT-FY23-11042022-010011-A | <1                               | FT-FY23-11042022-010011-B | <1                               |
| WS- 010012  | 9/8/2022              | 9/8/2023               | 1     | Classroom Faucet | In classroom 125                      |            | WF-09082022-010012  | 12/1/2022     | FT-FY23-11042022-010012-A | 1.3                              | FT-FY23-11042022-010012-B | <1                               |
| WS- 010013  | 9/8/2022              | 9/8/2023               | 1     | Classroom Faucet | In classroom 127                      |            | WF-09082022-010013  | 12/1/2022     | FT-FY23-11042022-010013-A | <1                               | FT-FY23-11042022-010013-B | <1                               |
| WS- 010014  | 9/8/2022              | 9/8/2023               | 1     | Classroom Faucet | In classroom 145                      |            | WF-09082022-010014  | 12/1/2022     | FT-FY23-11042022-010014-A | <1                               | FT-FY23-11042022-010014-B | <1                               |
| WS- 010015  | 9/8/2022              | 9/8/2023               | 1     | Classroom Faucet | In classroom 129                      |            | WF-09082022-010015  | 12/1/2022     | FT-FY23-11042022-010015-A | <1                               | FT-FY23-11042022-010015-B | <1                               |
| WS- 010016  | 9/8/2022              | 9/8/2023               | 1     | Classroom Faucet | In classroom 144                      |            | WF-09082022-010016  | 12/1/2022     | FT-FY23-11042022-010016-A | <1                               | FT-FY23-11042022-010016-B | <1                               |
| WS- 010017  | 2/21/2022             | 2/21/2023              | 1     | Cooler           | In hallway adjacent to room 144       | Low Right  | WF-02212022-010017  | 12/1/2022     | FT-FY23-11042022-010017-A | <1                               | FT-FY23-11042022-010017-B | <1                               |
| WS- 010018  | 2/21/2022             | 2/21/2023              | 1     | Cooler           | In hallway adjacent to room 144       | High Left  | WF-02212022-010018  | 12/1/2022     | FT-FY23-11042022-010018-A | <1                               | FT-FY23-11042022-010018-B | <1                               |
| WS- 010019  | 9/8/2022              | 9/8/2023               | 1     | Classroom Faucet | In classroom 142                      |            | WF-09082022-010019  | 12/1/2022     | FT-FY23-11042022-010019-A | <1                               | FT-FY23-11042022-010019-B | <1                               |
| WS- 010020  | 9/8/2022              | 9/8/2023               | 1     | Classroom Faucet | In classroom 131                      |            | WF-09082022-010020  | 12/1/2022     | FT-FY23-11042022-010020-A | <1                               | FT-FY23-11042022-010020-B | <1                               |
| WS- 010021  | 2/21/2022             | 2/21/2023              | 1     | Cooler           | In hallway adjacent to room 138       | Low Right  | WF-02212022-010021  | 12/1/2022     | FT-FY23-11042022-010021-A | <1                               | FT-FY23-11042022-010021-B | <1                               |
| WS- 010022  | 2/21/2022             | 2/21/2023              | 1     | Cooler           | In hallway adjacent to room 138       | High Left  | WF-02212022-010022  | 12/1/2022     | FT-FY23-11042022-010022-A | <1                               | FT-FY23-11042022-010022-B | <1                               |
| WS- 010024  | 9/8/2022              | 9/8/2023               | 1     | Classroom Faucet | In classroom 132                      |            | WF-09082022-010024  | 12/1/2022     | FT-FY23-11042022-010024-A | <1                               | FT-FY23-11042022-010024-B | <1                               |
| WS- 010025  | 9/8/2022              | 9/8/2023               | 1     | Classroom Faucet | In classroom 135                      |            | WF-09082022-010025  | 12/1/2022     | FT-FY23-11042022-010025-A | <1                               | FT-FY23-11042022-010025-B | <1                               |
| WS- 010026  | 9/8/2022              | 9/8/2023               | 1     | Classroom Faucet | In classroom 134                      |            | WF-09082022-010026  | 12/1/2022     | FT-FY23-11042022-010026-A | <1                               | FT-FY23-11042022-010026-B | <1                               |
| WS- 010031  | 2/21/2022             | 2/21/2023              | 2     | Cooler           | In hallway adjacent to room 211       | High Left  | WF-02212022-010031  | 12/1/2022     | FT-FY23-11042022-010031-A | <1                               | FT-FY23-11042022-010031-B | <1                               |
| WS- 010032  | 2/21/2022             | 2/21/2023              | 2     | Cooler           | In hallway across from boys' restroom | Low Left   | WF-02212022-010032  | 12/1/2022     | FT-FY23-11042022-010032-A | <1                               | FT-FY23-11042022-010032-B | <1                               |
| WS- 010044  | 2/21/2022             | 2/21/2023              | 3     | Cooler           | In hallway adjacent to room 304       |            | WF-02212022-010044  | 12/1/2022     | FT-FY23-11042022-010044-A | <1                               | FT-FY23-11042022-010044-B | <1                               |
| WS- 010077  | 2/21/2022             | 2/21/2023              | 3     | Cooler           | In hallway adjacent to room 306       | High Left  | WF-02212022-010077  | 12/1/2022     | FT-FY23-11042022-010077-A | <1                               | FT-FY23-11042022-010077-B | <1                               |
| WS- 010078  | 9/8/2022              | 9/8/2023               | 1     | Classroom Faucet | In classroom 137                      |            | WF-09082022-010078  | 12/1/2022     | FT-FY23-11042022-010078-A | <1                               | FT-FY23-11042022-010078-B | <1                               |
| WS- 010091  | 2/21/2022             | 2/21/2023              | 2     | Cooler           | In hallway adjacent to room 211       | Low Right  | WF-02212022-010091  | 12/1/2022     | FT-FY23-11042022-010091-A | <1                               | FT-FY23-11042022-010091-B | <1                               |
| WS- 010092  | 2/21/2022             | 2/21/2023              | 2     | Cooler           | In hallway across from boys' restroom | High Right | WF-02212022-010092  | 12/1/2022     | FT-FY23-11042022-010092-A | <1                               | FT-FY23-11042022-010092-B | <1                               |
| WS- 010093  | 2/21/2022             | 2/21/2023              | 2     | Bottle Filler    | In hallway across from boys' restroom |            | WF-02212022-010093  | 12/1/2022     | FT-FY23-11042022-010093-A | 1.2                              | FT-FY23-11042022-010093-B | <1                               |
| WS- 010094  | 2/21/2022             | 2/21/2023              | 3     | Cooler           | In hallway adjacent to room 306       | Low Right  | WF-02212022-010094  | 12/1/2022     | FT-FY23-11042022-010094-A | <1                               | FT-FY23-11042022-010094-B | <1                               |

## Food Prep Sink

| Less than 5ppb - Devices requiring no remediation |                       |                        |          |                |                 |       |                     |               |                           |                                  |                           |                                  |
|---|-----------------------|------------------------|----------|----------------|-----------------|-------|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|
| Record ID   | Filter Installed Date | Filter Expiration Date | Floor    | Device Type    | Device Location |       | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID      | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID      | FT Final Result - 2nd Draw (ppb) |
| WS- 009999  | 2/9/2022              | 2/9/2023               | Basement | Food Prep Sink | In kitchen      | Right | WF-02092022-009999  | 12/1/2022     | FT-FY23-11042022-009999-A | <1                               | FT-FY23-11042022-009999-B | <1                               |
| WS- 010000  | 2/9/2022              | 2/9/2023               | Basement | Food Prep Sink | In kitchen      | Left  | WF-02092022-010000  | 12/1/2022     | FT-FY23-11042022-010000-A | <1                               | FT-FY23-11042022-010000-B | <1                               |