



Tyler Elementary School Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009998	3/10/2020	3/10/2021	Basement	Cooler	In lunch room High Left	WF-03102020-009998	1/7/2021	FT-FY21-012021-009998-A	<1	FT-FY21-012021-009998-B	<1
WS-010001	3/10/2020	3/10/2021	1	Cooler	In hallway adjacent to room 120 High Left	WF-03102020-010001	1/7/2021	FT-FY21-012021-010001-A	<1	FT-FY21-012021-010001-B	<1
WS-010002	3/10/2020	3/10/2021	1	Cooler	In hallway adjacent to room 120 Low Right	WF-03102020-010002	1/7/2021	FT-FY21-012021-010002-A	<1	FT-FY21-012021-010002-B	<1
WS-010003	3/10/2020	3/10/2021	1	Break Room	In staff lounge 118	WF-03102020-010003	1/7/2021	FT-FY21-012021-010003-A	<1	FT-FY21-012021-010003-B	<1
WS-010006	3/10/2020	3/10/2021	1	Cooler	In hallway adjacent to main office High Left	WF-03102020-010006	1/7/2021	FT-FY21-012021-010006-A	<1	FT-FY21-012021-010006-B	<1
WS-010007	3/10/2020	3/10/2021	1	Cooler	In hallway adjacent to main office Low Right	WF-03102020-010007	1/7/2021	FT-FY21-012021-010007-A	<1	FT-FY21-012021-010007-B	<1
WS-010008	9/24/2020	9/24/2021	1	Classroom Faucet	In classroom 110	WF-09242020-010008	1/7/2021	FT-FY21-012021-010008-A	<1	FT-FY21-012021-010008-B	<1
WS-010009	9/24/2020	9/24/2021	1	Classroom Faucet	In classroom 109	WF-09242020-010009	1/7/2021	FT-FY21-012021-010009-A	<1	FT-FY21-012021-010009-B	<1
WS-010010	3/10/2020	3/10/2021	1	Health Suite	In health suite 107	WF-03102020-010010	1/7/2021	FT-FY21-012021-010010-A	<1	FT-FY21-012021-010010-B	<1
WS-010011	9/24/2020	9/24/2021	1	Classroom Faucet	In classroom 124	WF-09242020-010011	1/7/2021	FT-FY21-012021-010011-A	<1	FT-FY21-012021-010011-B	<1
WS-010012	9/24/2020	9/24/2021	1	Classroom Faucet	In classroom 125	WF-09242020-010012	1/7/2021	FT-FY21-012021-010012-A	<1	FT-FY21-012021-010012-B	<1
WS-010013	9/24/2020	9/24/2021	1	Classroom Faucet	In classroom 127	WF-09242020-010013	1/7/2021	FT-FY21-012021-010013-A	<1	FT-FY21-012021-010013-B	<1
WS-010014	9/24/2020	9/24/2021	1	Classroom Faucet	In classroom 145	WF-09242020-010014	1/7/2021	FT-FY21-012021-010014-A	<1	FT-FY21-012021-010014-B	<1
WS-010015	9/24/2020	9/24/2021	1	Classroom Faucet	In classroom 129	WF-09242020-010015	1/7/2021	FT-FY21-012021-010015-A	<1	FT-FY21-012021-010015-B	<1
WS-010016	9/24/2020	9/24/2021	1	Classroom Faucet	In classroom 144	WF-09242020-010016	1/7/2021	FT-FY21-012021-010016-A	<1	FT-FY21-012021-010016-B	<1
WS-010019	9/24/2020	9/24/2021	1	Classroom Faucet	In classroom 142	WF-09242020-010019	1/7/2021	FT-FY21-012021-010019-A	<1	FT-FY21-012021-010019-B	<1
WS-010020	9/24/2020	9/24/2021	1	Classroom Faucet	In classroom 131	WF-09242020-010020	1/7/2021	FT-FY21-012021-010020-A	<1	FT-FY21-012021-010020-B	<1
WS-010021	3/10/2020	3/10/2021	1	Cooler	In hallway adjacent to room 138 Low Right	WF-03102020-010021	1/7/2021	FT-FY21-012021-010021-A	<1	FT-FY21-012021-010021-B	<1
WS-010022	3/10/2020	3/10/2021	1	Cooler	In hallway adjacent to room 138 High Left	WF-03102020-010022	1/7/2021	FT-FY21-012021-010022-A	<1	FT-FY21-012021-010022-B	<1
WS-010024	9/24/2020	9/24/2021	1	Classroom Faucet	In classroom 132	WF-09242020-010024	1/7/2021	FT-FY21-012021-010024-A	<1	FT-FY21-012021-010024-B	<1
WS-010025	9/24/2020	9/24/2021	1	Classroom Faucet	In classroom 135	WF-09242020-010025	1/7/2021	FT-FY21-012021-010025-A	<1	FT-FY21-012021-010025-B	<1
WS-010026	9/24/2020	9/24/2021	1	Classroom Faucet	In classroom 134	WF-09242020-010026	1/7/2021	FT-FY21-012021-010026-A	<1	FT-FY21-012021-010026-B	<1
WS-010031	3/10/2020	3/10/2021	2	Cooler	In hallway adjacent to room 211 High Left	WF-03102020-010031	1/7/2021	FT-FY21-012021-010031-A	<1	FT-FY21-012021-010031-B	<1
WS-010032	3/10/2020	3/10/2021	2	Cooler	In hallway across from boys' restroom Low Left	WF-03102020-010032	1/7/2021	FT-FY21-012021-010032-A	<1	FT-FY21-012021-010032-B	<1
WS-010044	3/10/2020	3/10/2021	3	Cooler	In hallway adjacent to room 304	WF-03102020-010044	1/7/2021	FT-FY21-012021-010044-A	<1	FT-FY21-012021-010044-B	<1
WS-010077	3/10/2020	3/10/2021	3	Cooler	In hallway adjacent to room 306 High Left	WF-03102020-010077	1/7/2021	FT-FY21-012021-010077-A	<1	FT-FY21-012021-010077-B	<1
WS-010078	9/24/2020	9/24/2021	1	Classroom Faucet	In classroom 137	WF-09242020-010078	1/7/2021	FT-FY21-012021-010078-A	<1	FT-FY21-012021-010078-B	<1
WS-010088	3/10/2020	3/10/2021	Basement	Cooler	In lunch room Low Right	WF-03102020-010088	1/7/2021	FT-FY21-012021-010088-A	<1	FT-FY21-012021-010088-B	<1
WS-010089	3/10/2020	3/10/2021	Basement	Bottle Filler	In lunch room	WF-03102020-010089	1/7/2021	FT-FY21-012021-010089-A	<1	FT-FY21-012021-010089-B	<1
WS-010090	3/10/2020	3/10/2021	1	Bottle Filler	In hallway adjacent to main office	WF-03102020-010090	1/7/2021	FT-FY21-012021-010090-A	<1	FT-FY21-012021-010090-B	<1
WS-010091	3/10/2020	3/10/2021	2	Cooler	In hallway adjacent to room 211 Low Right	WF-03102020-010091	1/7/2021	FT-FY21-012021-010091-A	<1	FT-FY21-012021-010091-B	<1
WS-010092	3/10/2020	3/10/2021	2	Cooler	In hallway across from boys' restroom High Right	WF-03102020-010092	1/7/2021	FT-FY21-012021-010092-A	<1	FT-FY21-012021-010092-B	<1

WS- 010094	3/10/2020	3/10/2021	3	Cooler	In hallway adjacent to room 306	Low Right	WF-03102020-010094	1/7/2021	FT-FY21-012021-010094-A	<1	FT-FY21-012021-010094-B	<1
WS- 010095	3/10/2020	3/10/2021	3	Bottle Filler	In hallway adjacent to room 306		WF-03102020-010095	1/7/2021	FT-FY21-012021-010095-A	<1	FT-FY21-012021-010095-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009999	2/19/2020	2/19/2021	Basement	Food Prep Sink	In kitchen	Right	WF-02192020-009999	1/7/2021	FT-FY21-012021-009999-A	<1	FT-FY21-012021-009999-B	<1
WS- 010000	2/19/2020	2/19/2021	Basement	Food Prep Sink	In kitchen	Left	WF-02192020-010000	1/7/2021	FT-FY21-012021-010000-A	<1	FT-FY21-012021-010000-B	<1