



Tyler Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-010001	3/4/2021	3/4/2022	1	Cooler	In hallway adjacent to room 120	High Left	WF-03042021-010001	1/11/2022	FT-FY22-12292021-010001-A	<1	FT-FY22-12292021-010001-B	<1
WS-010002	3/4/2021	3/4/2022	1	Cooler	In hallway adjacent to room 120	Low Right	WF-03042021-010002	1/11/2022	FT-FY22-12292021-010002-A	<1	FT-FY22-12292021-010002-B	<1
WS-010003	3/4/2021	3/4/2022	1	Break Room	In staff lounge 118		WF-03042021-010003	1/11/2022	FT-FY22-12292021-010003-A	<1	FT-FY22-12292021-010003-B	<1
WS-010006	12/13/2021	12/13/2022	1	Cooler	In hallway adjacent to main office	High Left	WF-12132021-010006	1/11/2022	FT-FY22-12292021-010006-A	<1	FT-FY22-12292021-010006-B	<1
WS-010007	12/13/2021	12/13/2022	1	Cooler	In hallway adjacent to main office	Low Right	WF-12132021-010007	1/11/2022	FT-FY22-12292021-010007-A	<1	FT-FY22-12292021-010007-B	<1
WS-010008	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 110		WF-09142021-010008	1/11/2022	FT-FY22-12292021-010008-A	<1	FT-FY22-12292021-010008-B	<1
WS-010009	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 109		WF-09142021-010009	1/11/2022	FT-FY22-12292021-010009-A	<1	FT-FY22-12292021-010009-B	<1
WS-010010	3/4/2021	3/4/2022	1	Health Suite	In health suite 107		WF-03042021-010010	1/11/2022	FT-FY22-12292021-010010-A	<1	FT-FY22-12292021-010010-B	<1
WS-010011	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 124		WF-09142021-010011	1/11/2022	FT-FY22-12292021-010011-A	<1	FT-FY22-12292021-010011-B	<1
WS-010012	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 125		WF-09142021-010012	1/11/2022	FT-FY22-12292021-010012-A	<1	FT-FY22-12292021-010012-B	<1
WS-010013	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 127		WF-09142021-010013	1/11/2022	FT-FY22-12292021-010013-A	<1	FT-FY22-12292021-010013-B	<1
WS-010014	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 145		WF-09142021-010014	1/11/2022	FT-FY22-12292021-010014-A	<1	FT-FY22-12292021-010014-B	<1
WS-010015	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 129		WF-09142021-010015	1/11/2022	FT-FY22-12292021-010015-A	<1	FT-FY22-12292021-010015-B	<1
WS-010016	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 144		WF-09142021-010016	1/11/2022	FT-FY22-12292021-010016-A	<1	FT-FY22-12292021-010016-B	<1
WS-010017	3/4/2021	3/4/2022	1	Cooler	In hallway adjacent to room 144	Low Right	WF-03042021-010017	1/11/2022	FT-FY22-12292021-010017-A	<1	FT-FY22-12292021-010017-B	<1
WS-010018	3/4/2021	3/4/2022	1	Cooler	In hallway adjacent to room 144	High Left	WF-03042021-010018	1/11/2022	FT-FY22-12292021-010018-A	<1	FT-FY22-12292021-010018-B	<1
WS-010019	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 142		WF-09142021-010019	1/11/2022	FT-FY22-12292021-010019-A	<1	FT-FY22-12292021-010019-B	<1
WS-010020	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 131		WF-09142021-010020	1/11/2022	FT-FY22-12292021-010020-A	<1	FT-FY22-12292021-010020-B	<1
WS-010021	3/4/2021	3/4/2022	1	Cooler	In hallway adjacent to room 138	Low Right	WF-03042021-010021	1/11/2022	FT-FY22-12292021-010021-A	<1	FT-FY22-12292021-010021-B	<1
WS-010022	3/4/2021	3/4/2022	1	Cooler	In hallway adjacent to room 138	High Left	WF-03042021-010022	1/11/2022	FT-FY22-12292021-010022-A	<1	FT-FY22-12292021-010022-B	<1
WS-010024	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 132		WF-09142021-010024	1/11/2022	FT-FY22-12292021-010024-A	<1	FT-FY22-12292021-010024-B	<1
WS-010025	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 135		WF-09142021-010025	1/11/2022	FT-FY22-12292021-010025-A	2.9	FT-FY22-12292021-010025-B	<1
WS-010026	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 134		WF-09142021-010026	1/11/2022	FT-FY22-12292021-010026-A	<1	FT-FY22-12292021-010026-B	<1
WS-010031	3/4/2021	3/4/2022	2	Cooler	In hallway adjacent to room 211	High Left	WF-03042021-010031	1/11/2022	FT-FY22-12292021-010031-A	<1	FT-FY22-12292021-010031-B	<1
WS-010032	3/4/2021	3/4/2022	2	Cooler	In hallway across from boys' restroom	Low Left	WF-03042021-010032	1/11/2022	FT-FY22-12292021-010032-A	<1	FT-FY22-12292021-010032-B	<1
WS-010044	3/4/2021	3/4/2022	3	Cooler	In hallway adjacent to room 304		WF-03042021-010044	1/11/2022	FT-FY22-12292021-010044-A	<1	FT-FY22-12292021-010044-B	<1
WS-010077	3/4/2021	3/4/2022	3	Cooler	In hallway adjacent to room 306	High Left	WF-03042021-010077	1/11/2022	FT-FY22-12292021-010077-A	<1	FT-FY22-12292021-010077-B	<1
WS-010078	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 137		WF-09142021-010078	1/11/2022	FT-FY22-12292021-010078-A	<1	FT-FY22-12292021-010078-B	<1
WS-010090	12/13/2021	12/13/2022	1	Bottle Filler	In hallway adjacent to main office		WF-12132021-010090	1/11/2022	FT-FY22-12292021-010090-A	<1	FT-FY22-12292021-010090-B	<1
WS-010091	3/4/2021	3/4/2022	2	Cooler	In hallway adjacent to room 211	Low Right	WF-03042021-010091	1/11/2022	FT-FY22-12292021-010091-A	<1	FT-FY22-12292021-010091-B	<1
WS-010092	3/4/2021	3/4/2022	2	Cooler	In hallway across from boys' restroom	High Right	WF-03042021-010092	1/11/2022	FT-FY22-12292021-010092-A	<1	FT-FY22-12292021-010092-B	<1
WS-010093	3/4/2021	3/4/2022	2	Bottle Filler	In hallway across from boys' restroom		WF-03042021-010093	1/11/2022	FT-FY22-12292021-010093-A	<1	FT-FY22-12292021-010093-B	<1
WS-010094	3/4/2021	3/4/2022	3	Cooler	In hallway adjacent to room 306	Low Right	WF-03042021-010094	1/11/2022	FT-FY22-12292021-010094-A	<1	FT-FY22-12292021-010094-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009999	2/16/2021	2/16/2022	Basement	Food Prep Sink	In kitchen	Right	WF-02162021-009999	1/11/2022	FT-FY22-12292021-009999-A	<1	FT-FY22-12292021-009999-B	<1
WS- 010000	2/16/2021	2/16/2022	Basement	Food Prep Sink	In kitchen	Left	WF-02162021-010000	1/11/2022	FT-FY22-12292021-010000-A	<1	FT-FY22-12292021-010000-B	<1