



# TYLER ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	TYLER ELEMENTARY SCHOOL	WS- 009998	8/24/2016	Basement	Cooler	In lunch room	FT-72016-009998-A	< 1	FT-72016-009998-B	< 1
2	TYLER ELEMENTARY SCHOOL	WS- 010000	8/24/2016	Basement	Food Prep Sink	In kitchen Left	FT-82016-010000-A	< 1	FT-82016-010000-B	< 1
3	TYLER ELEMENTARY SCHOOL	WS- 010001	8/24/2016	1	Cooler	In hallway adjacent to room 120 High Left	FT-72016-010001-A	< 1	FT-72016-010001-B	< 1
4	TYLER ELEMENTARY SCHOOL	WS- 010002	8/24/2016	1	Cooler	In hallway adjacent to room 120 Low Right	FT-72016-010002-A	< 1	FT-72016-010002-B	< 1
5	TYLER ELEMENTARY SCHOOL	WS- 010006	8/24/2016	1	Cooler	In hallway adjacent to main office High Left	FT-72016-010006-A	< 1	FT-72016-010006-B	< 1
6	TYLER ELEMENTARY SCHOOL	WS- 010007	8/24/2016	1	Cooler	In hallway adjacent to main office Low Right	FT-72016-010007-A	< 1	FT-72016-010007-B	< 1
7	TYLER ELEMENTARY SCHOOL	WS- 010010	8/24/2016	1	Health Suite	In health suite 107	FT-72016-010010-A	< 1	FT-72016-010010-B	< 1
8	TYLER ELEMENTARY SCHOOL	WS- 010017	8/24/2016	1	Cooler	In hallway adjacent to room 144 Low Right	FT-72016-010017-A	< 1	FT-72016-010017-B	< 1
9	TYLER ELEMENTARY SCHOOL	WS- 010018	8/24/2016	1	Cooler	In hallway adjacent to room 144 High Left	FT-72016-010018-A	< 1	FT-72016-010018-B	< 1
10	TYLER ELEMENTARY SCHOOL	WS- 010021	8/24/2016	1	Cooler	In hallway adjacent to room 138 Low Right	FT-72016-010021-A	< 1	FT-72016-010021-B	< 1
11	TYLER ELEMENTARY SCHOOL	WS- 010022	8/24/2016	1	Cooler	In hallway adjacent to room 138 High Left	FT-72016-010022-A	< 1	FT-72016-010022-B	< 1
12	TYLER ELEMENTARY SCHOOL	WS- 010031	8/24/2016	2	Cooler	In hallway adjacent to room 211	FT-72016-010031-A	< 1	FT-72016-010031-B	< 1
13	TYLER ELEMENTARY SCHOOL	WS- 010032	8/24/2016	2	Cooler	In hallway across from boys' restroom	FT-72016-010032-A	< 1	FT-72016-010032-B	< 1
14	TYLER ELEMENTARY SCHOOL	WS- 010044	8/24/2016	3	Cooler	In hallway adjacent to room 304	FT-72016-010044-A	< 1	FT-72016-010044-B	< 1