



# Tyler ES Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009998	11/27/2018	11/27/2019	Basement	Cooler	In lunch room	High Left	WF-11272018-009998	12/5/2018	FT-FY19-112018-009998-A	<1	FT-FY19-112018-009998-B	<1
WS- 010001	11/27/2018	11/27/2019	1	Cooler	In hallway adjacent to room 120	High Left	WF-11272018-010001	12/5/2018	FT-FY19-112018-010001-A	<1	FT-FY19-112018-010001-B	<1
WS- 010002	11/27/2018	11/27/2019	1	Cooler	In hallway adjacent to room 120	Low Right	WF-11272018-010002	12/5/2018	FT-FY19-112018-010002-A	<1	FT-FY19-112018-010002-B	<1
WS- 010003	3/28/2018	3/28/2019	1	Break Room	In staff lounge 118		WF-03282018-010003	12/5/2018	FT-FY19-112018-010003-A	<1	FT-FY19-112018-010003-B	<1
WS- 010006	11/27/2018	11/27/2019	1	Cooler	In hallway adjacent to main office	High Left	WF-11272018-010006	12/5/2018	FT-FY19-112018-010006-A	<1	FT-FY19-112018-010006-B	<1
WS- 010007	11/27/2018	11/27/2019	1	Cooler	In hallway adjacent to main office	Low Right	WF-11272018-010007	12/5/2018	FT-FY19-112018-010007-A	<1	FT-FY19-112018-010007-B	<1
WS- 010008	10/10/2018	10/10/2019	1	Classroom Faucet	In classroom 110		WF-10102018-010008	12/5/2018	FT-FY19-112018-010008-A	<1	FT-FY19-112018-010008-B	<1
WS- 010009	10/10/2018	10/10/2019	1	Classroom Faucet	In classroom 109		WF-10102018-010009	12/5/2018	FT-FY19-112018-010009-A	<1	FT-FY19-112018-010009-B	<1
WS- 010010	3/28/2018	3/28/2019	1	Health Suite	In health suite 107		WF-03282018-010010	12/5/2018	FT-FY19-112018-010010-A	<1	FT-FY19-112018-010010-B	<1
WS- 010011	10/10/2018	10/10/2019	1	Classroom Faucet	In classroom 124		WF-10102018-010011	12/5/2018	FT-FY19-112018-010011-A	<1	FT-FY19-112018-010011-B	<1
WS- 010012	10/10/2018	10/10/2019	1	Classroom Faucet	In classroom 125		WF-10102018-010012	12/5/2018	FT-FY19-112018-010012-A	<1	FT-FY19-112018-010012-B	<1
WS- 010013	10/10/2018	10/10/2019	1	Classroom Faucet	In classroom 127		WF-10102018-010013	12/5/2018	FT-FY19-112018-010013-A	<1	FT-FY19-112018-010013-B	<1
WS- 010014	10/10/2018	10/10/2019	1	Classroom Faucet	In classroom 145		WF-10102018-010014	12/5/2018	FT-FY19-112018-010014-A	<1	FT-FY19-112018-010014-B	<1
WS- 010015	10/10/2018	10/10/2019	1	Classroom Faucet	In classroom 129		WF-10102018-010015	12/5/2018	FT-FY19-112018-010015-A	<1	FT-FY19-112018-010015-B	<1
WS- 010016	10/10/2018	10/10/2019	1	Classroom Faucet	In classroom 144		WF-10102018-010016	12/5/2018	FT-FY19-112018-010016-A	<1	FT-FY19-112018-010016-B	<1
WS- 010017	11/27/2018	11/27/2019	1	Cooler	In hallway adjacent to room 144	Low Right	WF-11272018-010017	12/5/2018	FT-FY19-112018-010017-A	<1	FT-FY19-112018-010017-B	<1
WS- 010018	11/27/2018	11/27/2019	1	Cooler	In hallway adjacent to room 144	High Left	WF-11272018-010018	12/5/2018	FT-FY19-112018-010018-A	<1	FT-FY19-112018-010018-B	<1
WS- 010019	10/10/2018	10/10/2019	1	Classroom Faucet	In classroom 142		WF-10102018-010019	12/5/2018	FT-FY19-112018-010019-A	<1	FT-FY19-112018-010019-B	<1
WS- 010020	10/10/2018	10/10/2019	1	Classroom Faucet	In classroom 131		WF-10102018-010020	12/5/2018	FT-FY19-112018-010020-A	<1	FT-FY19-112018-010020-B	<1
WS- 010021	11/27/2018	11/27/2019	1	Cooler	In hallway adjacent to room 138	Low Right	WF-11272018-010021	12/5/2018	FT-FY19-112018-010021-A	<1	FT-FY19-112018-010021-B	<1
WS- 010022	11/27/2018	11/27/2019	1	Cooler	In hallway adjacent to room 138	High Left	WF-11272018-010022	12/5/2018	FT-FY19-112018-010022-A	<1	FT-FY19-112018-010022-B	<1
WS- 010024	10/10/2018	10/10/2019	1	Classroom Faucet	In classroom 132		WF-10102018-010024	12/5/2018	FT-FY19-112018-010024-A	<1	FT-FY19-112018-010024-B	<1
WS- 010025	10/10/2018	10/10/2019	1	Classroom Faucet	In classroom 135		WF-10102018-010025	12/5/2018	FT-FY19-112018-010025-A	<1	FT-FY19-112018-010025-B	<1
WS- 010026	10/10/2018	10/10/2019	1	Classroom Faucet	In classroom 134		WF-10102018-010026	12/5/2018	FT-FY19-112018-010026-A	<1	FT-FY19-112018-010026-B	<1
WS- 010031	11/27/2018	11/27/2019	2	Cooler	In hallway adjacent to room 211	High Left	WF-11272018-010031	12/5/2018	FT-FY19-112018-010031-A	<1	FT-FY19-112018-010031-B	<1
WS- 010032	11/27/2018	11/27/2019	2	Cooler	In hallway across from boys' restroom	Low Left	WF-11272018-010032	12/5/2018	FT-FY19-112018-010032-A	<1	FT-FY19-112018-010032-B	<1
WS- 010044	11/27/2018	11/27/2019	3	Cooler	In hallway adjacent to room 304		WF-11272018-010044	12/5/2018	FT-FY19-112018-010044-A	<1	FT-FY19-112018-010044-B	<1
WS- 010077	11/27/2018	11/27/2019	3	Cooler	In hallway adjacent to room 306	High Left	WF-11272018-010077	12/5/2018	FT-FY19-112018-010077-A	<1	FT-FY19-112018-010077-B	<1
WS- 010078	10/10/2018	10/10/2019	1	Classroom Faucet	In classroom 137		WF-10102018-010078	12/5/2018	FT-FY19-112018-010078-A	<1	FT-FY19-112018-010078-B	<1
WS- 010088	11/27/2018	11/27/2019	Basement	Cooler	In lunch room	Low Right	WF-11272018-010088	12/5/2018	FT-FY19-112018-010088-A	<1	FT-FY19-112018-010088-B	<1
WS- 010089	11/27/2018	11/27/2019	Basement	Bottle Filler	In lunch room		WF-11272018-010089	12/5/2018	FT-FY19-112018-010089-A	<1	FT-FY19-112018-010089-B	<1
WS- 010090	11/27/2018	11/27/2019	1	Bottle Filler	In hallway adjacent to main office		WF-11272018-010090	12/5/2018	FT-FY19-112018-010090-A	<1	FT-FY19-112018-010090-B	<1
WS- 010091	11/27/2018	11/27/2019	2	Cooler	In hallway adjacent to room 211	Low Right	WF-11272018-010091	12/5/2018	FT-FY19-112018-010091-A	<1	FT-FY19-112018-010091-B	<1

WS- 010092	11/27/2018	11/27/2019	2	Cooler	In hallway across from boys' restroom	High	Right	WF-11272018-010092	12/5/2018	FT-FY19-112018-010092-A	<1	FT-FY19-112018-010092-B	<1
WS- 010093	11/27/2018	11/27/2019	2	Bottle Filler	In hallway across from boys' restroom			WF-11272018-010093	12/5/2018	FT-FY19-112018-010093-A	<1	FT-FY19-112018-010093-B	<1
WS- 010094	11/27/2018	11/27/2019	3	Cooler	In hallway adjacent to room 306	Low	Right	WF-11272018-010094	12/5/2018	FT-FY19-112018-010094-A	<1	FT-FY19-112018-010094-B	<1
WS- 010095	11/27/2018	11/27/2019	3	Bottle Filler	In hallway adjacent to room 306			WF-11272018-010095	12/5/2018	FT-FY19-112018-010095-A	<1	FT-FY19-112018-010095-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 010000	Basement	Food Prep Sink	In kitchen			Left	12/5/2018	FT-FY19-112018-010000-A	<1	FT-FY19-112018-010000-B	<1	