



UDC Van Ness Swing Space Lead Water Test Results



FY20 Filter Test

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | |
|---|-----------------------|------------------------|--------------|------------------|--|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS-003200 | 8/1/2019 | 8/1/2020 | Ground Floor | Health Suite | In health suite in A wing | WF-08012019-003200 | 8/13/2019 | FT-FY20-082019-003200-A | <1 | FT-FY20-082019-003200-B | <1 |
| WS-003201 | 8/1/2019 | 8/1/2020 | Ground Floor | Cooler | In lobby adjacent to D wing restrooms High Left | WF-08012019-003201 | 8/13/2019 | FT-FY20-082019-003201-A | <1 | FT-FY20-082019-003201-B | <1 |
| WS-003202 | 8/1/2019 | 8/1/2020 | Ground Floor | Cooler | In lobby adjacent to D wing restrooms Low Left | WF-08012019-003202 | 8/13/2019 | FT-FY20-082019-003202-A | <1 | FT-FY20-082019-003202-B | <1 |
| WS-003203 | 8/1/2019 | 8/1/2020 | Ground Floor | Cooler | In lobby adjacent to D wing restrooms High Right | WF-08012019-003203 | 8/13/2019 | FT-FY20-082019-003203-A | <1 | FT-FY20-082019-003203-B | <1 |
| WS-003204 | 8/1/2019 | 8/1/2020 | Ground Floor | Cooler | In lobby adjacent to D wing restrooms Low Right | WF-08012019-003204 | 8/13/2019 | FT-FY20-082019-003204-A | <1 | FT-FY20-082019-003204-B | <1 |
| WS-003205 | 8/1/2019 | 8/1/2020 | Ground Floor | Cooler | In lobby adjacent to C wing restrooms High Left | WF-08012019-003205 | 8/13/2019 | FT-FY20-082019-003205-A | <1 | FT-FY20-082019-003205-B | <1 |
| WS-003206 | 8/1/2019 | 8/1/2020 | Ground Floor | Cooler | In lobby adjacent to C wing restrooms Low Left | WF-08012019-003206 | 8/13/2019 | FT-FY20-082019-003206-A | <1 | FT-FY20-082019-003206-B | <1 |
| WS-003207 | 8/1/2019 | 8/1/2020 | Ground Floor | Cooler | In lobby adjacent to C wing restrooms High Right | WF-08012019-003207 | 8/13/2019 | FT-FY20-082019-003207-A | <1 | FT-FY20-082019-003207-B | <1 |
| WS-003208 | 8/1/2019 | 8/1/2020 | Ground Floor | Cooler | In lobby adjacent to C wing restrooms Low Right | WF-08012019-003208 | 8/13/2019 | FT-FY20-082019-003208-A | <1 | FT-FY20-082019-003208-B | <1 |
| WS-003230 | 8/1/2019 | 8/1/2020 | Ground Floor | Classroom Faucet | In room D105 | WF-08012019-003230 | 8/13/2019 | FT-FY20-082019-003230-A | <1 | FT-FY20-082019-003230-B | <1 |
| WS-003231 | 8/1/2019 | 8/1/2020 | Ground Floor | Classroom Faucet | In room D101 | WF-08012019-003231 | 8/13/2019 | FT-FY20-082019-003231-A | 2.3 | FT-FY20-082019-003231-B | <1 |
| WS-003232 | 8/1/2019 | 8/1/2020 | Ground Floor | Classroom Faucet | In room D108 | WF-08012019-003232 | 8/13/2019 | FT-FY20-082019-003232-A | 1.8 | FT-FY20-082019-003232-B | <1 |
| WS-003233 | 8/1/2019 | 8/1/2020 | Ground Floor | Classroom Faucet | In room D100 | WF-08012019-003233 | 8/13/2019 | FT-FY20-082019-003233-A | 1.2 | FT-FY20-082019-003233-B | <1 |
| WS-003234 | 8/1/2019 | 8/1/2020 | Ground Floor | Classroom Faucet | In room D107 | WF-08012019-003234 | 8/13/2019 | FT-FY20-082019-003234-A | 1.5 | FT-FY20-082019-003234-B | <1 |

Food Prep Sink

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | |
|---|-----------------------|------------------------|--------------|----------------|------------------|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS-003235 | 8/1/2019 | 8/1/2020 | Ground Floor | Food Prep Sink | In kitchen Right | WF-08012019-003235 | 8/13/2019 | FT-FY20-082019-003235-A | 3.2 | FT-FY20-082019-003235-B | <1 |