



Upshur Recreation Center Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005026	3/28/2024	3/28/2025	1	Cooler	In lobby adjacent to closet	WF-03282024-005026	4/19/2024	FT-FY24-04022024-005026-A	<1	FT-FY24-04022024-005026-B	<1
WS- 005027	12/19/2023	12/19/2024	1	Food Prep Sink	In kitchen	WF-12192023-005027	4/19/2024	FT-FY24-04022024-005027-A	<1	FT-FY24-04022024-005027-B	<1