



Upshur RC Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005026	4/24/2019	4/24/2020	1	Cooler	In lobby adjacent to closet	WF-04242019-005026	2/18/2020	FT-FY20-012020-005026-A	<1	FT-FY20-012020-005026-B	<1
WS- 005027	4/24/2019	4/24/2020	1	Food Prep Sink	In kitchen	WF-04242019-005027	2/18/2020	FT-FY20-012020-005027-A	<1	FT-FY20-012020-005027-B	<1