



Upshur RC Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005027	2/27/2021	2/27/2022	1	Food Prep Sink	In kitchen	WF-02272021-005027	2/16/2022	FT-FY22-01182022-005027-A	<1	FT-FY22-01182022-005027-B	<1