



Upshur RC Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005026	7/3/17	7/3/18	1	Cooler	In lobby adjacent to closet	WF-72017-005026	1/31/18	FT-FY18--72017-005026-A	<1	FT-FY18--72017-005026-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005027	7/3/17	7/3/18	1	Food Prep Sink	In kitchen	WF-72017-005027	1/31/18	FT-FY18--72017-005027-A	<1	FT-FY18--72017-005027-B	<1