



Van Ness ES Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001651	8/18/2025	8/18/2026	1	Combo Faucet	In classroom 138	WF-08182025-001651	1/27/2026	FT-FY26-01122026-001651-A	<2	FT-FY26-01122026-001651-B	<2
WS-001652	4/3/2025	4/3/2026	1	Combo Fountain	In classroom 138	WF-04032025-001652	1/27/2026	FT-FY26-01122026-001652-A	<2	FT-FY26-01122026-001652-B	<2
WS-001654	8/18/2025	8/18/2026	1	Combo Faucet	In classroom 140	WF-08182025-001654	1/27/2026	FT-FY26-01122026-001654-A	<2	FT-FY26-01122026-001654-B	<2
WS-001655	4/3/2025	4/3/2026	1	Combo Fountain	In classroom 140	WF-04032025-001655	1/27/2026	FT-FY26-01122026-001655-A	<2	FT-FY26-01122026-001655-B	<2
WS-001657	8/18/2025	8/18/2026	1	Combo Faucet	In classroom 142	WF-08182025-001657	1/27/2026	FT-FY26-01122026-001657-A	<2	FT-FY26-01122026-001657-B	<2
WS-001658	4/3/2025	4/3/2026	1	Combo Fountain	In classroom 142	WF-04032025-001658	1/27/2026	FT-FY26-01122026-001658-A	<2	FT-FY26-01122026-001658-B	<2
WS-001663	4/3/2025	4/3/2026	1	Bottle Filler	In annex in hallway adjacent to restroom	WF-04032025-001663	1/27/2026	FT-FY26-01122026-001663-A	<2	FT-FY26-01122026-001663-B	<2
WS-001664	4/3/2025	4/3/2026	1	Cooler	In annex in hallway adjacent to restroom	WF-04032025-001664	1/27/2026	FT-FY26-01122026-001664-A	<2	FT-FY26-01122026-001664-B	3.4
WS-003827	4/3/2025	4/3/2026	3	Cooler	In hallway across from stairwell B High Left	WF-04032025-003827	1/27/2026	FT-FY26-01122026-003827-A	<2	FT-FY26-01122026-003827-B	<2
WS-003828	4/3/2025	4/3/2026	3	Cooler	In hallway across from stairwell B Low Right	WF-04032025-003828	1/27/2026	FT-FY26-01122026-003828-A	<2	FT-FY26-01122026-003828-B	<2
WS-003829	4/3/2025	4/3/2026	3	Bottle Filler	In hallway across from stairwell B (bottle filler)	WF-04032025-003829	1/27/2026	FT-FY26-01122026-003829-A	<2	FT-FY26-01122026-003829-B	<2
WS-003830	4/3/2025	4/3/2026	3	Combo Fountain	In classroom 302 Left	WF-04032025-003830	1/27/2026	FT-FY26-01122026-003830-A	<2	FT-FY26-01122026-003830-B	<2
WS-003831	4/3/2025	4/3/2026	3	Combo Fountain	In classroom 306 Right	WF-04032025-003831	1/27/2026	FT-FY26-01122026-003831-A	<2	FT-FY26-01122026-003831-B	<2
WS-003832	4/3/2025	4/3/2026	3	Combo Fountain	In classroom 307 Right	WF-04032025-003832	1/27/2026	FT-FY26-01122026-003832-A	<2	FT-FY26-01122026-003832-B	<2
WS-003833	4/3/2025	4/3/2026	3	Combo Fountain	In classroom 311 Left	WF-04032025-003833	1/27/2026	FT-FY26-01122026-003833-A	<2	FT-FY26-01122026-003833-B	<2
WS-003834	4/3/2025	4/3/2026	3	Combo Fountain	In classroom 308 Left	WF-04032025-003834	1/27/2026	FT-FY26-01122026-003834-A	<2	FT-FY26-01122026-003834-B	<2
WS-003835	4/3/2025	4/3/2026	3	Combo Fountain	In classroom 312 Right	WF-04032025-003835	1/27/2026	FT-FY26-01122026-003835-A	<2	FT-FY26-01122026-003835-B	<2
WS-003836	4/3/2025	4/3/2026	Ground Floor	Cooler	In hallway adjacent to cafeteria High Left	WF-04032025-003836	1/27/2026	FT-FY26-01122026-003836-A	<2	FT-FY26-01122026-003836-B	<2
WS-003837	4/3/2025	4/3/2026	Ground Floor	Cooler	In hallway adjacent to cafeteria Low Right	WF-04032025-003837	1/27/2026	FT-FY26-01122026-003837-A	<2	FT-FY26-01122026-003837-B	<2
WS-003838	4/3/2025	4/3/2026	Ground Floor	Bottle Filler	In hallway adjacent to cafeteria (bottle filler)	WF-04032025-003838	1/27/2026	FT-FY26-01122026-003838-A	<2	FT-FY26-01122026-003838-B	<2
WS-003839	4/3/2025	4/3/2026	2	Break Room	In staff lounge 205	WF-04032025-003839	1/27/2026	FT-FY26-01122026-003839-A	<2	FT-FY26-01122026-003839-B	<2
WS-007900	8/18/2025	8/18/2026	3	Combo Faucet	In classroom 302 Right	WF-08182025-007900	1/27/2026	FT-FY26-01122026-007900-A	2	FT-FY26-01122026-007900-B	<2
WS-007901	8/18/2025	8/18/2026	3	Combo Faucet	In classroom 306 Left	WF-08182025-007901	1/27/2026	FT-FY26-01122026-007901-A	<2	FT-FY26-01122026-007901-B	<2
WS-007903	8/18/2025	8/18/2026	3	Combo Faucet	In classroom 311 Right	WF-08182025-007903	1/27/2026	FT-FY26-01122026-007903-A	<2	FT-FY26-01122026-007903-B	<2
WS-007904	8/18/2025	8/18/2026	3	Combo Faucet	In classroom 308 Left	WF-08182025-007904	1/27/2026	FT-FY26-01122026-007904-A	<2	FT-FY26-01122026-007904-B	<2
WS-007905	8/18/2025	8/18/2026	3	Combo Faucet	In classroom 312 Left	WF-08182025-007905	1/27/2026	FT-FY26-01122026-007905-A	<2	FT-FY26-01122026-007905-B	<2
WS-010339	4/3/2025	4/3/2026	1	Cooler	In hallway adjacent to room 136 High Left	WF-04032025-010339	1/27/2026	FT-FY26-01122026-010339-A	<2	FT-FY26-01122026-010339-B	<2
WS-010340	4/3/2025	4/3/2026	1	Cooler	In hallway adjacent to room 136 Low Right	WF-04032025-010340	1/27/2026	FT-FY26-01122026-010340-A	<2	FT-FY26-01122026-010340-B	<2
WS-010341	4/3/2025	4/3/2026	1	Bottle Filler	In hallway adjacent to room 136 (bottle filler)	WF-04032025-010341	1/27/2026	FT-FY26-01122026-010341-A	<2	FT-FY26-01122026-010341-B	<2
WS-010343	8/18/2025	8/18/2026	1	Combo Faucet	In classroom 136 Low Mid	WF-08182025-010343	1/27/2026	FT-FY26-01122026-010343-A	<2	FT-FY26-01122026-010343-B	<2
WS-010344	4/3/2025	4/3/2026	1	Combo Fountain	In classroom 134 Low Right	WF-04032025-010344	1/27/2026	FT-FY26-01122026-010344-A	<2	FT-FY26-01122026-010344-B	<2
WS-010345	8/18/2025	8/18/2026	1	Combo Faucet	In classroom 134 Low Mid	WF-08182025-010345	1/27/2026	FT-FY26-01122026-010345-A	<2	FT-FY26-01122026-010345-B	<2
WS-010346	4/3/2025	4/3/2026	1	Combo Fountain	In classroom 132 Low Left	WF-04032025-010346	1/27/2026	FT-FY26-01122026-010346-A	<2	FT-FY26-01122026-010346-B	<2
WS-010347	8/18/2025	8/18/2026	1	Combo Faucet	In classroom 132 Low Mid	WF-08182025-010347	1/27/2026	FT-FY26-01122026-010347-A	<2	FT-FY26-01122026-010347-B	<2

WS- 010350	8/18/2025	8/18/2026	2	Classroom Faucet	In classroom 216		WF-08182025-010350	1/27/2026	FT-FY26-01122026-010350-A	<2	FT-FY26-01122026-010350-B	<2
WS- 010351	8/18/2025	8/18/2026	2	Combo Faucet	In classroom 219	Low Mid	WF-08182025-010351	1/27/2026	FT-FY26-01122026-010351-A	<2	FT-FY26-01122026-010351-B	<2
WS- 010356	8/18/2025	8/18/2026	2	Combo Faucet	In classroom 210	Mid	WF-08182025-010356	1/27/2026	FT-FY26-01122026-010356-A	<2	FT-FY26-01122026-010356-B	<2
WS- 010357	8/18/2025	8/18/2026	2	Classroom Faucet	In classroom 210	Right	WF-08182025-010357	1/27/2026	FT-FY26-01122026-010357-A	<2	FT-FY26-01122026-010357-B	<2
WS- 010358	4/3/2025	4/3/2026	2	Cooler	In hallway adjacent to stairwell B	High Left	WF-04032025-010358	1/27/2026	FT-FY26-01122026-010358-A	<2	FT-FY26-01122026-010358-B	<2
WS- 010359	4/3/2025	4/3/2026	2	Bottle Filler	In hallway adjacent to stairwell B (bottle filler)		WF-04032025-010359	1/27/2026	FT-FY26-01122026-010359-A	<2	FT-FY26-01122026-010359-B	<2
WS- 010360	8/18/2025	8/18/2026	2	Classroom Faucet	In classroom 217	Right	WF-08182025-010360	1/27/2026	FT-FY26-01122026-010360-A	<2	FT-FY26-01122026-010360-B	<2
WS- 010361	8/18/2025	8/18/2026	2	Combo Faucet	In classroom 217	Mid	WF-08182025-010361	1/27/2026	FT-FY26-01122026-010361-A	<2	FT-FY26-01122026-010361-B	<2
WS- 010363	4/3/2025	4/3/2026	2	Cooler	In hallway adjacent to stairwell B	Low Right	WF-04032025-010363	1/27/2026	FT-FY26-01122026-010363-A	<2	FT-FY26-01122026-010363-B	<2
WS- 010364	8/18/2025	8/18/2026	1	Classroom Faucet	In classroom 136	High Right	WF-08182025-010364	1/27/2026	FT-FY26-01122026-010364-A	<2	FT-FY26-01122026-010364-B	<2
WS- 010365	8/18/2025	8/18/2026	1	Classroom Faucet	In classroom 134	High Left	WF-08182025-010365	1/27/2026	FT-FY26-01122026-010365-A	4.5	FT-FY26-01122026-010365-B	<2
WS- 010366	8/18/2025	8/18/2026	1	Classroom Faucet	In classroom 132	High Right	WF-08182025-010366	1/27/2026	FT-FY26-01122026-010366-A	<2	FT-FY26-01122026-010366-B	<2
WS- 010367	8/18/2025	8/18/2026	1	Classroom Faucet	In classroom 130	High Left	WF-08182025-010367	1/27/2026	FT-FY26-01122026-010367-A	<2	FT-FY26-01122026-010367-B	<2
WS- 010369	4/3/2025	4/3/2026	1	Health Suite	In health suite in treatment room 126A		WF-04032025-010369	1/27/2026	FT-FY26-01122026-010369-A	<2	FT-FY26-01122026-010369-B	<2
WS- 010379	4/3/2025	4/3/2026	1	Break Room	In break room 124		WF-04032025-010379	1/27/2026	FT-FY26-01122026-010379-A	<2	FT-FY26-01122026-010379-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010368	12/8/2025	12/8/2026	1	Food Prep Sink	In kitchen	WF-12082025-010368	1/27/2026	FT-FY26-01122026-010368-A	<2	FT-FY26-01122026-010368-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.