



Van Ness Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-001651	9/14/2021	9/14/2022	1	Combo Faucet	In classroom 138	WF-09142021-001651	1/13/2022	FT-FY22-12292021-001651-A	<1	FT-FY22-12292021-001651-B	<1
WS-001652	8/19/2021	8/19/2022	1	Combo Fountain	In classroom 138	WF-08192021-001652	1/13/2022	FT-FY22-12292021-001652-A	<1	FT-FY22-12292021-001652-B	<1
WS-001654	9/14/2021	9/14/2022	1	Combo Faucet	In classroom 140	WF-09142021-001654	1/13/2022	FT-FY22-12292021-001654-A	<1	FT-FY22-12292021-001654-B	<1
WS-001655	8/19/2021	8/19/2022	1	Combo Fountain	In classroom 140	WF-08192021-001655	1/13/2022	FT-FY22-12292021-001655-A	<1	FT-FY22-12292021-001655-B	<1
WS-001657	9/14/2021	9/14/2022	1	Combo Faucet	In classroom 142	WF-09142021-001657	1/13/2022	FT-FY22-12292021-001657-A	<1	FT-FY22-12292021-001657-B	<1
WS-001658	8/19/2021	8/19/2022	1	Combo Fountain	In classroom 142	WF-08192021-001658	1/13/2022	FT-FY22-12292021-001658-A	<1	FT-FY22-12292021-001658-B	<1
WS-001663	8/19/2021	8/19/2022	1	Bottle Filler	In annex in hallway adjacent to restroom	WF-08192021-001663	1/13/2022	FT-FY22-12292021-001663-A	<1	FT-FY22-12292021-001663-B	<1
WS-001664	8/19/2021	8/19/2022	1	Cooler	In annex in hallway adjacent to restroom	WF-08192021-001664	1/13/2022	FT-FY22-12292021-001664-A	<1	FT-FY22-12292021-001664-B	<1
WS-003827	12/1/2021	12/2/2022	3	Cooler	In hallway across from stairwell B	WF-12012021-003827	1/13/2022	FT-FY22-12292021-003827-A	<1	FT-FY22-12292021-003827-B	<1
WS-003828	12/1/2021	12/1/2022	3	Cooler	In hallway across from stairwell B	WF-12012021-003828	1/13/2022	FT-FY22-12292021-003828-A	<1	FT-FY22-12292021-003828-B	<1
WS-003829	12/1/2021	12/1/2022	3	Bottle Filler	In hallway across from stairwell B (bottle filler)	WF-12012021-003829	1/13/2022	FT-FY22-12292021-003829-A	<1	FT-FY22-12292021-003829-B	<1
WS-003830	5/4/2021	5/4/2022	3	Combo Fountain	In classroom 302	WF-05042021-003830	1/13/2022	FT-FY22-12292021-003830-A	<1	FT-FY22-12292021-003830-B	<1
WS-003831	5/4/2021	5/4/2022	3	Combo Fountain	In classroom 306	WF-05042021-003831	1/13/2022	FT-FY22-12292021-003831-A	<1	FT-FY22-12292021-003831-B	<1
WS-003832	5/4/2021	5/4/2022	3	Combo Fountain	In classroom 307	WF-05042021-003832	1/13/2022	FT-FY22-12292021-003832-A	<1	FT-FY22-12292021-003832-B	<1
WS-003833	5/4/2021	5/4/2022	3	Combo Fountain	In classroom 311	WF-05042021-003833	1/13/2022	FT-FY22-12292021-003833-A	<1	FT-FY22-12292021-003833-B	<1
WS-003834	5/4/2021	5/4/2022	3	Combo Fountain	In classroom 308	WF-05042021-003834	1/13/2022	FT-FY22-12292021-003834-A	<1	FT-FY22-12292021-003834-B	<1
WS-003835	5/4/2021	5/4/2022	3	Combo Fountain	In classroom 312	WF-05042021-003835	1/13/2022	FT-FY22-12292021-003835-A	<1	FT-FY22-12292021-003835-B	<1
WS-003836	5/4/2021	5/4/2022	Ground Floor	Cooler	In hallway adjacent to cafeteria	WF-05042021-003836	1/13/2022	FT-FY22-12292021-003836-A	<1	FT-FY22-12292021-003836-B	<1
WS-003837	5/4/2021	5/4/2022	Ground Floor	Cooler	In hallway adjacent to cafeteria	WF-05042021-003837	1/13/2022	FT-FY22-12292021-003837-A	<1	FT-FY22-12292021-003837-B	<1
WS-003838	5/4/2021	5/4/2022	Ground Floor	Bottle Filler	In hallway adjacent to cafeteria (bottle filler)	WF-05042021-003838	1/13/2022	FT-FY22-12292021-003838-A	<1	FT-FY22-12292021-003838-B	<1
WS-003839	5/4/2021	5/4/2022	2	Break Room	In staff lounge 205	WF-05042021-003839	1/13/2022	FT-FY22-12292021-003839-A	<1	FT-FY22-12292021-003839-B	<1
WS-007900	9/14/2021	9/14/2022	3	Combo Faucet	In classroom 302	WF-09142021-007900	1/13/2022	FT-FY22-12292021-007900-A	<1	FT-FY22-12292021-007900-B	<1
WS-007901	9/14/2021	9/14/2022	3	Combo Faucet	In classroom 306	WF-09142021-007901	1/13/2022	FT-FY22-12292021-007901-A	<1	FT-FY22-12292021-007901-B	<1
WS-007903	9/14/2021	9/14/2022	3	Combo Faucet	In classroom 311	WF-09142021-007903	1/13/2022	FT-FY22-12292021-007903-A	<1	FT-FY22-12292021-007903-B	<1
WS-007904	9/14/2021	9/14/2022	3	Combo Faucet	In classroom 308	WF-09142021-007904	1/13/2022	FT-FY22-12292021-007904-A	<1	FT-FY22-12292021-007904-B	<1
WS-007905	9/14/2021	9/14/2022	3	Combo Faucet	In classroom 312	WF-09142021-007905	1/13/2022	FT-FY22-12292021-007905-A	<1	FT-FY22-12292021-007905-B	<1
WS-007906	5/4/2021	5/4/2022	2	Combo Fountain	In art room 207	WF-05042021-007906	1/13/2022	FT-FY22-12292021-007906-A	<1	FT-FY22-12292021-007906-B	<1
WS-010339	12/1/2021	12/1/2022	1	Cooler	In hallway adjacent to room 136	WF-12012021-010339	1/13/2022	FT-FY22-12292021-010339-A	<1	FT-FY22-12292021-010339-B	<1
WS-010340	12/1/2021	12/1/2022	1	Cooler	In hallway adjacent to room 136	WF-12012021-010340	1/13/2022	FT-FY22-12292021-010340-A	<1	FT-FY22-12292021-010340-B	<1
WS-010341	12/1/2021	12/2/2022	1	Bottle Filler	In hallway adjacent to room 136 (bottle filler)	WF-12012021-010341	1/13/2022	FT-FY22-12292021-010341-A	<1	FT-FY22-12292021-010341-B	<1
WS-010342	5/4/2021	5/4/2022	1	Combo Fountain	In classroom 136	WF-05042021-010342	1/13/2022	FT-FY22-12292021-010342-A	<1	FT-FY22-12292021-010342-B	<1
WS-010343	9/14/2021	9/14/2022	1	Combo Faucet	In classroom 136	WF-09142021-010343	1/13/2022	FT-FY22-12292021-010343-A	<1	FT-FY22-12292021-010343-B	<1
WS-010344	5/4/2021	5/4/2022	1	Combo Fountain	In classroom 134	WF-05042021-010344	1/13/2022	FT-FY22-12292021-010344-A	<1	FT-FY22-12292021-010344-B	<1
WS-010345	9/14/2021	9/14/2022	1	Combo Faucet	In classroom 134	WF-09142021-010345	1/13/2022	FT-FY22-12292021-010345-A	<1	FT-FY22-12292021-010345-B	<1
WS-010346	5/4/2021	5/4/2022	1	Combo Fountain	In classroom 132	WF-05042021-010346	1/13/2022	FT-FY22-12292021-010346-A	<1	FT-FY22-12292021-010346-B	<1

WS- 010347	9/14/2021	9/14/2022	1	Combo Faucet	In classroom 132	Low	Mid	WF-09142021-010347	1/13/2022	FT-FY22-12292021-010347-A	<1	FT-FY22-12292021-010347-B	<1
WS- 010348	9/14/2021	9/14/2022	1	Combo Faucet	In classroom 130	Low	Mid	WF-09142021-010348	1/13/2022	FT-FY22-12292021-010348-A	<1	FT-FY22-12292021-010348-B	<1
WS- 010349	5/4/2021	5/4/2022	1	Combo Fountain	In classroom 130	Low	Right	WF-05042021-010349	1/13/2022	FT-FY22-12292021-010349-A	<1	FT-FY22-12292021-010349-B	<1
WS- 010350	9/14/2021	9/14/2022	2	Classroom Faucet	In classroom 216			WF-09142021-010350	1/13/2022	FT-FY22-12292021-010350-A	<1	FT-FY22-12292021-010350-B	<1
WS- 010351	9/14/2021	9/14/2022	2	Combo Faucet	In classroom 219	Low	Mid	WF-09142021-010351	1/13/2022	FT-FY22-12292021-010351-A	<1	FT-FY22-12292021-010351-B	<1
WS- 010352	5/4/2021	5/4/2022	2	Combo Fountain	In classroom 219	Low	Right	WF-05042021-010352	1/13/2022	FT-FY22-12292021-010352-A	<1	FT-FY22-12292021-010352-B	<1
WS- 010355	5/4/2021	5/4/2022	2	Combo Fountain	In classroom 210		Left	WF-05042021-010355	1/13/2022	FT-FY22-12292021-010355-A	<1	FT-FY22-12292021-010355-B	<1
WS- 010356	9/14/2021	9/14/2022	2	Combo Faucet	In classroom 210		Mid	WF-09142021-010356	1/13/2022	FT-FY22-12292021-010356-A	<1	FT-FY22-12292021-010356-B	<1
WS- 010357	9/14/2021	9/14/2022	2	Classroom Faucet	In classroom 210		Right	WF-09142021-010357	1/13/2022	FT-FY22-12292021-010357-A	<1	FT-FY22-12292021-010357-B	<1
WS- 010359	5/4/2021	5/4/2022	2	Bottle Filler	In hallway adjacent to stairwell B (bottle filler)			WF-05042021-010359	1/13/2022	FT-FY22-12292021-010359-A	<1	FT-FY22-12292021-010359-B	<1
WS- 010360	9/14/2021	9/14/2022	2	Classroom Faucet	In classroom 217		Right	WF-09142021-010360	1/13/2022	FT-FY22-12292021-010360-A	<1	FT-FY22-12292021-010360-B	<1
WS- 010361	9/14/2021	9/14/2022	2	Combo Faucet	In classroom 217		Mid	WF-09142021-010361	1/13/2022	FT-FY22-12292021-010361-A	<1	FT-FY22-12292021-010361-B	<1
WS- 010362	5/4/2021	5/4/2022	2	Combo Fountain	In classroom 217		Left	WF-05042021-010362	1/13/2022	FT-FY22-12292021-010362-A	<1	FT-FY22-12292021-010362-B	<1
WS- 010364	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 136	High	Right	WF-09142021-010364	1/13/2022	FT-FY22-12292021-010364-A	<1	FT-FY22-12292021-010364-B	<1
WS- 010365	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 134	High	Left	WF-09142021-010365	1/13/2022	FT-FY22-12292021-010365-A	<1	FT-FY22-12292021-010365-B	<1
WS- 010366	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 132	High	Right	WF-09142021-010366	1/13/2022	FT-FY22-12292021-010366-A	<1	FT-FY22-12292021-010366-B	<1
WS- 010367	9/14/2021	9/14/2022	1	Classroom Faucet	In classroom 130	High	Left	WF-09142021-010367	1/13/2022	FT-FY22-12292021-010367-A	<1	FT-FY22-12292021-010367-B	<1
WS- 010369	5/4/2021	5/4/2022	1	Health Suite	In health suite in treatment room 126A			WF-05042021-010369	1/13/2022	FT-FY22-12292021-010369-A	<1	FT-FY22-12292021-010369-B	<1
WS- 010379	5/4/2021	5/4/2022	1	Break Room	In break room 124			WF-05042021-010379	1/13/2022	FT-FY22-12292021-010379-A	<1	FT-FY22-12292021-010379-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010368	2/17/2021	2/17/2022	1	Food Prep Sink	In kitchen	WF-02172021-010368	1/13/2022	FT-FY22-12292021-010368-A	<1	FT-FY22-12292021-010368-B	<1