



# VAN NESS LEAD WATER TEST RESULTS

May 24th, 2016



| Building Location | Sample Collected Date | Water Source ID | Device Type | Floor    | Device Location  | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation  | Retest Date | Retest 1st Draw | Retest 2nd Draw |
|-------------------|-----------------------|-----------------|-------------|----------|--|----------------------|--------------------------------|----------------------|--------------------------------|--|-------------|-----------------|-----------------|
| 1 VAN NESS        | 5/13/2016             | WS-010339       | Cooler      | 1        | In hallway adjacent to classroom 136                       | WT-042916-10356-A    | < 1                            | WT-042916-10356-B    | < 1                            |  |             |                 |                 |
| 2 VAN NESS        | 5/13/2016             | WS-010340       | Cooler      | 1        | In hallway adjacent to 136                                 | WT-042916-10357-A    | < 1                            | WT-042916-10357-B    | < 1                            |  |             |                 |                 |
| 3 VAN NESS        | 5/13/2016             | WS-010341       | Other       | 1        | In hallway adjacent to classroom 136 (water bottle filler) | WT-042916-10358-A    | < 1                            | WT-042916-10358-B    | < 1                            |  |             |                 |                 |
| 4 VAN NESS        | 5/13/2016             | WS-010342       | Fountain    | 1        | In classroom 136   | WT-042916-10359-A    | < 1                            | WT-042916-10359-B    | < 1                            |  |             |                 |                 |
| 5 VAN NESS        | 5/13/2016             | WS-010343       | Classroom   | 1        | In classroom 136   | WT-042916-10360-A    | < 1                            | WT-042916-10360-B    | < 1                            |  |             |                 |                 |
| 6 VAN NESS        | 5/13/2016             | WS-010344       | Fountain    | 1        | In classroom 134   | WT-042916-10361-A    | < 1                            | WT-042916-10361-B    | < 1                            |  |             |                 |                 |
| 7 VAN NESS        | 5/13/2016             | WS-010345       | Classroom   | 1        | In classroom 134   | WT-042916-10362-A    | < 1                            | WT-042916-10362-B    | < 1                            |  |             |                 |                 |
| 8 VAN NESS        | 5/13/2016             | WS-010346       | Fountain    | 1        | In classroom 132   | WT-042916-10363-A    | < 1                            | WT-042916-10363-B    | < 1                            |  |             |                 |                 |
| 9 VAN NESS        | 5/13/2016             | WS-010347       | Classroom   | 1        | In classroom 132   | WT-042916-10364-A    | < 1                            | WT-042916-10364-B    | < 1                            |  |             |                 |                 |
| 10 VAN NESS       | 5/13/2016             | WS-010348       | Classroom   | 1        | In classroom 130   | WT-042916-10365-A    | < 1                            | WT-042916-10365-B    | < 1                            |  |             |                 |                 |
| 11 VAN NESS       | 5/13/2016             | WS-010349       | Fountain    | 1        | In classroom 130   | WT-042916-10366-A    | < 1                            | WT-042916-10366-B    | < 1                            |  |             |                 |                 |
| 12 VAN NESS       | 5/13/2016             | WS-010350       | Classroom   | 2        | In classroom 216   | WT-042916-10367-A    | < 1                            | WT-042916-10367-B    | < 1                            |  |             |                 |                 |
| 13 VAN NESS       | 5/13/2016             | WS-010351       | Classroom   | 2        | In classroom 219   | WT-042916-10368-A    | < 1                            | WT-042916-10368-B    | < 1                            |  |             |                 |                 |
| 14 VAN NESS       | 5/13/2016             | WS-010352       | Fountain    | 2        | In classroom 219   | WT-042916-10369-A    | < 1                            | WT-042916-10369-B    | < 1                            |  |             |                 |                 |
| 15 VAN NESS       | 5/13/2016             | WS-010353       | Classroom   | 2        | In classroom 220   | WT-042916-10370-A    | < 1                            | WT-042916-10370-B    | < 1                            |  |             |                 |                 |
| 16 VAN NESS       | 5/13/2016             | WS-010354       | Classroom   | 2        | In classroom 214   | WT-042916-10371-A    | < 1                            | WT-042916-10371-B    | < 1                            |  |             |                 |                 |
| 17 VAN NESS       | 5/13/2016             | WS-010355       | Fountain    | 2        | In classroom 210   | WT-042916-10372-A    | < 1                            | WT-042916-10372-B    | < 1                            |  |             |                 |                 |
| 18 VAN NESS       | 5/13/2016             | WS-010356       | Classroom   | 2        | In classroom 210   | WT-042916-10373-A    | < 1                            | WT-042916-10373-B    | < 1                            |  |             |                 |                 |
| 19 VAN NESS       | 5/13/2016             | WS-010357       | Classroom   | 2        | In classroom 210   | WT-042916-10374-A    | < 1                            | WT-042916-10374-B    | < 1                            |  |             |                 |                 |
| 20 VAN NESS       | 5/13/2016             | WS-010358       | Cooler      | 2        | In hallway next to stair B                                 | WT-042916-10375-A    | < 1                            | WT-042916-10375-B    | < 1                            |  |             |                 |                 |
| 21 VAN NESS       | 5/13/2016             | WS-010359       | Cooler      | 2        | In hallway next to stair B water bottle filling station    | WT-042916-10376-A    | < 1                            | WT-042916-10376-B    | < 1                            |  |             |                 |                 |
| 22 VAN NESS       | 5/13/2016             | WS-010360       | Classroom   | 2        | In classroom 217   | WT-042916-10377-A    | < 1                            | WT-042916-10377-B    | < 1                            |  |             |                 |                 |
| 23 VAN NESS       | 5/13/2016             | WS-010361       | Classroom   | 2        | In classroom 217   | WT-042916-10378-A    | < 1                            | WT-042916-10378-B    | < 1                            |  |             |                 |                 |
| 24 VAN NESS       | 5/13/2016             | WS-010362       | Fountain    | 2        | In classroom 217   | WT-042916-10379-A    | < 1                            | WT-042916-10379-B    | < 1                            |  |             |                 |                 |
| 25 VAN NESS       | 5/13/2016             | WS-010363       | Cooler      | 2        | In hallway next to stair B                                 | WT-042916-10380-A    | < 1                            | WT-042916-10380-B    | < 1                            |  |             |                 |                 |
| 26 VAN NESS       | 5/13/2016             | WS-010364       | Classroom   | 1        | In classroom 136   | WT-042916-10381-A    | < 1                            | WT-042916-10381-B    | < 1                            |  |             |                 |                 |
| 27 VAN NESS       | 5/13/2016             | WS-010365       | Classroom   | 1        | In classroom 134   | WT-042916-10382-A    | < 1                            | WT-042916-10382-B    | < 1                            |  |             |                 |                 |
| 28 VAN NESS       | 5/13/2016             | WS-010366       | Classroom   | 1        | In classroom 132   | WT-042916-10383-A    | < 1                            | WT-042916-10383-B    | < 1                            |  |             |                 |                 |
| 29 VAN NESS       | 5/13/2016             | WS-010367       | Classroom   | 1        | In classroom 130   | WT-042916-10384-A    | < 1                            | WT-042916-10384-B    | < 1                            |  |             |                 |                 |
| 30 VAN NESS       | 5/13/2016             | WS-010368       | Kitchen     | 1        | In the kitchen   | WT-042916-10385-A    | < 1                            | WT-042916-10385-B    | < 1                            |  |             |                 |                 |
| 31 VAN NESS       | 5/13/2016             | WS-010369       | Bathroom    | 1        | In health suite bathroom                                   | WT-042916-10386-A    | < 1                            | WT-042916-10386-B    | < 1                            |  |             |                 |                 |
| 32 VAN NESS       | 5/13/2016             | WS-010378       | Classroom   | 2        | In classroom 219   | WT-042916-10395-A    | < 1                            | WT-042916-10395-B    | < 1                            |  |             |                 |                 |
| 33 VAN NESS       | 5/13/2016             | WS-010379       | Break Room  | 1        | In room 124  | WT-042916-10396-A    | < 1                            | WT-042916-10396-B    | < 1                            |  |             |                 |                 |
| 34 VAN NESS       | 5/13/2016             | WS-010380       | Utility     | Basement | In boiler room   | WT-042916-10397-A    | 51.9                           | WT-042916-10397-B    | < 1                            | Non-drinking water source – Not accessible to children |             |                 |                 |

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.