



# Van Ness ES Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation													
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003830	6/28/2017	6/28/2018	3	Combo Fountain	In classroom 302	Left		WF-62017-003830	11/15/2017	FT-FY18-62017-003830-A	<1	FT-FY18-62017-003830-B	<1
WS-003833	6/28/2017	6/28/2018	3	Combo Fountain	In classroom 311	Left		WF-62017-003833	11/15/2017	FT-FY18-62017-003833-A	<1	FT-FY18-62017-003833-B	<1
WS-003836	6/28/2017	6/28/2018	Ground Floor	Cooler	In hallway adjacent to cafeteria	Left	High	WF-62017-003836	11/15/2017	FT-FY18-62017-003836-A	<1	FT-FY18-62017-003836-B	<1
WS-003838	6/28/2017	6/28/2018	1	Bottle Filler	In hallway adjacent to cafeteria (bottle filler)			WF-62017-003838	11/15/2017	FT-FY18-62017-003838-A	<1	FT-FY18-62017-003838-B	<1
WS-003839	6/28/2017	6/28/2018	2	Break Room	In staff lounge 205			WF-62017-003839	11/15/2017	FT-FY18-62017-003839-A	<1	FT-FY18-62017-003839-B	<1
WS-007901	10/30/2017	10/30/2018	3	Combo Faucet	In classroom 306	Left		WF-102017-007901	11/15/2017	FT-FY18-102017-007901-A	<1	FT-FY18-102017-007901-B	<1
WS-010340	6/28/2017	6/28/2018	1	Cooler	In hallway adjacent to room 136	Right	Low	WF-62017-010340	11/15/2017	FT-FY18-62017-010340-A	<1	FT-FY18-62017-010340-B	<1
WS-010343	10/30/2017	10/30/2018	1	Combo Faucet	In classroom 136	Mid	Low	WF-102017-010343	11/15/2017	FT-FY18-102017-010343-A	<1	FT-FY18-102017-010343-B	<1
WS-010344	6/28/2017	6/28/2018	1	Combo Fountain	In classroom 134	Right	Low	WF-62017-010344	11/15/2017	FT-FY18-62017-010344-A	<1	FT-FY18-62017-010344-B	<1
WS-010348	10/30/2017	10/30/2018	1	Combo Faucet	In classroom 130	Mid	Low	WF-102017-010348	11/15/2017	FT-FY18-102017-010348-A	<1	FT-FY18-102017-010348-B	<1
WS-010355	6/28/2017	6/28/2018	2	Combo Fountain	In classroom 210	Left		WF-62017-010355	11/15/2017	FT-FY18-62017-010355-A	<1	FT-FY18-62017-010355-B	<1
WS-010356	10/30/2017	10/30/2018	2	Combo Faucet	In classroom 210	Mid		WF-102017-010356	11/15/2017	FT-FY18-102017-010356-A	<1	FT-FY18-102017-010356-B	<1
WS-010358	6/28/2017	6/28/2018	2	Cooler	In hallway adjacent to stairwell B	Left	High	WF-62017-010358	11/15/2017	FT-FY18-62017-010358-A	<1	FT-FY18-62017-010358-B	<1
WS-010365	10/30/2017	10/30/2018	1	Classroom Faucet	In classroom 134	Left	High	WF-102017-010365	11/15/2017	FT-FY18-102017-010365-A	<1	FT-FY18-102017-010365-B	<1
WS-010367	10/30/2017	10/30/2018	1	Classroom Faucet	In classroom 130	Left	High	WF-102017-010367	11/15/2017	FT-FY18-102017-010367-A	<1	FT-FY18-102017-010367-B	<1

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-010368	1	Food Prep Sink	In	Kitchen				11/15/2017	FT-FY18-102017-010368-A	<1	FT-FY18-102017-010368-B	<1