



# Van Ness ES Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003827	6/13/2018	6/13/2019	3	Cooler	In hallway across from stairwell B High Left	WF-06132018-003827	12/2/2018	FT-FY19-112018-003827-A	<1	FT-FY19-112018-003827-B	<1
WS-003828	6/13/2018	6/13/2019	3	Cooler	In hallway across from stairwell B Low Right	WF-06132018-003828	12/2/2018	FT-FY19-112018-003828-A	<1	FT-FY19-112018-003828-B	<1
WS-003829	6/13/2018	6/13/2019	3	Bottle Filler	In hallway across from stairwell B (bottle filler)	WF-06132018-003829	12/2/2018	FT-FY19-112018-003829-A	<1	FT-FY19-112018-003829-B	<1
WS-003830	6/13/2018	6/13/2019	3	Combo Fountain	In classroom 302 Left	WF-06132018-003830	12/2/2018	FT-FY19-112018-003830-A	<1	FT-FY19-112018-003830-B	<1
WS-003831	6/13/2018	6/13/2019	3	Combo Fountain	In classroom 306 Right	WF-06132018-003831	12/2/2018	FT-FY19-112018-003831-A	<1	FT-FY19-112018-003831-B	<1
WS-003832	6/13/2018	6/13/2019	3	Combo Fountain	In classroom 307 Right	WF-06132018-003832	12/2/2018	FT-FY19-112018-003832-A	<1	FT-FY19-112018-003832-B	<1
WS-003833	6/13/2018	6/13/2019	3	Combo Fountain	In classroom 311 Left	WF-06132018-003833	12/2/2018	FT-FY19-112018-003833-A	<1	FT-FY19-112018-003833-B	<1
WS-003834	6/13/2018	6/13/2019	3	Combo Fountain	In classroom 308 Left	WF-06132018-003834	12/2/2018	FT-FY19-112018-003834-A	<1	FT-FY19-112018-003834-B	<1
WS-003835	6/13/2018	6/13/2019	3	Combo Fountain	In classroom 312 Right	WF-06132018-003835	12/2/2018	FT-FY19-112018-003835-A	<1	FT-FY19-112018-003835-B	<1
WS-003836	6/13/2018	6/13/2019	Ground Floor	Cooler	In hallway adjacent to cafeteria High Left	WF-06132018-003836	12/2/2018	FT-FY19-112018-003836-A	<1	FT-FY19-112018-003836-B	<1
WS-003837	6/13/2018	6/13/2019	Ground Floor	Cooler	In hallway adjacent to cafeteria Low Right	WF-06132018-003837	12/2/2018	FT-FY19-112018-003837-A	<1	FT-FY19-112018-003837-B	<1
WS-003838	6/13/2018	6/13/2019	Ground Floor	Bottle Filler	In hallway adjacent to cafeteria (bottle filler)	WF-06132018-003838	12/2/2018	FT-FY19-112018-003838-A	<1	FT-FY19-112018-003838-B	<1
WS-003839	6/13/2018	6/13/2019	2	Break Room	In staff lounge 205	WF-06132018-003839	12/2/2018	FT-FY19-112018-003839-A	<1	FT-FY19-112018-003839-B	<1
WS-007900	10/9/2018	10/9/2019	3	Combo Faucet	In classroom 302 Right	WF-10092018-007900	12/2/2018	FT-FY19-112018-007900-A	<1	FT-FY19-112018-007900-B	<1
WS-007901	10/9/2018	10/9/2019	3	Combo Faucet	In classroom 306 Left	WF-10092018-007901	12/2/2018	FT-FY19-112018-007901-A	<1	FT-FY19-112018-007901-B	<1
WS-007903	10/9/2018	10/9/2019	3	Combo Faucet	In classroom 311 Right	WF-10092018-007903	12/2/2018	FT-FY19-112018-007903-A	<1	FT-FY19-112018-007903-B	<1
WS-007904	10/9/2018	10/9/2019	3	Combo Faucet	In classroom 308 Left	WF-10092018-007904	12/2/2018	FT-FY19-112018-007904-A	<1	FT-FY19-112018-007904-B	<1
WS-007905	10/9/2018	10/9/2019	3	Combo Faucet	In classroom 312 Left	WF-10092018-007905	12/2/2018	FT-FY19-112018-007905-A	<1	FT-FY19-112018-007905-B	<1
WS-007906	6/13/2018	6/13/2019	2	Combo Fountain	In art room 207	WF-06132018-007906	12/2/2018	FT-FY19-112018-007906-A	<1	FT-FY19-112018-007906-B	<1
WS-010339	6/13/2018	6/13/2019	1	Cooler	In hallway adjacent to room 136 High Left	WF-06132018-010339	12/2/2018	FT-FY19-112018-010339-A	<1	FT-FY19-112018-010339-B	<1
WS-010340	6/13/2018	6/13/2019	1	Cooler	In hallway adjacent to room 136 Low Right	WF-06132018-010340	12/2/2018	FT-FY19-112018-010340-A	<1	FT-FY19-112018-010340-B	<1
WS-010341	6/13/2018	6/13/2019	1	Bottle Filler	In hallway adjacent to room 136 (bottle filler)	WF-06132018-010341	12/2/2018	FT-FY19-112018-010341-A	<1	FT-FY19-112018-010341-B	<1
WS-010342	6/13/2018	6/13/2019	1	Combo Fountain	In classroom 136 Low Left	WF-06132018-010342	12/2/2018	FT-FY19-112018-010342-A	<1	FT-FY19-112018-010342-B	<1
WS-010343	10/9/2018	10/9/2019	1	Combo Faucet	In classroom 136 Low Mid	WF-10092018-010343	12/2/2018	FT-FY19-112018-010343-A	<1	FT-FY19-112018-010343-B	<1
WS-010344	6/13/2018	6/13/2019	1	Combo Fountain	In classroom 134 Low Right	WF-06132018-010344	12/2/2018	FT-FY19-112018-010344-A	<1	FT-FY19-112018-010344-B	<1
WS-010345	10/9/2018	10/9/2019	1	Combo Faucet	In classroom 134 Low Mid	WF-10092018-010345	12/2/2018	FT-FY19-112018-010345-A	<1	FT-FY19-112018-010345-B	<1
WS-010346	6/13/2018	6/13/2019	1	Combo Fountain	In classroom 132 Low Left	WF-06132018-010346	12/2/2018	FT-FY19-112018-010346-A	<1	FT-FY19-112018-010346-B	<1
WS-010347	10/9/2018	10/9/2019	1	Combo Faucet	In classroom 132 Low Mid	WF-10092018-010347	12/2/2018	FT-FY19-112018-010347-A	<1	FT-FY19-112018-010347-B	<1
WS-010348	10/9/2018	10/9/2019	1	Combo Faucet	In classroom 130 Low Mid	WF-10092018-010348	12/2/2018	FT-FY19-112018-010348-A	<1	FT-FY19-112018-010348-B	<1
WS-010349	6/13/2018	6/13/2019	1	Combo Fountain	In classroom 130 Low Right	WF-06132018-010349	12/2/2018	FT-FY19-112018-010349-A	<1	FT-FY19-112018-010349-B	<1
WS-010350	10/9/2018	10/9/2019	2	Classroom Faucet	In classroom 216	WF-10092018-010350	12/2/2018	FT-FY19-112018-010350-A	<1	FT-FY19-112018-010350-B	<1
WS-010351	10/9/2018	10/9/2019	2	Combo Faucet	In classroom 219 Low Mid	WF-10092018-010351	12/2/2018	FT-FY19-112018-010351-A	<1	FT-FY19-112018-010351-B	<1
WS-010352	6/13/2018	6/13/2019	2	Combo Fountain	In classroom 219 Low Right	WF-06132018-010352	12/2/2018	FT-FY19-112018-010352-A	<1	FT-FY19-112018-010352-B	<1
WS-010355	6/13/2018	6/13/2019	2	Combo Fountain	In classroom 210 Left	WF-06132018-010355	12/2/2018	FT-FY19-112018-010355-A	<1	FT-FY19-112018-010355-B	<1
WS-010356	10/9/2018	10/9/2019	2	Combo Faucet	In classroom 210 Mid	WF-10092018-010356	12/2/2018	FT-FY19-112018-010356-A	<1	FT-FY19-112018-010356-B	<1

WS- 010357	10/9/2018	10/9/2019	2	Classroom Faucet	In classroom 210	Right	WF-10092018-010357	12/2/2018	FT-FY19-112018-010357-A	<1	FT-FY19-112018-010357-B	<1
WS- 010358	6/13/2018	6/13/2019	2	Cooler	In hallway adjacent to stairwell B	High Left	WF-06132018-010358	12/2/2018	FT-FY19-112018-010358-A	<1	FT-FY19-112018-010358-B	<1
WS- 010359	6/13/2018	6/13/2019	2	Bottle Filler	In hallway adjacent to stairwell B (bottle filler)		WF-06132018-010359	12/2/2018	FT-FY19-112018-010359-A	<1	FT-FY19-112018-010359-B	<1
WS- 010360	10/9/2018	10/9/2019	2	Classroom Faucet	In classroom 217	Right	WF-10092018-010360	12/2/2018	FT-FY19-112018-010360-A	<1	FT-FY19-112018-010360-B	<1
WS- 010361	10/9/2018	10/9/2019	2	Combo Faucet	In classroom 217	Mid	WF-10092018-010361	12/2/2018	FT-FY19-112018-010361-A	1	FT-FY19-112018-010361-B	<1
WS- 010362	6/13/2018	6/13/2019	2	Combo Fountain	In classroom 217	Left	WF-06132018-010362	12/2/2018	FT-FY19-112018-010362-A	<1	FT-FY19-112018-010362-B	<1
WS- 010363	6/13/2018	6/13/2019	2	Cooler	In hallway adjacent to stairwell B	Low Right	WF-06132018-010363	12/2/2018	FT-FY19-112018-010363-A	<1	FT-FY19-112018-010363-B	<1
WS- 010364	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 136	High Right	WF-10092018-010364	12/2/2018	FT-FY19-112018-010364-A	<1	FT-FY19-112018-010364-B	<1
WS- 010365	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 134	High Left	WF-10092018-010365	12/2/2018	FT-FY19-112018-010365-A	<1	FT-FY19-112018-010365-B	<1
WS- 010366	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 132	High Right	WF-10092018-010366	12/2/2018	FT-FY19-112018-010366-A	<1	FT-FY19-112018-010366-B	<1
WS- 010367	10/9/2018	10/9/2019	1	Classroom Faucet	In classroom 130	High Left	WF-10092018-010367	12/2/2018	FT-FY19-112018-010367-A	<1	FT-FY19-112018-010367-B	<1
WS- 010369	6/13/2018	6/13/2019	1	Health Suite	In health suite in treatment room 126A		WF-06132018-010369	12/2/2018	FT-FY19-112018-010369-A	<1	FT-FY19-112018-010369-B	<1
WS- 010379	6/13/2018	6/13/2019	1	Break Room	In break room 124		WF-06132018-010379	12/2/2018	FT-FY19-112018-010379-A	<1	FT-FY19-112018-010379-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation									
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 010368	1	Food Prep Sink	In kitchen	12/2/2018	FT-FY19-112018-010368-A	<1	FT-FY19-112018-010368-B	<1	