



WATKINS ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Below Actionable Level - Devices Requiring No Remediation

Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WATKINS ELEMENTARY SCHOOL	WS- 009390	8/24/2017	1	Combo Fountain	In classroom 105	FT-82017-009390-A	< 1	FT-82017-009390-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009392	8/24/2017	1	Combo Fountain	In classroom 110	FT-82017-009392-A	< 1	FT-82017-009392-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009394	8/24/2017	1	Combo Fountain	In classroom 115	FT-82017-009394-A	< 1	FT-82017-009394-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009473	8/24/2017	1	Combo Fountain	In classroom 120	FT-82017-009473-A	< 1	FT-82017-009473-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009475	8/24/2017	1	Combo Fountain	In classroom 125	FT-82017-009475-A	< 1	FT-82017-009475-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009477	8/24/2017	1	Combo Fountain	In classroom 130	FT-82017-009477-A	< 1	FT-82017-009477-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009479	8/24/2017	1	Combo Fountain	In classroom 140	FT-82017-009479-A	< 1	FT-82017-009479-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009481	8/24/2017	1	Combo Fountain	In classroom 135	FT-82017-009481-A	< 1	FT-82017-009481-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009482	8/24/2017	1	Cooler	In gym room 190 High Left	FT-82017-009482-A	< 1	FT-82017-009482-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009483	8/24/2017	1	Cooler	In gym room 190	FT-82017-009483-A	< 1	FT-82017-009483-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009484	8/24/2017	1	Bottle Filler	In gym room 190	FT-82017-009484-A	< 1	FT-82017-009484-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009489	8/24/2017	1	Break Room	In main office in workroom 151	FT-82017-009489-A	< 1	FT-82017-009489-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009491	8/24/2017	4	Combo Fountain	In classroom 425	FT-82017-009491-A	< 1	FT-82017-009491-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009492	8/24/2017	4	Cooler	In hallway across from elevator 4th floor Low Right	FT-82017-009492-A	< 1	FT-82017-009492-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009493	8/24/2017	3	Cooler	In hallway across from elevator 3rd floor Low Right	FT-82017-009493-A	< 1	FT-82017-009493-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009495	8/24/2017	3	Combo Fountain	In classroom 305	FT-82017-009495-A	< 1	FT-82017-009495-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009497	8/24/2017	2	Combo Fountain	In classroom 215	FT-82017-009497-A	< 1	FT-82017-009497-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009499	8/24/2017	2	Combo Fountain	In classroom 220	FT-82017-009499-A	< 1	FT-82017-009499-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009503	8/24/2017	1	Cooler	In hallway across from gym room 190 High Left	FT-82017-009503-A	< 1	FT-82017-009503-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009504	8/24/2017	1	Cooler	In hallway across from gym room 190 Low Right	FT-82017-009504-A	< 1	FT-82017-009504-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009505	8/24/2017	1	Bottle Filler	In hallway across from gym room 190	FT-82017-009505-A	< 1	FT-82017-009505-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009506	8/24/2017	1	Health Suite	In health suite room 121	FT-82017-009506-A	< 1	FT-82017-009506-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 009507	8/24/2017	1	Break Room	In staff workroom 104	FT-82017-009507-A	< 1	FT-82017-009507-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010100	8/24/2017	4	Break Room	In staff workroom 404	FT-82017-010100-A	< 1	FT-82017-010100-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010102	8/24/2017	4	Combo Fountain	In classroom 405	FT-82017-010102-A	< 1	FT-82017-010102-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010104	8/24/2017	4	Combo Fountain	In classroom 410 Low Right	FT-82017-010104-A	< 1	FT-82017-010104-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010106	8/24/2017	4	Combo Fountain	In classroom 415	FT-82017-010106-A	< 1	FT-82017-010106-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010108	8/24/2017	4	Combo Fountain	In classroom 420	FT-82017-010108-A	< 1	FT-82017-010108-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010110	8/24/2017	4	Combo Fountain	In classroom 435	FT-82017-010110-A	< 1	FT-82017-010110-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010111	8/24/2017	4	Bottle Filler	In hallway across from elevator 4th floor	FT-82017-010111-A	< 1	FT-82017-010111-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010112	8/24/2017	4	Cooler	In hallway across from elevator 4th floor High Left	FT-82017-010112-A	< 1	FT-82017-010112-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010113	8/24/2017	3	Bottle Filler	In hallway across from elevator 3rd floor	FT-82017-010113-A	< 1	FT-82017-010113-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010114	8/24/2017	3	Cooler	In hallway across from elevator 3rd floor High Left	FT-82017-010114-A	< 1	FT-82017-010114-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010116	8/24/2017	3	Combo Fountain	In classroom 320	FT-82017-010116-A	< 1	FT-82017-010116-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010118	8/24/2017	3	Combo Fountain	In classroom 315	FT-82017-010118-A	< 1	FT-82017-010118-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010119	8/24/2017	3	Break Room	In staff lounge 311B	FT-82017-010119-A	2.7	FT-82017-010119-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010121	8/24/2017	3	Combo Fountain	In classroom 310	FT-82017-010121-A	< 1	FT-82017-010121-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010122	8/24/2017	3	Break Room	In staff workroom 304	FT-82017-010122-A	< 1	FT-82017-010122-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010123	8/24/2017	2	Break Room	In staff workroom 204	FT-82017-010123-A	< 1	FT-82017-010123-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010218	8/24/2017	2	Combo Fountain	In classroom 205	FT-82017-010218-A	< 1	FT-82017-010218-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010220	8/24/2017	2	Combo Fountain	In classroom 210	FT-82017-010220-A	< 1	FT-82017-010220-B	< 1

WATKINS ELEMENTARY SCHOOL	WS- 010225	8/24/2017	2	Bottle Filler	In hallway across from elevator 2nd floor			FT-82017-010225-A	< 1	FT-82017-010225-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010226	8/24/2017	2	Cooler	In hallway across from elevator 2nd floor	Low	Right	FT-82017-010226-A	< 1	FT-82017-010226-B	< 1
WATKINS ELEMENTARY SCHOOL	WS- 010227	8/24/2017	2	Cooler	In hallway across from elevator 2nd floor	High	Left	FT-82017-010227-A	< 1	FT-82017-010227-B	< 1