



WALKER JONES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002056	12/23/2016	1	Combo Faucet	In classroom 104	FT-122016-002056-A	< 1	FT-122016-002056-B	< 1
2	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002059	12/23/2016	1	Combo Faucet	In classroom 105	FT-122016-002059-A	< 1	FT-122016-002059-B	< 1
3	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002060	12/23/2016	1	Combo Faucet	In classroom 103	FT-122016-002060-A	< 1	FT-122016-002060-B	< 1
4	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002061	12/23/2016	1	Combo Faucet	In classroom 106	FT-122016-002061-A	< 1	FT-122016-002061-B	< 1
5	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002064	12/23/2016	1	Combo Faucet	In classroom 108	FT-122016-002064-A	< 1	FT-122016-002064-B	< 1
6	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002068	12/23/2016	1	Break Room	In staff lounge 112	FT-122016-002068-A	< 1	FT-122016-002068-B	< 1
7	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002069	12/23/2016	1	Combo Faucet	In classroom 115	FT-122016-002069-A	< 1	FT-122016-002069-B	< 1
8	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002071	12/23/2016	1	Combo Faucet	In classroom 120	FT-122016-002071-A	< 1	FT-122016-002071-B	< 1
9	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002073	12/23/2016	1	Combo Faucet	In classroom 122	FT-122016-002073-A	< 1	FT-122016-002073-B	< 1
10	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002077	12/23/2016	1	Combo Faucet	In classroom 119	FT-122016-002077-A	< 1	FT-122016-002077-B	< 1
11	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002079	12/23/2016	1	Combo Faucet	In classroom 128	FT-122016-002079-A	< 1	FT-122016-002079-B	< 1
12	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002082	12/23/2016	1	Combo Faucet	In Classroom 126	FT-122016-002082-A	< 1	FT-122016-002082-B	< 1
13	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002087	12/23/2016	Basement	Combo Faucet	In classroom 032	FT-122016-002087-A	< 1	FT-122016-002087-B	< 1
14	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002156	12/23/2016	3	Classroom Faucet	In art room 325 Right	FT-122016-002156-A	< 1	FT-122016-002156-B	< 1
15	WALKER-JONES EDUCATIONAL CAMPUS	WS- 006081	12/23/2016	1	Break Room	In welcome center 114	FT-122016-006081-A	< 1	FT-122016-006081-B	< 1

Greater than 1 ppb - Devices Shut Off and Corrective Action Taken										
1	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002076	12/23/2016	1	Combo Faucet	In classroom 117	FT-122016-002076-A	1	FT-122016-002076-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002076	1/25/2017	1	Combo Faucet	In classroom 117	FT-122016-002076-A	4.2	FT-122016-002076-B	< 1

Second Filter Re-Test (After Device Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002076	4/7/2017	1	Combo Faucet	In classroom 117	FT-122016-002076-A	5.7	FT-122016-002076-B	< 1

Filter Re-Test (Post Consultation; After Dual Supply Faucet Installation)

Less than 5 ppb - Device Returned to Service										
1	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002076	8/11/2017	1	Combo Faucet	In classroom 117	FT-122016-002076-A	< 1	FT-122016-002076-B	< 1