



# Walker Jones Education Campus Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002051	6/8/2020	6/8/2021	1	Ice Maker	In kitchen (ice maker)	WF-06082020-002051	3/16/2021	FT-FY21-032021-002051-A	<1	FT-FY21-032021-002051-B	<1	
WS-002055	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 104	WF-06082020-002055	3/16/2021	FT-FY21-032021-002055-A	<1	FT-FY21-032021-002055-B	<1	
WS-002056	10/5/2020	10/5/2021	1	Combo Faucet	In classroom 104	WF-10052020-002056	3/16/2021	FT-FY21-032021-002056-A	<1	FT-FY21-032021-002056-B	<1	
WS-002057	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 103	WF-06082020-002057	3/16/2021	FT-FY21-032021-002057-A	<1	FT-FY21-032021-002057-B	<1	
WS-002058	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 105	WF-06082020-002058	3/16/2021	FT-FY21-032021-002058-A	<1	FT-FY21-032021-002058-B	<1	
WS-002059	10/5/2020	10/5/2021	1	Combo Faucet	In classroom 105	WF-10052020-002059	3/16/2021	FT-FY21-032021-002059-A	<1	FT-FY21-032021-002059-B	<1	
WS-002060	10/5/2020	10/5/2021	1	Combo Faucet	In classroom 103	WF-10052020-002060	3/16/2021	FT-FY21-032021-002060-A	1.4	FT-FY21-032021-002060-B	<1	
WS-002061	10/5/2020	10/5/2021	1	Combo Faucet	In classroom 106	WF-10052020-002061	3/16/2021	FT-FY21-032021-002061-A	<1	FT-FY21-032021-002061-B	<1	
WS-002062	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 106	WF-06082020-002062	3/16/2021	FT-FY21-032021-002062-A	<1	FT-FY21-032021-002062-B	<1	
WS-002063	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 108	WF-06082020-002063	3/16/2021	FT-FY21-032021-002063-A	<1	FT-FY21-032021-002063-B	<1	
WS-002064	10/5/2020	10/5/2021	1	Combo Faucet	In classroom 108	WF-10052020-002064	3/16/2021	FT-FY21-032021-002064-A	<1	FT-FY21-032021-002064-B	<1	
WS-002065	6/8/2020	6/8/2021	1	Cooler	In hallway adjacent to restroom 111	High Left	WF-06082020-002065	3/16/2021	FT-FY21-032021-002065-A	<1	FT-FY21-032021-002065-B	<1
WS-002066	6/8/2020	6/8/2021	1	Cooler	In hallway adjacent to restroom 111	Low Right	WF-06082020-002066	3/16/2021	FT-FY21-032021-002066-A	<1	FT-FY21-032021-002066-B	<1
WS-002067	6/8/2020	6/8/2021	1	Combo Fountain	In staff lounge 112		WF-06082020-002067	3/16/2021	FT-FY21-032021-002067-A	<1	FT-FY21-032021-002067-B	<1
WS-002068	6/8/2020	6/8/2021	1	Break Room	In staff lounge 112		WF-06082020-002068	3/16/2021	FT-FY21-032021-002068-A	<1	FT-FY21-032021-002068-B	<1
WS-002069	10/5/2020	10/5/2021	1	Combo Faucet	In classroom 115		WF-10052020-002069	3/16/2021	FT-FY21-032021-002069-A	<1	FT-FY21-032021-002069-B	<1
WS-002070	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 115		WF-06082020-002070	3/16/2021	FT-FY21-032021-002070-A	<1	FT-FY21-032021-002070-B	<1
WS-002071	10/5/2020	10/5/2021	1	Combo Faucet	In classroom 120		WF-10052020-002071	3/16/2021	FT-FY21-032021-002071-A	<1	FT-FY21-032021-002071-B	<1
WS-002072	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 120	Right	WF-06082020-002072	3/16/2021	FT-FY21-032021-002072-A	<1	FT-FY21-032021-002072-B	<1
WS-002073	10/5/2020	10/5/2021	1	Combo Faucet	In classroom 122		WF-10052020-002073	3/16/2021	FT-FY21-032021-002073-A	<1	FT-FY21-032021-002073-B	<1
WS-002074	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 122		WF-06082020-002074	3/16/2021	FT-FY21-032021-002074-A	<1	FT-FY21-032021-002074-B	<1
WS-002075	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 117		WF-06082020-002075	3/16/2021	FT-FY21-032021-002075-A	<1	FT-FY21-032021-002075-B	<1
WS-002076	10/5/2020	10/5/2021	1	Combo Faucet	In classroom 117		WF-10052020-002076	3/16/2021	FT-FY21-032021-002076-A	<1	FT-FY21-032021-002076-B	<1
WS-002077	10/5/2020	10/5/2021	1	Combo Faucet	In classroom 119		WF-10052020-002077	3/16/2021	FT-FY21-032021-002077-A	<1	FT-FY21-032021-002077-B	<1
WS-002078	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 119		WF-06082020-002078	3/16/2021	FT-FY21-032021-002078-A	<1	FT-FY21-032021-002078-B	<1
WS-002079	10/5/2020	10/5/2021	1	Combo Faucet	In classroom 128		WF-10052020-002079	3/16/2021	FT-FY21-032021-002079-A	<1	FT-FY21-032021-002079-B	<1
WS-002080	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 128		WF-06082020-002080	3/16/2021	FT-FY21-032021-002080-A	<1	FT-FY21-032021-002080-B	<1
WS-002081	6/8/2020	6/8/2021	1	Combo Fountain	In classroom 126		WF-06082020-002081	3/16/2021	FT-FY21-032021-002081-A	<1	FT-FY21-032021-002081-B	<1
WS-002082	10/5/2020	10/5/2021	1	Combo Faucet	In Classroom 126		WF-10052020-002082	3/16/2021	FT-FY21-032021-002082-A	<1	FT-FY21-032021-002082-B	<1
WS-002083	6/8/2020	6/8/2021	1	Combo Fountain	In health suite 123A		WF-06082020-002083	3/16/2021	FT-FY21-032021-002083-A	<1	FT-FY21-032021-002083-B	<1
WS-002084	6/8/2020	6/8/2021	1	Health Suite	In health suite 123A		WF-06082020-002084	3/16/2021	FT-FY21-032021-002084-A	<1	FT-FY21-032021-002084-B	<1
WS-002085	6/8/2020	6/8/2021	Basement	Cooler	In hallway adjacent to room 041	High Left	WF-06082020-002085	3/16/2021	FT-FY21-032021-002085-A	<1	FT-FY21-032021-002085-B	<1

WS-002086	6/8/2020	6/8/2021	Basement	Cooler	In hallway adjacent to room 041	Low	Right	WF-06082020-002086	3/16/2021	FT-FY21-032021-002086-A	<1	FT-FY21-032021-002086-B	<1
WS-002087	10/5/2020	10/5/2021	Basement	Combo Faucet	In classroom 032			WF-10052020-002087	3/16/2021	FT-FY21-032021-002087-A	<1	FT-FY21-032021-002087-B	<1
WS-002088	6/8/2020	6/8/2021	Basement	Combo Fountain	In classroom 032			WF-06082020-002088	3/16/2021	FT-FY21-032021-002088-A	<1	FT-FY21-032021-002088-B	<1
WS-002089	6/8/2020	6/8/2021	Basement	Combo Fountain	In classroom 034			WF-06082020-002089	3/16/2021	FT-FY21-032021-002089-A	<1	FT-FY21-032021-002089-B	<1
WS-002092	6/8/2020	6/8/2021	Basement	Combo Fountain	In classroom 036			WF-06082020-002092	3/16/2021	FT-FY21-032021-002092-A	<1	FT-FY21-032021-002092-B	<1
WS-002093	6/8/2020	6/8/2021	Basement	Combo Fountain	In athletics training room 043			WF-06082020-002093	3/16/2021	FT-FY21-032021-002093-A	2.1	FT-FY21-032021-002093-B	1.4
WS-002095	6/8/2020	6/8/2021	2	Combo Fountain	In library 230C			WF-06082020-002095	3/16/2021	FT-FY21-032021-002095-A	<1	FT-FY21-032021-002095-B	<1
WS-002097	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 227			WF-06082020-002097	3/16/2021	FT-FY21-032021-002097-A	<1	FT-FY21-032021-002097-B	<1
WS-002100	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 228			WF-06082020-002100	3/16/2021	FT-FY21-032021-002100-A	<1	FT-FY21-032021-002100-B	<1
WS-002101	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 226			WF-06082020-002101	3/16/2021	FT-FY21-032021-002101-A	<1	FT-FY21-032021-002101-B	<1
WS-002103	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 221			WF-06082020-002103	3/16/2021	FT-FY21-032021-002103-A	<1	FT-FY21-032021-002103-B	<1
WS-002106	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 224			WF-06082020-002106	3/16/2021	FT-FY21-032021-002106-A	<1	FT-FY21-032021-002106-B	<1
WS-002107	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 219			WF-06082020-002107	3/16/2021	FT-FY21-032021-002107-A	<1	FT-FY21-032021-002107-B	<1
WS-002110	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 222			WF-06082020-002110	3/16/2021	FT-FY21-032021-002110-A	<1	FT-FY21-032021-002110-B	<1
WS-002111	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 217			WF-06082020-002111	3/16/2021	FT-FY21-032021-002111-A	<1	FT-FY21-032021-002111-B	<1
WS-002113	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 220			WF-06082020-002113	3/16/2021	FT-FY21-032021-002113-A	<1	FT-FY21-032021-002113-B	<1
WS-002115	6/8/2020	6/8/2021	2	Cooler	In hallway across from room 212	High	Left	WF-06082020-002115	3/16/2021	FT-FY21-032021-002115-A	<1	FT-FY21-032021-002115-B	<1
WS-002116	6/8/2020	6/8/2021	2	Cooler	In hallway across from room 212	Low	Right	WF-06082020-002116	3/16/2021	FT-FY21-032021-002116-A	<1	FT-FY21-032021-002116-B	<1
WS-002117	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 212		Right	WF-06082020-002117	3/16/2021	FT-FY21-032021-002117-A	1.2	FT-FY21-032021-002117-B	<1
WS-002119	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 205		Right	WF-06082020-002119	3/16/2021	FT-FY21-032021-002119-A	<1	FT-FY21-032021-002119-B	<1
WS-002121	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 210		Right	WF-06082020-002121	3/16/2021	FT-FY21-032021-002121-A	<1	FT-FY21-032021-002121-B	<1
WS-002123	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 203			WF-06082020-002123	3/16/2021	FT-FY21-032021-002123-A	<1	FT-FY21-032021-002123-B	<1
WS-002125	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 208		Right	WF-06082020-002125	3/16/2021	FT-FY21-032021-002125-A	<1	FT-FY21-032021-002125-B	<1
WS-002127	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 201			WF-06082020-002127	3/16/2021	FT-FY21-032021-002127-A	<1	FT-FY21-032021-002127-B	<1
WS-002130	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 206			WF-06082020-002130	3/16/2021	FT-FY21-032021-002130-A	<1	FT-FY21-032021-002130-B	<1
WS-002131	6/8/2020	6/8/2021	3	Cooler	In hallway across from room 312 (Early Stages)	High	Left	WF-06082020-002131	3/16/2021	FT-FY21-032021-002131-A	<1	FT-FY21-032021-002131-B	<1
WS-002132	6/8/2020	6/8/2021	3	Cooler	In hallway across from room 312 (Early Stages)	Low	Right	WF-06082020-002132	3/16/2021	FT-FY21-032021-002132-A	<1	FT-FY21-032021-002132-B	<1
WS-002133	6/8/2020	6/8/2021	3	Combo Fountain	In staff lounge 300 (Early Stages)			WF-06082020-002133	3/16/2021	FT-FY21-032021-002133-A	<1	FT-FY21-032021-002133-B	<1
WS-002135	6/8/2020	6/8/2021	3	Combo Fountain	In classroom 310 first clockwise from entry door (Early Stag		Right	WF-06082020-002135	3/16/2021	FT-FY21-032021-002135-A	2.8	FT-FY21-032021-002135-B	<1
WS-002137	6/8/2020	6/8/2021	3	Combo Fountain	In classroom 310 second clockwise from entry door (Early S		Right	WF-06082020-002137	3/16/2021	FT-FY21-032021-002137-A	<1	FT-FY21-032021-002137-B	<1
WS-002140	6/8/2020	6/8/2021	3	Combo Fountain	In classroom 310 third clockwise from entry door (Early Sta		Right	WF-06082020-002140	3/16/2021	FT-FY21-032021-002140-A	<1	FT-FY21-032021-002140-B	<1
WS-002141	6/8/2020	6/8/2021	3	Combo Fountain	In science lab room 320 first clockwise from north entry door			WF-06082020-002141	3/16/2021	FT-FY21-032021-002141-A	<1	FT-FY21-032021-002141-B	<1
WS-002143	6/8/2020	6/8/2021	3	Combo Fountain	In science lab room 320 second clockwise from north entry door			WF-06082020-002143	3/16/2021	FT-FY21-032021-002143-A	<1	FT-FY21-032021-002143-B	<1
WS-002146	6/8/2020	6/8/2021	3	Combo Fountain	In science lab room 320 third clockwise from north entry door			WF-06082020-002146	3/16/2021	FT-FY21-032021-002146-A	1.6	FT-FY21-032021-002146-B	<1
WS-002148	6/8/2020	6/8/2021	3	Combo Fountain	In science lab room 320 fourth clockwise from north entry door			WF-06082020-002148	3/16/2021	FT-FY21-032021-002148-A	3.4	FT-FY21-032021-002148-B	<1
WS-002149	6/8/2020	6/8/2021	3	Combo Fountain	In science lab room 324 first clockwise from north entry door			WF-06082020-002149	3/16/2021	FT-FY21-032021-002149-A	<1	FT-FY21-032021-002149-B	<1
WS-002151	6/8/2020	6/8/2021	3	Combo Fountain	In science lab room 324 second clockwise from north entry door			WF-06082020-002151	3/16/2021	FT-FY21-032021-002151-A	<1	FT-FY21-032021-002151-B	<1
WS-002153	6/8/2020	6/8/2021	3	Combo Fountain	In science lab room 324 third clockwise from north entry door			WF-06082020-002153	3/16/2021	FT-FY21-032021-002153-A	<1	FT-FY21-032021-002153-B	<1

WS- 002156	10/5/2020	10/5/2021	3	Classroom Faucet	In art room 325	Right	WF-10052020-002156	3/16/2021	FT-FY21-032021-002156-A	<1	FT-FY21-032021-002156-B	<1
WS- 006081	6/8/2020	6/8/2021	1	Break Room	In welcome center 114		WF-06082020-006081	3/16/2021	FT-FY21-032021-006081-A	<1	FT-FY21-032021-006081-B	<1
WS- 006082	6/8/2020	6/8/2021	1	Combo Fountain	In welcome center 114		WF-06082020-006082	3/16/2021	FT-FY21-032021-006082-A	<1	FT-FY21-032021-006082-B	<1
WS- 006084	6/8/2020	6/8/2021	2	Combo Fountain	In classroom 227		WF-06082020-006084	3/16/2021	FT-FY21-032021-006084-A	<1	FT-FY21-032021-006084-B	<1
WS- 006085	6/8/2020	6/8/2021	2	Combo Fountain	In conference room 214B		WF-06082020-006085	3/16/2021	FT-FY21-032021-006085-A	<1	FT-FY21-032021-006085-B	<1
WS- 006086	6/8/2020	6/8/2021	2	Combo Fountain	In conference room 214A		WF-06082020-006086	3/16/2021	FT-FY21-032021-006086-A	<1	FT-FY21-032021-006086-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002050	2/17/2021	2/17/2022	1	Food Prep Sink	In kitchen first clockwise from entry door	WF-02172021-002050	3/16/2021	FT-FY21-032021-002050-A	<1	FT-FY21-032021-002050-B	<1

### FY21 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002155	6/8/2020	6/8/2021	3	Combo Fountain	In science lab room 320A	WF-06082020-002155	3/16/2021	FT-FY21-032021-002155-A	5.5	FT-FY21-032021-002155-B	1.2