



Walker-Jones EC Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002051	4/22/2019	4/22/2020	1	Ice Maker	In kitchen (ice maker)	WF-04222019-002051	11/13/2019	FT-FY20-112019-002051-A	<1	FT-FY20-112019-002051-B	<1	
WS-002055	4/22/2019	4/22/2020	1	Combo Fountain	In classroom 104	WF-04222019-002055	11/13/2019	FT-FY20-112019-002055-A	<1	FT-FY20-112019-002055-B	<1	
WS-002056	10/17/2019	10/17/2020	1	Combo Faucet	In classroom 104	WF-10172019-002056	11/13/2019	FT-FY20-112019-002056-A	<1	FT-FY20-112019-002056-B	<1	
WS-002057	4/22/2019	4/22/2020	1	Combo Fountain	In classroom 103	WF-04222019-002057	11/13/2019	FT-FY20-112019-002057-A	<1	FT-FY20-112019-002057-B	<1	
WS-002058	4/22/2019	4/22/2020	1	Combo Fountain	In classroom 105	WF-04222019-002058	11/13/2019	FT-FY20-112019-002058-A	<1	FT-FY20-112019-002058-B	<1	
WS-002059	10/17/2019	10/17/2020	1	Combo Faucet	In classroom 105	WF-10172019-002059	11/13/2019	FT-FY20-112019-002059-A	1	FT-FY20-112019-002059-B	<1	
WS-002060	10/17/2019	10/17/2020	1	Combo Faucet	In classroom 103	WF-10172019-002060	11/13/2019	FT-FY20-112019-002060-A	4.8	FT-FY20-112019-002060-B	<1	
WS-002061	10/17/2019	10/17/2020	1	Combo Faucet	In classroom 106	WF-10172019-002061	11/13/2019	FT-FY20-112019-002061-A	1.5	FT-FY20-112019-002061-B	<1	
WS-002062	4/22/2019	4/22/2020	1	Combo Fountain	In classroom 106	WF-04222019-002062	11/13/2019	FT-FY20-112019-002062-A	<1	FT-FY20-112019-002062-B	<1	
WS-002063	4/22/2019	4/22/2020	1	Combo Fountain	In classroom 108	WF-04222019-002063	11/13/2019	FT-FY20-112019-002063-A	<1	FT-FY20-112019-002063-B	<1	
WS-002064	10/17/2019	10/17/2020	1	Combo Faucet	In classroom 108	WF-10172019-002064	11/13/2019	FT-FY20-112019-002064-A	<1	FT-FY20-112019-002064-B	<1	
WS-002065	4/22/2019	4/22/2020	1	Cooler	In hallway adjacent to restroom 111	High Left	WF-04222019-002065	11/13/2019	FT-FY20-112019-002065-A	<1	FT-FY20-112019-002065-B	<1
WS-002066	4/22/2019	4/22/2020	1	Cooler	In hallway adjacent to restroom 111	Low Right	WF-04222019-002066	11/13/2019	FT-FY20-112019-002066-A	<1	FT-FY20-112019-002066-B	<1
WS-002067	4/22/2019	4/22/2020	1	Combo Fountain	In staff lounge 112	WF-04222019-002067	11/13/2019	FT-FY20-112019-002067-A	<1	FT-FY20-112019-002067-B	<1	
WS-002068	4/22/2019	4/22/2020	1	Break Room	In staff lounge 112	WF-04222019-002068	11/13/2019	FT-FY20-112019-002068-A	<1	FT-FY20-112019-002068-B	<1	
WS-002069	10/17/2019	10/17/2020	1	Combo Faucet	In classroom 115	WF-10172019-002069	11/13/2019	FT-FY20-112019-002069-A	<1	FT-FY20-112019-002069-B	<1	
WS-002070	4/22/2019	4/22/2020	1	Combo Fountain	In classroom 115	WF-04222019-002070	11/13/2019	FT-FY20-112019-002070-A	<1	FT-FY20-112019-002070-B	<1	
WS-002071	10/17/2019	10/17/2020	1	Combo Faucet	In classroom 120	WF-10172019-002071	11/13/2019	FT-FY20-112019-002071-A	2.5	FT-FY20-112019-002071-B	<1	
WS-002072	4/22/2019	4/22/2020	1	Combo Fountain	In classroom 120	Right	WF-04222019-002072	11/13/2019	FT-FY20-112019-002072-A	<1	FT-FY20-112019-002072-B	<1
WS-002073	10/17/2019	10/17/2020	1	Combo Faucet	In classroom 122	WF-10172019-002073	11/13/2019	FT-FY20-112019-002073-A	<1	FT-FY20-112019-002073-B	<1	
WS-002074	4/22/2019	4/22/2020	1	Combo Fountain	In classroom 122	WF-04222019-002074	11/13/2019	FT-FY20-112019-002074-A	<1	FT-FY20-112019-002074-B	<1	
WS-002075	4/22/2019	4/22/2020	1	Combo Fountain	In classroom 117	WF-04222019-002075	11/13/2019	FT-FY20-112019-002075-A	<1	FT-FY20-112019-002075-B	<1	
WS-002076	10/17/2019	10/17/2020	1	Combo Faucet	In classroom 117	WF-10172019-002076	11/13/2019	FT-FY20-112019-002076-A	<1	FT-FY20-112019-002076-B	<1	
WS-002077	10/17/2019	10/17/2020	1	Combo Faucet	In classroom 119	WF-10172019-002077	11/13/2019	FT-FY20-112019-002077-A	3.7	FT-FY20-112019-002077-B	<1	
WS-002078	4/22/2019	4/22/2020	1	Combo Fountain	In classroom 119	WF-04222019-002078	11/13/2019	FT-FY20-112019-002078-A	2.8	FT-FY20-112019-002078-B	1.6	
WS-002079	10/17/2019	10/17/2020	1	Combo Faucet	In classroom 128	WF-10172019-002079	11/13/2019	FT-FY20-112019-002079-A	2.9	FT-FY20-112019-002079-B	<1	
WS-002080	4/22/2019	4/22/2020	1	Combo Fountain	In classroom 128	WF-04222019-002080	11/13/2019	FT-FY20-112019-002080-A	<1	FT-FY20-112019-002080-B	<1	
WS-002081	4/22/2019	4/22/2020	1	Combo Fountain	In classroom 126	WF-04222019-002081	11/13/2019	FT-FY20-112019-002081-A	<1	FT-FY20-112019-002081-B	<1	
WS-002082	10/17/2019	10/17/2020	1	Combo Faucet	In Classroom 126	WF-10172019-002082	11/13/2019	FT-FY20-112019-002082-A	1.6	FT-FY20-112019-002082-B	<1	
WS-002083	4/22/2019	4/22/2020	1	Combo Fountain	In health suite 123A	WF-04222019-002083	11/13/2019	FT-FY20-112019-002083-A	1.2	FT-FY20-112019-002083-B	<1	
WS-002084	4/22/2019	4/22/2020	1	Health Suite	In health suite 123A	WF-04222019-002084	11/13/2019	FT-FY20-112019-002084-A	<1	FT-FY20-112019-002084-B	<1	
WS-002087	10/17/2019	10/17/2020	Basement	Combo Faucet	In classroom 032	WF-10172019-002087	11/13/2019	FT-FY20-112019-002087-A	1.9	FT-FY20-112019-002087-B	<1	
WS-002088	4/22/2019	4/22/2020	Basement	Combo Fountain	In classroom 032	WF-04222019-002088	11/13/2019	FT-FY20-112019-002088-A	<1	FT-FY20-112019-002088-B	<1	
WS-002089	4/22/2019	4/22/2020	Basement	Combo Fountain	In classroom 034	WF-04222019-002089	11/13/2019	FT-FY20-112019-002089-A	<1	FT-FY20-112019-002089-B	<1	
WS-002092	4/22/2019	4/22/2020	Basement	Combo Fountain	In classroom 036	WF-04222019-002092	11/13/2019	FT-FY20-112019-002092-A	<1	FT-FY20-112019-002092-B	<1	
WS-002093	4/22/2019	4/22/2020	Basement	Combo Fountain	In athletics training room 043	WF-04222019-002093	11/13/2019	FT-FY20-112019-002093-A	2.8	FT-FY20-112019-002093-B	<1	
WS-002095	4/22/2019	4/22/2020	2	Combo Fountain	In library 230C	WF-04222019-002095	11/13/2019	FT-FY20-112019-002095-A	<1	FT-FY20-112019-002095-B	<1	
WS-002097	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 227	WF-04222019-002097	11/13/2019	FT-FY20-112019-002097-A	<1	FT-FY20-112019-002097-B	<1	

WS-002100	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 228		WF-04222019-002100	11/13/2019	FT-FY20-112019-002100-A	2.5	FT-FY20-112019-002100-B	<1
WS-002101	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 226		WF-04222019-002101	11/13/2019	FT-FY20-112019-002101-A	<1	FT-FY20-112019-002101-B	<1
WS-002103	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 221		WF-04222019-002103	11/13/2019	FT-FY20-112019-002103-A	<1	FT-FY20-112019-002103-B	<1
WS-002106	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 224		WF-04222019-002106	11/13/2019	FT-FY20-112019-002106-A	<1	FT-FY20-112019-002106-B	<1
WS-002107	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 219		WF-04222019-002107	11/13/2019	FT-FY20-112019-002107-A	<1	FT-FY20-112019-002107-B	<1
WS-002110	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 222		WF-04222019-002110	11/13/2019	FT-FY20-112019-002110-A	<1	FT-FY20-112019-002110-B	<1
WS-002111	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 217		WF-04222019-002111	11/13/2019	FT-FY20-112019-002111-A	<1	FT-FY20-112019-002111-B	<1
WS-002113	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 220		WF-04222019-002113	11/13/2019	FT-FY20-112019-002113-A	<1	FT-FY20-112019-002113-B	<1
WS-002115	4/22/2019	4/22/2020	2	Cooler	In hallway across from room 212	High Left	WF-04222019-002115	11/13/2019	FT-FY20-112019-002115-A	<1	FT-FY20-112019-002115-B	<1
WS-002116	4/22/2019	4/22/2020	2	Cooler	In hallway across from room 212	Low Right	WF-04222019-002116	11/13/2019	FT-FY20-112019-002116-A	<1	FT-FY20-112019-002116-B	<1
WS-002117	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 212	Right	WF-04222019-002117	11/13/2019	FT-FY20-112019-002117-A	<1	FT-FY20-112019-002117-B	<1
WS-002119	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 205	Right	WF-04222019-002119	11/13/2019	FT-FY20-112019-002119-A	<1	FT-FY20-112019-002119-B	<1
WS-002121	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 210	Right	WF-04222019-002121	11/13/2019	FT-FY20-112019-002121-A	<1	FT-FY20-112019-002121-B	<1
WS-002123	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 203		WF-04222019-002123	11/13/2019	FT-FY20-112019-002123-A	<1	FT-FY20-112019-002123-B	<1
WS-002125	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 208	Right	WF-04222019-002125	11/13/2019	FT-FY20-112019-002125-A	<1	FT-FY20-112019-002125-B	<1
WS-002127	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 201		WF-04222019-002127	11/13/2019	FT-FY20-112019-002127-A	<1	FT-FY20-112019-002127-B	<1
WS-002130	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 206		WF-04222019-002130	11/13/2019	FT-FY20-112019-002130-A	<1	FT-FY20-112019-002130-B	<1
WS-002131	4/22/2019	4/22/2020	3	Cooler	In hallway across from room 312 (Early Stages)	High Left	WF-04222019-002131	11/13/2019	FT-FY20-112019-002131-A	<1	FT-FY20-112019-002131-B	<1
WS-002132	4/22/2019	4/22/2020	3	Cooler	In hallway across from room 312 (Early Stages)	Low Right	WF-04222019-002132	11/13/2019	FT-FY20-112019-002132-A	<1	FT-FY20-112019-002132-B	<1
WS-002133	4/22/2019	4/22/2020	3	Combo Fountain	In staff lounge 300 (Early Stages)		WF-04222019-002133	11/13/2019	FT-FY20-112019-002133-A	<1	FT-FY20-112019-002133-B	<1
WS-002135	4/22/2019	4/22/2020	3	Combo Fountain	In classroom 310 first clockwise from entry door (Early Stages)	Right	WF-04222019-002135	11/13/2019	FT-FY20-112019-002135-A	3.2	FT-FY20-112019-002135-B	<1
WS-002137	4/22/2019	4/22/2020	3	Combo Fountain	In classroom 310 second clockwise from entry door (Early Stages)	Right	WF-04222019-002137	11/13/2019	FT-FY20-112019-002137-A	2.5	FT-FY20-112019-002137-B	<1
WS-002140	4/22/2019	4/22/2020	3	Combo Fountain	In classroom 310 third clockwise from entry door (Early Stages)	Right	WF-04222019-002140	11/13/2019	FT-FY20-112019-002140-A	2.3	FT-FY20-112019-002140-B	<1
WS-002141	4/22/2019	4/22/2020	3	Combo Fountain	In science lab room 320 first clockwise from north entry door		WF-04222019-002141	11/13/2019	FT-FY20-112019-002141-A	<1	FT-FY20-112019-002141-B	<1
WS-002143	4/22/2019	4/22/2020	3	Combo Fountain	In science lab room 320 second clockwise from north entry door		WF-04222019-002143	11/13/2019	FT-FY20-112019-002143-A	<1	FT-FY20-112019-002143-B	<1
WS-002146	4/22/2019	4/22/2020	3	Combo Fountain	In science lab room 320 third clockwise from north entry door		WF-04222019-002146	11/13/2019	FT-FY20-112019-002146-A	<1	FT-FY20-112019-002146-B	<1
WS-002148	4/22/2019	4/22/2020	3	Combo Fountain	In science lab room 320 fourth clockwise from north entry door		WF-04222019-002148	11/13/2019	FT-FY20-112019-002148-A	<1	FT-FY20-112019-002148-B	<1
WS-002149	4/22/2019	4/22/2020	3	Combo Fountain	In science lab room 324 first clockwise from north entry door		WF-04222019-002149	11/13/2019	FT-FY20-112019-002149-A	<1	FT-FY20-112019-002149-B	<1
WS-002151	4/22/2019	4/22/2020	3	Combo Fountain	In science lab room 324 second clockwise from north entry door		WF-04222019-002151	11/13/2019	FT-FY20-112019-002151-A	<1	FT-FY20-112019-002151-B	<1
WS-002153	4/22/2019	4/22/2020	3	Combo Fountain	In science lab room 324 third clockwise from north entry door		WF-04222019-002153	11/13/2019	FT-FY20-112019-002153-A	<1	FT-FY20-112019-002153-B	<1
WS-002155	4/22/2019	4/22/2020	3	Combo Fountain	In science lab room 320A		WF-04222019-002155	11/13/2019	FT-FY20-112019-002155-A	4.1	FT-FY20-112019-002155-B	<1
WS-002156	10/17/2019	10/17/2020	3	Classroom Faucet	In art room 325	Right	WF-10172019-002156	11/13/2019	FT-FY20-112019-002156-A	<1	FT-FY20-112019-002156-B	<1
WS-006081	4/22/2019	4/22/2020	1	Break Room	In welcome center 114		WF-04222019-006081	11/13/2019	FT-FY20-112019-006081-A	3.8	FT-FY20-112019-006081-B	<1
WS-006082	4/22/2019	4/22/2020	1	Combo Fountain	In welcome center 114		WF-04222019-006082	11/13/2019	FT-FY20-112019-006082-A	1.9	FT-FY20-112019-006082-B	<1
WS-006084	4/22/2019	4/22/2020	2	Combo Fountain	In classroom 227		WF-04222019-006084	11/13/2019	FT-FY20-112019-006084-A	1.6	FT-FY20-112019-006084-B	<1
WS-006085	4/22/2019	4/22/2020	2	Combo Fountain	In conference room 214B		WF-04222019-006085	11/13/2019	FT-FY20-112019-006085-A	<1	FT-FY20-112019-006085-B	<1
WS-006086	4/22/2019	4/22/2020	2	Combo Fountain	In conference room 214A		WF-04222019-006086	11/13/2019	FT-FY20-112019-006086-A	1.6	FT-FY20-112019-006086-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002050	7/3/2019	7/3/2020	1	Food Prep Sink	In kitchen first clockwise from entry door	WF-07032019-002050	11/13/2019	FT-FY20-112019-002050-A	<1	FT-FY20-112019-002050-B	<1	

FY20 Filter Test

Greater than 5ppb - Devices requiring remediation												
---	--	--	--	--	--	--	--	--	--	--	--	--

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002085	4/22/2019	4/22/2020	Basement	Cooler	In hallway adjacent to room 041	High Left	WF-04222019-002085	11/13/2019	FT-FY20-112019-002085-A	<1	FT-FY20-112019-002085-B	62.7
WS-002086	4/23/2019	4/23/2020	Basement	Cooler	In hallway adjacent to room 041	Low Right	WF-04232019-002086	11/13/2019	FT-FY20-112019-002086-A	76.9	FT-FY20-112019-002086-B	10