



# Walker Jones Education Campus Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

| Record ID  | Filter Installed Date | Filter Expiration Date | Floor    | Device Type    | Device Location                     | Water Filter's Name | Date Analyzed      | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |    |
|------------|-----------------------|------------------------|----------|----------------|-------------------------------------|---------------------|--------------------|-------------------------|----------------------------------|-------------------------|----------------------------------|----|
| WS- 002051 | 6/8/2020              | 6/8/2021               | 1        | Ice Maker      | In kitchen (ice maker)              | WF-06082020-002051  | 3/16/2021          | FT-FY21-032021-002051-A | <1                               | FT-FY21-032021-002051-B | <1                               |    |
| WS- 002055 | 6/8/2020              | 6/8/2021               | 1        | Combo Fountain | In classroom 104                    | WF-06082020-002055  | 3/16/2021          | FT-FY21-032021-002055-A | <1                               | FT-FY21-032021-002055-B | <1                               |    |
| WS- 002056 | 10/5/2020             | 10/5/2021              | 1        | Combo Faucet   | In classroom 104                    | WF-10052020-002056  | 3/16/2021          | FT-FY21-032021-002056-A | <1                               | FT-FY21-032021-002056-B | <1                               |    |
| WS- 002057 | 6/8/2020              | 6/8/2021               | 1        | Combo Fountain | In classroom 103                    | WF-06082020-002057  | 3/16/2021          | FT-FY21-032021-002057-A | <1                               | FT-FY21-032021-002057-B | <1                               |    |
| WS- 002058 | 6/8/2020              | 6/8/2021               | 1        | Combo Fountain | In classroom 105                    | WF-06082020-002058  | 3/16/2021          | FT-FY21-032021-002058-A | <1                               | FT-FY21-032021-002058-B | <1                               |    |
| WS- 002059 | 10/5/2020             | 10/5/2021              | 1        | Combo Faucet   | In classroom 105                    | WF-10052020-002059  | 3/16/2021          | FT-FY21-032021-002059-A | <1                               | FT-FY21-032021-002059-B | <1                               |    |
| WS- 002060 | 10/5/2020             | 10/5/2021              | 1        | Combo Faucet   | In classroom 103                    | WF-10052020-002060  | 3/16/2021          | FT-FY21-032021-002060-A | 1.4                              | FT-FY21-032021-002060-B | <1                               |    |
| WS- 002061 | 10/5/2020             | 10/5/2021              | 1        | Combo Faucet   | In classroom 106                    | WF-10052020-002061  | 3/16/2021          | FT-FY21-032021-002061-A | <1                               | FT-FY21-032021-002061-B | <1                               |    |
| WS- 002062 | 6/8/2020              | 6/8/2021               | 1        | Combo Fountain | In classroom 106                    | WF-06082020-002062  | 3/16/2021          | FT-FY21-032021-002062-A | <1                               | FT-FY21-032021-002062-B | <1                               |    |
| WS- 002063 | 6/8/2020              | 6/8/2021               | 1        | Combo Fountain | In classroom 108                    | WF-06082020-002063  | 3/16/2021          | FT-FY21-032021-002063-A | <1                               | FT-FY21-032021-002063-B | <1                               |    |
| WS- 002064 | 10/5/2020             | 10/5/2021              | 1        | Combo Faucet   | In classroom 108                    | WF-10052020-002064  | 3/16/2021          | FT-FY21-032021-002064-A | <1                               | FT-FY21-032021-002064-B | <1                               |    |
| WS- 002065 | 6/8/2020              | 6/8/2021               | 1        | Cooler         | In hallway adjacent to restroom 111 | High Left           | WF-06082020-002065 | 3/16/2021               | FT-FY21-032021-002065-A          | <1                      | FT-FY21-032021-002065-B          | <1 |
| WS- 002066 | 6/8/2020              | 6/8/2021               | 1        | Cooler         | In hallway adjacent to restroom 111 | Low Right           | WF-06082020-002066 | 3/16/2021               | FT-FY21-032021-002066-A          | <1                      | FT-FY21-032021-002066-B          | <1 |
| WS- 002067 | 6/8/2020              | 6/8/2021               | 1        | Combo Fountain | In staff lounge 112                 | WF-06082020-002067  | 3/16/2021          | FT-FY21-032021-002067-A | <1                               | FT-FY21-032021-002067-B | <1                               |    |
| WS- 002068 | 6/8/2020              | 6/8/2021               | 1        | Break Room     | In staff lounge 112                 | WF-06082020-002068  | 3/16/2021          | FT-FY21-032021-002068-A | <1                               | FT-FY21-032021-002068-B | <1                               |    |
| WS- 002069 | 10/5/2020             | 10/5/2021              | 1        | Combo Faucet   | In classroom 115                    | WF-10052020-002069  | 3/16/2021          | FT-FY21-032021-002069-A | <1                               | FT-FY21-032021-002069-B | <1                               |    |
| WS- 002070 | 6/8/2020              | 6/8/2021               | 1        | Combo Fountain | In classroom 115                    | WF-06082020-002070  | 3/16/2021          | FT-FY21-032021-002070-A | <1                               | FT-FY21-032021-002070-B | <1                               |    |
| WS- 002071 | 10/5/2020             | 10/5/2021              | 1        | Combo Faucet   | In classroom 120                    | WF-10052020-002071  | 3/16/2021          | FT-FY21-032021-002071-A | <1                               | FT-FY21-032021-002071-B | <1                               |    |
| WS- 002072 | 6/8/2020              | 6/8/2021               | 1        | Combo Fountain | In classroom 120                    | Right               | WF-06082020-002072 | 3/16/2021               | FT-FY21-032021-002072-A          | <1                      | FT-FY21-032021-002072-B          | <1 |
| WS- 002073 | 10/5/2020             | 10/5/2021              | 1        | Combo Faucet   | In classroom 122                    | WF-10052020-002073  | 3/16/2021          | FT-FY21-032021-002073-A | <1                               | FT-FY21-032021-002073-B | <1                               |    |
| WS- 002074 | 6/8/2020              | 6/8/2021               | 1        | Combo Fountain | In classroom 122                    | WF-06082020-002074  | 3/16/2021          | FT-FY21-032021-002074-A | <1                               | FT-FY21-032021-002074-B | <1                               |    |
| WS- 002075 | 6/8/2020              | 6/8/2021               | 1        | Combo Fountain | In classroom 117                    | WF-06082020-002075  | 3/16/2021          | FT-FY21-032021-002075-A | <1                               | FT-FY21-032021-002075-B | <1                               |    |
| WS- 002076 | 10/5/2020             | 10/5/2021              | 1        | Combo Faucet   | In classroom 117                    | WF-10052020-002076  | 3/16/2021          | FT-FY21-032021-002076-A | <1                               | FT-FY21-032021-002076-B | <1                               |    |
| WS- 002077 | 10/5/2020             | 10/5/2021              | 1        | Combo Faucet   | In classroom 119                    | WF-10052020-002077  | 3/16/2021          | FT-FY21-032021-002077-A | <1                               | FT-FY21-032021-002077-B | <1                               |    |
| WS- 002078 | 6/8/2020              | 6/8/2021               | 1        | Combo Fountain | In classroom 119                    | WF-06082020-002078  | 3/16/2021          | FT-FY21-032021-002078-A | <1                               | FT-FY21-032021-002078-B | <1                               |    |
| WS- 002079 | 10/5/2020             | 10/5/2021              | 1        | Combo Faucet   | In classroom 128                    | WF-10052020-002079  | 3/16/2021          | FT-FY21-032021-002079-A | <1                               | FT-FY21-032021-002079-B | <1                               |    |
| WS- 002080 | 6/8/2020              | 6/8/2021               | 1        | Combo Fountain | In classroom 128                    | WF-06082020-002080  | 3/16/2021          | FT-FY21-032021-002080-A | <1                               | FT-FY21-032021-002080-B | <1                               |    |
| WS- 002081 | 6/8/2020              | 6/8/2021               | 1        | Combo Fountain | In classroom 126                    | WF-06082020-002081  | 3/16/2021          | FT-FY21-032021-002081-A | <1                               | FT-FY21-032021-002081-B | <1                               |    |
| WS- 002082 | 10/5/2020             | 10/5/2021              | 1        | Combo Faucet   | In Classroom 126                    | WF-10052020-002082  | 3/16/2021          | FT-FY21-032021-002082-A | <1                               | FT-FY21-032021-002082-B | <1                               |    |
| WS- 002083 | 6/8/2020              | 6/8/2021               | 1        | Combo Fountain | In health suite 123A                | WF-06082020-002083  | 3/16/2021          | FT-FY21-032021-002083-A | <1                               | FT-FY21-032021-002083-B | <1                               |    |
| WS- 002084 | 6/8/2020              | 6/8/2021               | 1        | Health Suite   | In health suite 123A                | WF-06082020-002084  | 3/16/2021          | FT-FY21-032021-002084-A | <1                               | FT-FY21-032021-002084-B | <1                               |    |
| WS- 002085 | 6/8/2020              | 6/8/2021               | Basement | Cooler         | In hallway adjacent to room 041     | High Left           | WF-06082020-002085 | 3/16/2021               | FT-FY21-032021-002085-A          | <1                      | FT-FY21-032021-002085-B          | <1 |
| WS- 002086 | 6/8/2020              | 6/8/2021               | Basement | Cooler         | In hallway adjacent to room 041     | Low Right           | WF-06082020-002086 | 3/16/2021               | FT-FY21-032021-002086-A          | <1                      | FT-FY21-032021-002086-B          | <1 |
| WS- 002087 | 10/5/2020             | 10/5/2021              | Basement | Combo Faucet   | In classroom 032                    | WF-10052020-002087  | 3/16/2021          | FT-FY21-032021-002087-A | <1                               | FT-FY21-032021-002087-B | <1                               |    |

|           |           |           |          |                  |  |           |                    |           |                         |     |                         |     |
|-----------|-----------|-----------|----------|------------------|--|-----------|--------------------|-----------|-------------------------|-----|-------------------------|-----|
| WS-002088 | 6/8/2020  | 6/8/2021  | Basement | Combo Fountain   | In classroom 032   |           | WF-06082020-002088 | 3/16/2021 | FT-FY21-032021-002088-A | <1  | FT-FY21-032021-002088-B | <1  |
| WS-002089 | 6/8/2020  | 6/8/2021  | Basement | Combo Fountain   | In classroom 034   |           | WF-06082020-002089 | 3/16/2021 | FT-FY21-032021-002089-A | <1  | FT-FY21-032021-002089-B | <1  |
| WS-002092 | 6/8/2020  | 6/8/2021  | Basement | Combo Fountain   | In classroom 036   |           | WF-06082020-002092 | 3/16/2021 | FT-FY21-032021-002092-A | <1  | FT-FY21-032021-002092-B | <1  |
| WS-002093 | 6/8/2020  | 6/8/2021  | Basement | Combo Fountain   | In athletics training room 043                                 |           | WF-06082020-002093 | 3/16/2021 | FT-FY21-032021-002093-A | 2.1 | FT-FY21-032021-002093-B | 1.4 |
| WS-002095 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In library 230C  |           | WF-06082020-002095 | 3/16/2021 | FT-FY21-032021-002095-A | <1  | FT-FY21-032021-002095-B | <1  |
| WS-002097 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 227   |           | WF-06082020-002097 | 3/16/2021 | FT-FY21-032021-002097-A | <1  | FT-FY21-032021-002097-B | <1  |
| WS-002100 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 228   |           | WF-06082020-002100 | 3/16/2021 | FT-FY21-032021-002100-A | <1  | FT-FY21-032021-002100-B | <1  |
| WS-002101 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 226   |           | WF-06082020-002101 | 3/16/2021 | FT-FY21-032021-002101-A | <1  | FT-FY21-032021-002101-B | <1  |
| WS-002103 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 221   |           | WF-06082020-002103 | 3/16/2021 | FT-FY21-032021-002103-A | <1  | FT-FY21-032021-002103-B | <1  |
| WS-002106 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 224   |           | WF-06082020-002106 | 3/16/2021 | FT-FY21-032021-002106-A | <1  | FT-FY21-032021-002106-B | <1  |
| WS-002107 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 219   |           | WF-06082020-002107 | 3/16/2021 | FT-FY21-032021-002107-A | <1  | FT-FY21-032021-002107-B | <1  |
| WS-002110 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 222   |           | WF-06082020-002110 | 3/16/2021 | FT-FY21-032021-002110-A | <1  | FT-FY21-032021-002110-B | <1  |
| WS-002111 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 217   |           | WF-06082020-002111 | 3/16/2021 | FT-FY21-032021-002111-A | <1  | FT-FY21-032021-002111-B | <1  |
| WS-002113 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 220   |           | WF-06082020-002113 | 3/16/2021 | FT-FY21-032021-002113-A | <1  | FT-FY21-032021-002113-B | <1  |
| WS-002115 | 6/8/2020  | 6/8/2021  | 2        | Cooler           | In hallway across from room 212                                | High Left | WF-06082020-002115 | 3/16/2021 | FT-FY21-032021-002115-A | <1  | FT-FY21-032021-002115-B | <1  |
| WS-002116 | 6/8/2020  | 6/8/2021  | 2        | Cooler           | In hallway across from room 212                                | Low Right | WF-06082020-002116 | 3/16/2021 | FT-FY21-032021-002116-A | <1  | FT-FY21-032021-002116-B | <1  |
| WS-002117 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 212   | Right     | WF-06082020-002117 | 3/16/2021 | FT-FY21-032021-002117-A | 1.2 | FT-FY21-032021-002117-B | <1  |
| WS-002119 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 205   | Right     | WF-06082020-002119 | 3/16/2021 | FT-FY21-032021-002119-A | <1  | FT-FY21-032021-002119-B | <1  |
| WS-002121 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 210   | Right     | WF-06082020-002121 | 3/16/2021 | FT-FY21-032021-002121-A | <1  | FT-FY21-032021-002121-B | <1  |
| WS-002123 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 203   |           | WF-06082020-002123 | 3/16/2021 | FT-FY21-032021-002123-A | <1  | FT-FY21-032021-002123-B | <1  |
| WS-002125 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 208   | Right     | WF-06082020-002125 | 3/16/2021 | FT-FY21-032021-002125-A | <1  | FT-FY21-032021-002125-B | <1  |
| WS-002127 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 201   |           | WF-06082020-002127 | 3/16/2021 | FT-FY21-032021-002127-A | <1  | FT-FY21-032021-002127-B | <1  |
| WS-002130 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 206   |           | WF-06082020-002130 | 3/16/2021 | FT-FY21-032021-002130-A | <1  | FT-FY21-032021-002130-B | <1  |
| WS-002131 | 6/8/2020  | 6/8/2021  | 3        | Cooler           | In hallway across from room 312 (Early Stages)                 | High Left | WF-06082020-002131 | 3/16/2021 | FT-FY21-032021-002131-A | <1  | FT-FY21-032021-002131-B | <1  |
| WS-002132 | 6/8/2020  | 6/8/2021  | 3        | Cooler           | In hallway across from room 312 (Early Stages)                 | Low Right | WF-06082020-002132 | 3/16/2021 | FT-FY21-032021-002132-A | <1  | FT-FY21-032021-002132-B | <1  |
| WS-002133 | 6/8/2020  | 6/8/2021  | 3        | Combo Fountain   | In staff lounge 300 (Early Stages)                             |           | WF-06082020-002133 | 3/16/2021 | FT-FY21-032021-002133-A | <1  | FT-FY21-032021-002133-B | <1  |
| WS-002135 | 6/8/2020  | 6/8/2021  | 3        | Combo Fountain   | In classroom 310 first clockwise from entry door (Early Sta    | Right     | WF-06082020-002135 | 3/16/2021 | FT-FY21-032021-002135-A | 2.8 | FT-FY21-032021-002135-B | <1  |
| WS-002137 | 6/8/2020  | 6/8/2021  | 3        | Combo Fountain   | In classroom 310 second clockwise from entry door (Early Sta   | Right     | WF-06082020-002137 | 3/16/2021 | FT-FY21-032021-002137-A | <1  | FT-FY21-032021-002137-B | <1  |
| WS-002140 | 6/8/2020  | 6/8/2021  | 3        | Combo Fountain   | In classroom 310 third clockwise from entry door (Early Sta    | Right     | WF-06082020-002140 | 3/16/2021 | FT-FY21-032021-002140-A | <1  | FT-FY21-032021-002140-B | <1  |
| WS-002141 | 6/8/2020  | 6/8/2021  | 3        | Combo Fountain   | In science lab room 320 first clockwise from north entry door  |           | WF-06082020-002141 | 3/16/2021 | FT-FY21-032021-002141-A | <1  | FT-FY21-032021-002141-B | <1  |
| WS-002143 | 6/8/2020  | 6/8/2021  | 3        | Combo Fountain   | In science lab room 320 second clockwise from north entry door |           | WF-06082020-002143 | 3/16/2021 | FT-FY21-032021-002143-A | <1  | FT-FY21-032021-002143-B | <1  |
| WS-002146 | 6/8/2020  | 6/8/2021  | 3        | Combo Fountain   | In science lab room 320 third clockwise from north entry door  |           | WF-06082020-002146 | 3/16/2021 | FT-FY21-032021-002146-A | 1.6 | FT-FY21-032021-002146-B | <1  |
| WS-002148 | 6/8/2020  | 6/8/2021  | 3        | Combo Fountain   | In science lab room 320 fourth clockwise from north entry door |           | WF-06082020-002148 | 3/16/2021 | FT-FY21-032021-002148-A | 3.4 | FT-FY21-032021-002148-B | <1  |
| WS-002149 | 6/8/2020  | 6/8/2021  | 3        | Combo Fountain   | In science lab room 324 first clockwise from north entry door  |           | WF-06082020-002149 | 3/16/2021 | FT-FY21-032021-002149-A | <1  | FT-FY21-032021-002149-B | <1  |
| WS-002151 | 6/8/2020  | 6/8/2021  | 3        | Combo Fountain   | In science lab room 324 second clockwise from north entry door |           | WF-06082020-002151 | 3/16/2021 | FT-FY21-032021-002151-A | <1  | FT-FY21-032021-002151-B | <1  |
| WS-002153 | 6/8/2020  | 6/8/2021  | 3        | Combo Fountain   | In science lab room 324 third clockwise from north entry door  |           | WF-06082020-002153 | 3/16/2021 | FT-FY21-032021-002153-A | <1  | FT-FY21-032021-002153-B | <1  |
| WS-002156 | 10/5/2020 | 10/5/2021 | 3        | Classroom Faucet | In art room 325  | Right     | WF-10052020-002156 | 3/16/2021 | FT-FY21-032021-002156-A | <1  | FT-FY21-032021-002156-B | <1  |
| WS-006081 | 6/8/2020  | 6/8/2021  | 1        | Break Room       | In welcome center 114  |           | WF-06082020-006081 | 3/16/2021 | FT-FY21-032021-006081-A | <1  | FT-FY21-032021-006081-B | <1  |
| WS-006082 | 6/8/2020  | 6/8/2021  | 1        | Combo Fountain   | In welcome center 114  |           | WF-06082020-006082 | 3/16/2021 | FT-FY21-032021-006082-A | <1  | FT-FY21-032021-006082-B | <1  |
| WS-006084 | 6/8/2020  | 6/8/2021  | 2        | Combo Fountain   | In classroom 227   |           | WF-06082020-006084 | 3/16/2021 | FT-FY21-032021-006084-A | <1  | FT-FY21-032021-006084-B | <1  |

|            |          |          |   |                |                         |                    |           |                         |    |                         |    |
|------------|----------|----------|---|----------------|-------------------------|--------------------|-----------|-------------------------|----|-------------------------|----|
| WS- 006085 | 6/8/2020 | 6/8/2021 | 2 | Combo Fountain | In conference room 214B | WF-06082020-006085 | 3/16/2021 | FT-FY21-032021-006085-A | <1 | FT-FY21-032021-006085-B | <1 |
| WS- 006086 | 6/8/2020 | 6/8/2021 | 2 | Combo Fountain | In conference room 214A | WF-06082020-006086 | 3/16/2021 | FT-FY21-032021-006086-A | <1 | FT-FY21-032021-006086-B | <1 |

### Food Prep Sink

| Less than 5ppb - Devices requiring no remediation |                       |                        |       |                |  |                     |               |                         |                                  |                         |                                  |
|---|-----------------------|------------------------|-------|----------------|--|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID   | Filter Installed Date | Filter Expiration Date | Floor | Device Type    | Device Location                            | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
| WS- 002050  | 2/17/2021             | 2/17/2022              | 1     | Food Prep Sink | In kitchen first clockwise from entry door | WF-02172021-002050  | 3/16/2021     | FT-FY21-032021-002050-A | <1                               | FT-FY21-032021-002050-B | <1                               |

### FY21 Filter Test

| Greater than 5ppb - Devices requiring remediation |                       |                        |       |                |                          |                     |               |                         |                                  |                         |                                  |
|---|-----------------------|------------------------|-------|----------------|--------------------------|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID   | Filter Installed Date | Filter Expiration Date | Floor | Device Type    | Device Location          | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
| WS- 002155  | 6/8/2020              | 6/8/2021               | 3     | Combo Fountain | In science lab room 320A | WF-06082020-002155  | 3/16/2021     | FT-FY21-032021-002155-A | 5.5                              | FT-FY21-032021-002155-B | 1.2                              |

### FY21 Filter Test

| Less than 5ppb - Devices requiring no remediation |                       |                        |       |                |                          |                     |               |                         |                                  |                         |                                  |
|---|-----------------------|------------------------|-------|----------------|--------------------------|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| Record ID   | Filter Installed Date | Filter Expiration Date | Floor | Device Type    | Device Location          | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
| WS- 002155  | 3/18/2021             | 3/18/2022              | 3     | Combo Fountain | In science lab room 320A | WF-03182021-002155  | 4/7/2021      | FT-FY21-032021-002155-A | <1                               | FT-FY21-032021-002155-B | <1                               |