



WALKER-JONES EC LEAD WATER TEST RESULTS



| | Building Location: Building Name | RECORD ID | Date Analyzed | Floor | Device Type | Device Location | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) |
|----|----------------------------------|--------------|---------------|----------|----------------|--|-----------------------------|--------------------------------|----------------------|--------------------------------|
| 1 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002050 | 8/15/2016 | 1 | Food Prep Sink | In kitchen first clockwise from entry door | FT-82016-002050-A | < 1 | FT-82016-002050-B | < 1 |
| 2 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002055 | 8/15/2016 | 1 | Fountain | In classroom 104 | FT-82016-002055-A | < 1 | FT-82016-002055-B | < 1 |
| 3 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002057 | 8/15/2016 | 1 | Fountain | In classroom 103 | FT-82016-002057-A | < 1 | FT-82016-002057-B | < 1 |
| 4 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002058 | 8/15/2016 | 1 | Fountain | In classroom 105 | FT-82016-002058-A | < 1 | FT-82016-002058-B | < 1 |
| 5 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002062 | 8/15/2016 | 1 | Fountain | In classroom 106 | FT-82016-002062-A | < 1 | FT-82016-002062-B | < 1 |
| 6 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002063 | 8/15/2016 | 1 | Fountain | In classroom 108 | FT-82016-002063-A | < 1 | FT-82016-002063-B | < 1 |
| 7 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002065 | 8/15/2016 | 1 | Cooler | In hallway adjacent to restroom 111 | High Left FT-82016-002065-A | < 1 | FT-82016-002065-B | < 1 |
| 8 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002066 | 8/15/2016 | 1 | Cooler | In hallway adjacent to restroom 111 | Low Right FT-82016-002066-A | < 1 | FT-82016-002066-B | < 1 |
| 9 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002067 | 8/15/2016 | 1 | Fountain | In staff lounge 112 | FT-82016-002067-A | 1.4 | FT-82016-002067-B | < 1 |
| 10 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002070 | 8/15/2016 | 1 | Fountain | In classroom 115 | FT-82016-002070-A | < 1 | FT-82016-002070-B | < 1 |
| 11 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002072 | 8/15/2016 | 1 | Fountain | In classroom 120 | Right FT-82016-002072-A | < 1 | FT-82016-002072-B | < 1 |
| 12 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002074 | 8/15/2016 | 1 | Fountain | In classroom 122 | FT-82016-002074-A | < 1 | FT-82016-002074-B | < 1 |
| 13 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002075 | 8/15/2016 | 1 | Fountain | In classroom 117 | FT-82016-002075-A | < 1 | FT-82016-002075-B | < 1 |
| 14 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002078 | 8/15/2016 | 1 | Fountain | In classroom 119 | FT-82016-002078-A | < 1 | FT-82016-002078-B | < 1 |
| 15 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002080 | 8/15/2016 | 1 | Fountain | In classroom 128 | FT-82016-002080-A | < 1 | FT-82016-002080-B | < 1 |
| 16 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002081 | 8/15/2016 | 1 | Fountain | In classroom 126 | FT-82016-002081-A | < 1 | FT-82016-002081-B | < 1 |
| 17 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002083 | 8/15/2016 | 1 | Fountain | In health suite 123A | FT-82016-002083-A | < 1 | FT-82016-002083-B | < 1 |
| 18 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002084 | 8/15/2016 | 1 | Health Suite | In health suite 123A | FT-82016-002084-A | < 1 | FT-82016-002084-B | < 1 |
| 19 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002085 | 8/15/2016 | Basement | Cooler | In hallway adjacent to room 041 | High Left FT-82016-002085-A | < 1 | FT-82016-002085-B | < 1 |
| 20 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002086 | 8/15/2016 | Basement | Cooler | In hallway adjacent to room 041 | Low Right FT-82016-002086-A | < 1 | FT-82016-002086-B | < 1 |
| 21 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002088 | 8/15/2016 | Basement | Fountain | In classroom 032 | FT-82016-002088-A | < 1 | FT-82016-002088-B | < 1 |
| 22 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002089 | 8/15/2016 | Basement | Fountain | In classroom 034 | FT-82016-002089-A | < 1 | FT-82016-002089-B | < 1 |
| 23 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002092 | 8/15/2016 | Basement | Fountain | In classroom 036 | FT-82016-002092-A | < 1 | FT-82016-002092-B | < 1 |
| 24 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002093 | 8/15/2016 | Basement | Fountain | In training room 043 | FT-82016-002093-A | < 1 | FT-82016-002093-B | < 1 |
| 25 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002095 | 8/15/2016 | 2 | Fountain | In library 230C | FT-82016-002095-A | < 1 | FT-82016-002095-B | < 1 |
| 26 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002097 | 8/15/2016 | 2 | Fountain | In classroom 227 | FT-82016-002097-A | < 1 | FT-82016-002097-B | < 1 |
| 27 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002100 | 8/15/2016 | 2 | Fountain | In classroom 228 | FT-82016-002100-A | < 1 | FT-82016-002100-B | < 1 |
| 28 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002101 | 8/15/2016 | 2 | Fountain | In classroom 226 | FT-82016-002101-A | < 1 | FT-82016-002101-B | < 1 |
| 29 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002103 | 8/15/2016 | 2 | Fountain | In classroom 221 | FT-82016-002103-A | < 1 | FT-82016-002103-B | < 1 |
| 30 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002106 | 8/15/2016 | 2 | Fountain | In classroom 224 | FT-82016-002106-A | < 1 | FT-82016-002106-B | < 1 |
| 31 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002107 | 8/15/2016 | 2 | Fountain | In classroom 219 | FT-82016-002107-A | < 1 | FT-82016-002107-B | < 1 |
| 32 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002110 | 8/15/2016 | 2 | Fountain | In classroom 222 | FT-82016-002110-A | < 1 | FT-82016-002110-B | < 1 |
| 33 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002111 | 8/15/2016 | 2 | Fountain | In classroom 217 | FT-82016-002111-A | < 1 | FT-82016-002111-B | < 1 |
| 34 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002113 | 8/15/2016 | 2 | Fountain | In classroom 220 | FT-82016-002113-A | < 1 | FT-82016-002113-B | < 1 |
| 35 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002115 | 8/15/2016 | 2 | Cooler | In hallway across from room 212 | High Left FT-82016-002115-A | < 1 | FT-82016-002115-B | < 1 |
| 36 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002116 | 8/15/2016 | 2 | Cooler | In hallway across from room 212 | Low Right FT-82016-002116-A | < 1 | FT-82016-002116-B | < 1 |
| 37 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002117 | 8/15/2016 | 2 | Fountain | In classroom 212 | Right FT-82016-002117-A | < 1 | FT-82016-002117-B | < 1 |
| 38 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002119 | 8/15/2016 | 2 | Fountain | In classroom 205 | Right FT-82016-002119-A | < 1 | FT-82016-002119-B | < 1 |
| 39 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002121** | 8/15/2016 | 2 | Fountain | In classroom 210 | Right FT-82016-002121-A | 26.9 | FT-82016-002121-B | < 1 |
| | | | 8/20/2016 | | | | Re-test A | < 1 | Re-test B | < 1 |
| 40 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002123 | 8/15/2016 | 2 | Fountain | In classroom 203 | FT-82016-002123-A | < 1 | FT-82016-002123-B | < 1 |
| 41 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002125 | 8/15/2016 | 2 | Fountain | In classroom 208 | Right FT-82016-002125-A | 3.7 | FT-82016-002125-B | < 1 |
| 42 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002127 | 8/15/2016 | 2 | Fountain | In classroom 201 | FT-82016-002127-A | < 1 | FT-82016-002127-B | < 1 |
| 43 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002130 | 8/15/2016 | 2 | Fountain | In classroom 206 | FT-82016-002130-A | < 1 | FT-82016-002130-B | < 1 |
| 44 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002131 | 8/15/2016 | 3 | Cooler | In hallway across from room 312 | High Left FT-82016-002131-A | < 1 | FT-82016-002131-B | < 1 |
| 45 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002132 | 8/15/2016 | 3 | Cooler | In hallway across from room 312 | Low Right FT-82016-002132-A | < 1 | FT-82016-002132-B | < 1 |
| 46 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002133 | 8/15/2016 | 3 | Fountain | In classroom 300 | FT-82016-002133-A | < 1 | FT-82016-002133-B | < 1 |

| | | | | | | | | | | | |
|----|---------------------------------|------------|-----------|---|------------------|--|-------|-------------------|-----|-------------------|-----|
| 47 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002135 | 8/15/2016 | 3 | Fountain | In science lab room 310 first clockwise from entry door | Right | FT-82016-002135-A | < 1 | FT-82016-002135-B | < 1 |
| 48 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002136 | | 3 | Classroom Faucet | In science lab room 310 first clockwise from entry door | Left | FT-82016-002136-A | | FT-82016-002136-B | |
| 49 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002137 | 8/15/2016 | 3 | Fountain | In science lab room 310 second clockwise from entry door | Right | FT-82016-002137-A | < 1 | FT-82016-002137-B | < 1 |
| 50 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002140 | 8/15/2016 | 3 | Fountain | In science lab room 310 third clockwise from entry door | Right | FT-82016-002140-A | < 1 | FT-82016-002140-B | < 1 |
| 51 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002141 | 8/15/2016 | 3 | Fountain | In science lab room 320 first clockwise from north entry door | | FT-82016-002141-A | < 1 | FT-82016-002141-B | < 1 |
| 52 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002143 | 8/15/2016 | 3 | Fountain | In science lab room 320 second clockwise from north entry door | | FT-82016-002143-A | < 1 | FT-82016-002143-B | < 1 |
| 53 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002146 | 8/15/2016 | 3 | Fountain | In science lab room 320 third clockwise from north entry door | | FT-82016-002146-A | < 1 | FT-82016-002146-B | < 1 |
| 54 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002148 | 8/15/2016 | 3 | Fountain | In science lab room 320 fourth clockwise from north entry door | | FT-82016-002148-A | < 1 | FT-82016-002148-B | < 1 |
| 55 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002149 | 8/15/2016 | 3 | Fountain | In science lab room 324 first clockwise from north entry door | | FT-82016-002149-A | < 1 | FT-82016-002149-B | < 1 |
| 56 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002151 | 8/15/2016 | 3 | Fountain | In science lab room 324 second clockwise from north entry door | | FT-82016-002151-A | < 1 | FT-82016-002151-B | < 1 |
| 57 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002153 | 8/15/2016 | 3 | Fountain | In science lab room 324 third clockwise from north entry door | | FT-82016-002153-A | < 1 | FT-82016-002153-B | < 1 |
| 58 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 002155 | 8/15/2016 | 3 | Fountain | In science lab room 320A | | FT-82016-002155-A | < 1 | FT-82016-002155-B | < 1 |
| 59 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 006082 | 8/15/2016 | 1 | Fountain | In welcome center 115 | | FT-82016-006082-A | < 1 | FT-82016-006082-B | < 1 |
| 60 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 006084 | 8/15/2016 | 2 | Fountain | In classroom 227 | | FT-82016-006084-A | < 1 | FT-82016-006084-B | < 1 |
| 61 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 006085 | 8/15/2016 | 2 | Classroom Faucet | In conference room 214A | | FT-82016-006085-A | < 1 | FT-82016-006085-B | < 1 |
| 62 | WALKER-JONES EDUCATIONAL CAMPUS | WS- 006086 | 8/15/2016 | 2 | Fountain | In conference room 214A | | FT-82016-006086-A | < 1 | FT-82016-006086-B | < 1 |

**Filter inspected, found improperly installed, repaired, and re-sampled.