



# WALKER-JONES EC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	WALKER-JONES EDUCATIONAL CAMPUS	WS-002050	8/15/2016	1	Food Prep Sink	In kitchen first clockwise from entry door	FT-82016-002050-A	< 1	FT-82016-002050-B	< 1
2	WALKER-JONES EDUCATIONAL CAMPUS	WS-002055	8/15/2016	1	Fountain	In classroom 104	FT-82016-002055-A	< 1	FT-82016-002055-B	< 1
3	WALKER-JONES EDUCATIONAL CAMPUS	WS-002057	8/15/2016	1	Fountain	In classroom 103	FT-82016-002057-A	< 1	FT-82016-002057-B	< 1
4	WALKER-JONES EDUCATIONAL CAMPUS	WS-002058	8/15/2016	1	Fountain	In classroom 105	FT-82016-002058-A	< 1	FT-82016-002058-B	< 1
5	WALKER-JONES EDUCATIONAL CAMPUS	WS-002062	8/15/2016	1	Fountain	In classroom 106	FT-82016-002062-A	< 1	FT-82016-002062-B	< 1
6	WALKER-JONES EDUCATIONAL CAMPUS	WS-002063	8/15/2016	1	Fountain	In classroom 108	FT-82016-002063-A	< 1	FT-82016-002063-B	< 1
7	WALKER-JONES EDUCATIONAL CAMPUS	WS-002065	8/15/2016	1	Cooler	In hallway adjacent to restroom 111 High Left	FT-82016-002065-A	< 1	FT-82016-002065-B	< 1
8	WALKER-JONES EDUCATIONAL CAMPUS	WS-002066	8/15/2016	1	Cooler	In hallway adjacent to restroom 111 Low Right	FT-82016-002066-A	< 1	FT-82016-002066-B	< 1
9	WALKER-JONES EDUCATIONAL CAMPUS	WS-002067	8/15/2016 10/10/2016	1	Fountain	In staff lounge 112	FT-82016-002067-A Re-test A	1.4 < 1	FT-82016-002067-B Re-test B	< 1 < 1
10	WALKER-JONES EDUCATIONAL CAMPUS	WS-002070	8/15/2016	1	Fountain	In classroom 115	FT-82016-002070-A	< 1	FT-82016-002070-B	< 1
11	WALKER-JONES EDUCATIONAL CAMPUS	WS-002072	8/15/2016	1	Fountain	In classroom 120 Right	FT-82016-002072-A	< 1	FT-82016-002072-B	< 1
12	WALKER-JONES EDUCATIONAL CAMPUS	WS-002074	8/15/2016	1	Fountain	In classroom 122	FT-82016-002074-A	< 1	FT-82016-002074-B	< 1
13	WALKER-JONES EDUCATIONAL CAMPUS	WS-002075	8/15/2016	1	Fountain	In classroom 117	FT-82016-002075-A	< 1	FT-82016-002075-B	< 1
14	WALKER-JONES EDUCATIONAL CAMPUS	WS-002078	8/15/2016	1	Fountain	In classroom 119	FT-82016-002078-A	< 1	FT-82016-002078-B	< 1
15	WALKER-JONES EDUCATIONAL CAMPUS	WS-002080	8/15/2016	1	Fountain	In classroom 128	FT-82016-002080-A	< 1	FT-82016-002080-B	< 1
16	WALKER-JONES EDUCATIONAL CAMPUS	WS-002081	8/15/2016	1	Fountain	In classroom 126	FT-82016-002081-A	< 1	FT-82016-002081-B	< 1
17	WALKER-JONES EDUCATIONAL CAMPUS	WS-002083	8/15/2016	1	Fountain	In health suite 123A	FT-82016-002083-A	< 1	FT-82016-002083-B	< 1
18	WALKER-JONES EDUCATIONAL CAMPUS	WS-002084	8/15/2016	1	Health Suite	In health suite 123A	FT-82016-002084-A	< 1	FT-82016-002084-B	< 1
19	WALKER-JONES EDUCATIONAL CAMPUS	WS-002085	8/15/2016	Basement	Cooler	In hallway adjacent to room 041 High Left	FT-82016-002085-A	< 1	FT-82016-002085-B	< 1
20	WALKER-JONES EDUCATIONAL CAMPUS	WS-002086	8/15/2016	Basement	Cooler	In hallway adjacent to room 041 Low Right	FT-82016-002086-A	< 1	FT-82016-002086-B	< 1
21	WALKER-JONES EDUCATIONAL CAMPUS	WS-002088	8/15/2016	Basement	Fountain	In classroom 032	FT-82016-002088-A	< 1	FT-82016-002088-B	< 1
22	WALKER-JONES EDUCATIONAL CAMPUS	WS-002089	8/15/2016	Basement	Fountain	In classroom 034	FT-82016-002089-A	< 1	FT-82016-002089-B	< 1
23	WALKER-JONES EDUCATIONAL CAMPUS	WS-002092	8/15/2016	Basement	Fountain	In classroom 036	FT-82016-002092-A	< 1	FT-82016-002092-B	< 1
24	WALKER-JONES EDUCATIONAL CAMPUS	WS-002093	8/15/2016	Basement	Fountain	In training room 043	FT-82016-002093-A	< 1	FT-82016-002093-B	< 1
25	WALKER-JONES EDUCATIONAL CAMPUS	WS-002095	8/15/2016	2	Fountain	In library 230C	FT-82016-002095-A	< 1	FT-82016-002095-B	< 1
26	WALKER-JONES EDUCATIONAL CAMPUS	WS-002097	8/15/2016	2	Fountain	In classroom 227	FT-82016-002097-A	< 1	FT-82016-002097-B	< 1
27	WALKER-JONES EDUCATIONAL CAMPUS	WS-002100	8/15/2016	2	Fountain	In classroom 228	FT-82016-002100-A	< 1	FT-82016-002100-B	< 1
28	WALKER-JONES EDUCATIONAL CAMPUS	WS-002101	8/15/2016	2	Fountain	In classroom 226	FT-82016-002101-A	< 1	FT-82016-002101-B	< 1
29	WALKER-JONES EDUCATIONAL CAMPUS	WS-002103	8/15/2016	2	Fountain	In classroom 221	FT-82016-002103-A	< 1	FT-82016-002103-B	< 1
30	WALKER-JONES EDUCATIONAL CAMPUS	WS-002106	8/15/2016	2	Fountain	In classroom 224	FT-82016-002106-A	< 1	FT-82016-002106-B	< 1
31	WALKER-JONES EDUCATIONAL CAMPUS	WS-002107	8/15/2016	2	Fountain	In classroom 219	FT-82016-002107-A	< 1	FT-82016-002107-B	< 1
32	WALKER-JONES EDUCATIONAL CAMPUS	WS-002110	8/15/2016	2	Fountain	In classroom 222	FT-82016-002110-A	< 1	FT-82016-002110-B	< 1
33	WALKER-JONES EDUCATIONAL CAMPUS	WS-002111	8/15/2016	2	Fountain	In classroom 217	FT-82016-002111-A	< 1	FT-82016-002111-B	< 1
34	WALKER-JONES EDUCATIONAL CAMPUS	WS-002113	8/15/2016	2	Fountain	In classroom 220	FT-82016-002113-A	< 1	FT-82016-002113-B	< 1
35	WALKER-JONES EDUCATIONAL CAMPUS	WS-002115	8/15/2016	2	Cooler	In hallway across from room 212 High Left	FT-82016-002115-A	< 1	FT-82016-002115-B	< 1
36	WALKER-JONES EDUCATIONAL CAMPUS	WS-002116	8/15/2016	2	Cooler	In hallway across from room 212 Low Right	FT-82016-002116-A	< 1	FT-82016-002116-B	< 1
37	WALKER-JONES EDUCATIONAL CAMPUS	WS-002117	8/15/2016	2	Fountain	In classroom 212 Right	FT-82016-002117-A	< 1	FT-82016-002117-B	< 1
38	WALKER-JONES EDUCATIONAL CAMPUS	WS-002119	8/15/2016	2	Fountain	In classroom 205 Right	FT-82016-002119-A	< 1	FT-82016-002119-B	< 1
39	WALKER-JONES EDUCATIONAL CAMPUS	WS-002121**	8/15/2016 8/20/2016	2	Fountain	In classroom 210 Right	FT-82016-002121-A Re-test A	26.9 < 1	FT-82016-002121-B Re-test B	< 1 < 1
40	WALKER-JONES EDUCATIONAL CAMPUS	WS-002123	8/15/2016	2	Fountain	In classroom 203	FT-82016-002123-A	< 1	FT-82016-002123-B	< 1
41	WALKER-JONES EDUCATIONAL CAMPUS	WS-002125	8/15/2016 10/10/2016	2	Fountain	In classroom 208 Right	FT-82016-002125-A Re-test A	3.7 < 1	FT-82016-002125-B Re-test B	< 1 < 1
42	WALKER-JONES EDUCATIONAL CAMPUS	WS-002127	8/15/2016	2	Fountain	In classroom 201	FT-82016-002127-A	< 1	FT-82016-002127-B	< 1
43	WALKER-JONES EDUCATIONAL CAMPUS	WS-002130	8/15/2016	2	Fountain	In classroom 206	FT-82016-002130-A	< 1	FT-82016-002130-B	< 1
44	WALKER-JONES EDUCATIONAL CAMPUS	WS-002131	8/15/2016	3	Cooler	In hallway across from room 312 High Left	FT-82016-002131-A	< 1	FT-82016-002131-B	< 1
45	WALKER-JONES EDUCATIONAL CAMPUS	WS-002132	8/15/2016	3	Cooler	In hallway across from room 312 Low Right	FT-82016-002132-A	< 1	FT-82016-002132-B	< 1

46	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002133	8/15/2016	3	Fountain	In classroom 300	FT-82016-002133-A	< 1	FT-82016-002133-B	< 1
47	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002135	8/15/2016	3	Fountain	In science lab room 310 first clockwise from entry door Right	FT-82016-002135-A	< 1	FT-82016-002135-B	< 1
49	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002137	8/15/2016	3	Fountain	In science lab room 310 second clockwise from entry door Right	FT-82016-002137-A	< 1	FT-82016-002137-B	< 1
50	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002140	8/15/2016	3	Fountain	In science lab room 310 third clockwise from entry door Right	FT-82016-002140-A	< 1	FT-82016-002140-B	< 1
51	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002141	8/15/2016	3	Fountain	In science lab room 320 first clockwise from north entry door	FT-82016-002141-A	< 1	FT-82016-002141-B	< 1
52	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002143	8/15/2016	3	Fountain	In science lab room 320 second clockwise from north entry door	FT-82016-002143-A	< 1	FT-82016-002143-B	< 1
53	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002146	8/15/2016	3	Fountain	In science lab room 320 third clockwise from north entry door	FT-82016-002146-A	< 1	FT-82016-002146-B	< 1
54	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002148	8/15/2016	3	Fountain	In science lab room 320 fourth clockwise from north entry door	FT-82016-002148-A	< 1	FT-82016-002148-B	< 1
55	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002149	8/15/2016	3	Fountain	In science lab room 324 first clockwise from north entry door	FT-82016-002149-A	< 1	FT-82016-002149-B	< 1
56	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002151	8/15/2016	3	Fountain	In science lab room 324 second clockwise from north entry door	FT-82016-002151-A	< 1	FT-82016-002151-B	< 1
57	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002153	8/15/2016	3	Fountain	In science lab room 324 third clockwise from north entry door	FT-82016-002153-A	< 1	FT-82016-002153-B	< 1
58	WALKER-JONES EDUCATIONAL CAMPUS	WS- 002155	8/15/2016	3	Fountain	In science lab room 320A	FT-82016-002155-A	< 1	FT-82016-002155-B	< 1
59	WALKER-JONES EDUCATIONAL CAMPUS	WS- 006082	8/15/2016	1	Fountain	In welcome center 115	FT-82016-006082-A	< 1	FT-82016-006082-B	< 1
60	WALKER-JONES EDUCATIONAL CAMPUS	WS- 006084	8/15/2016	2	Fountain	In classroom 227	FT-82016-006084-A	< 1	FT-82016-006084-B	< 1
61	WALKER-JONES EDUCATIONAL CAMPUS	WS- 006085	8/15/2016	2	Classroom Faucet	In conference room 214A	FT-82016-006085-A	< 1	FT-82016-006085-B	< 1
62	WALKER-JONES EDUCATIONAL CAMPUS	WS- 006086	8/15/2016	2	Fountain	In conference room 214A	FT-82016-006086-A	< 1	FT-82016-006086-B	< 1

\*\*Filter inspected, found improperly installed, repaired, and re-sampled.