



WALKER-JONES EC LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	WALKER-JONES EC	5/3/2016	WS- 002158	Classroom	3	In classroom 325	Left	WT-042916-2175- A	< 1	WT-042916-2175- B	< 1				
2	WALKER-JONES EC	5/3/2016	WS- 002157	Classroom	3	In room 320	Left	WT-042916-2174- A	< 1	WT-042916-2174- B	< 1				
3	WALKER-JONES EC	5/3/2016	WS- 002156	Classroom	3	In classroom 325	Right	WT-042916-2173- A	< 1	WT-042916-2173- B	< 1				
4	WALKER-JONES EC	5/3/2016	WS- 002155	Fountain	3	In room 320	Right	WT-042916-2172- A	2.6	WT-042916-2172- B	< 1				
5	WALKER-JONES EC	5/3/2016	WS- 002154	Classroom	3	In classroom 324	Mid	WT-042916-2171- A	5.1	WT-042916-2171- B	< 1				
6	WALKER-JONES EC	5/3/2016	WS- 002153	Fountain	3	In classroom 324	Right	WT-042916-2170- A	2.2	WT-042916-2170- B	< 1				
7	WALKER-JONES EC	5/3/2016	WS- 002152	Classroom	3	In room 324	Left	WT-042916-2169- A	< 1	WT-042916-2169- B	< 1				
8	WALKER-JONES EC	5/3/2016	WS- 002151	Fountain	3	In room 324	Right	WT-042916-2168- A	< 1	WT-042916-2168- B	< 1				
9	WALKER-JONES EC	5/3/2016	WS- 002150	Classroom	3	In classroom 324	Left	WT-042916-2167- A	< 1	WT-042916-2167- B	< 1				
10	WALKER-JONES EC	5/3/2016	WS- 002149	Fountain	3	In classroom 324	Right	WT-042916-2166- A	1	WT-042916-2166- B	< 1				
11	WALKER-JONES EC	5/3/2016	WS- 002148	Fountain	3	In room 320	Right	WT-042916-2165- A	4	WT-042916-2165- B	< 1				
12	WALKER-JONES EC	5/3/2016	WS- 002147	Classroom	3	In room 320	Left	WT-042916-2164- A	7.2	WT-042916-2164- B	1.1				
13	WALKER-JONES EC	5/3/2016	WS- 002146	Fountain	3	In room 320	Right	WT-042916-2163- A	< 1	WT-042916-2163- B	< 1				
14	WALKER-JONES EC	5/3/2016	WS- 002145	Classroom	3	In room 320	Left	WT-042916-2162- A	15.4	WT-042916-2162- B	< 1	Filtered	6/16/2016	1.8	<1
15	WALKER-JONES EC	5/3/2016	WS- 002144	Classroom	3	In room 320	Left	WT-042916-2161- A	13.3	WT-042916-2161- B	< 1				
16	WALKER-JONES EC	5/3/2016	WS- 002143	Fountain	3	In room 320	Right	WT-042916-2160- A	5.8	WT-042916-2160- B	1.1				
17	WALKER-JONES EC	5/3/2016	WS- 002142	Classroom	3	In room 320	Left	WT-042916-2159- A	7.1	WT-042916-2159- B	1.6				
18	WALKER-JONES EC	5/3/2016	WS- 002141	Fountain	3	In room 320	Right	WT-042916-2158- A	4.6	WT-042916-2158- B	< 1				
19	WALKER-JONES EC	5/3/2016	WS- 002140	Fountain	3	In room 310	Right	WT-042916-2157- A	89.6	WT-042916-2157- B	2.6	Filtered	6/16/2016	4.1	1.2
20	WALKER-JONES EC	5/3/2016	WS- 002139	Classroom	3	In room 310	Left	WT-042916-2156- A	4.1	WT-042916-2156- B	1.9				
21	WALKER-JONES EC	5/3/2016	WS- 002138	Classroom	3	In classroom 310	Left	WT-042916-2155- A	269	WT-042916-2155- B	13.4	Filtered	6/16/2016	<1	1.0
22	WALKER-JONES EC	5/3/2016	WS- 002137	Fountain	3	In classroom 310	Right	WT-042916-2154- A	29.8	WT-042916-2154- B	2.9	Filtered	6/16/2016	2.3	<1
23	WALKER-JONES EC	5/3/2016	WS- 002136	Classroom	3	In classroom 310	Left	WT-042916-2153- A	452	WT-042916-2153- B	12	Filtered	6/16/2016	1.3	<1
24	WALKER-JONES EC	5/3/2016	WS- 002135	Fountain	3	In classroom 310	Right	WT-042916-2152- A	168	WT-042916-2152- B	9.7	Filtered	6/16/2016	7.7	3.4
25	WALKER-JONES EC	5/3/2016	WS- 002134	Classroom	3	In classroom 300	Left	WT-042916-2151- A	< 1	WT-042916-2151- B	< 1				
26	WALKER-JONES EC	5/3/2016	WS- 002133	Fountain	3	In classroom 300	Right	WT-042916-2150- A	< 1	WT-042916-2150- B	< 1				



WALKER-JONES EC LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location			1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
27	WALKER-JONES EC	5/3/2016	WS- 002132	Fountain	3	in hallway adjacent to room 309	Right	Low	WT-042916-2149- A	< 1	WT-042916-2149- B	< 1				
28	WALKER-JONES EC	5/3/2016	WS- 002131	Cooler	3	In hallway adjacent to room 312	Left	High	WT-042916-2148- A	< 1	WT-042916-2148- B	< 1				
29	WALKER-JONES EC	5/3/2016	WS- 002130	Fountain	2	In classroom 206	Left		WT-042916-2147- A	< 1	WT-042916-2147- B	< 1				
30	WALKER-JONES EC	5/3/2016	WS- 002129	Classroom	2	In classroom 206	Right		WT-042916-2146- A	< 1	WT-042916-2146- B	< 1				
31	WALKER-JONES EC	5/3/2016	WS- 002128	Classroom	2	In classroom 201	Left		WT-042916-2145- A	< 1	WT-042916-2145- B	< 1				
32	WALKER-JONES EC	5/3/2016	WS- 002127	Fountain	2	In classroom 201	Right		WT-042916-2144- A	< 1	WT-042916-2144- B	1				
33	WALKER-JONES EC	5/3/2016	WS- 002126	Classroom	2	In classroom 208	Left		WT-042916-2143- A	1.1	WT-042916-2143- B	< 1				
34	WALKER-JONES EC	5/3/2016	WS- 002125	Fountain	2	In classroom 208	Right		WT-042916-2142- A	3.3	WT-042916-2142- B	< 1				
35	WALKER-JONES EC	5/3/2016	WS- 002124	Classroom	2	In classroom 203	Left		WT-042916-2141- A	< 1	WT-042916-2141- B	< 1				
36	WALKER-JONES EC	5/3/2016	WS- 002123	Fountain	2	In classroom 203	Right		WT-042916-2140- A	< 1	WT-042916-2140- B	< 1				
37	WALKER-JONES EC	5/3/2016	WS- 002122	Classroom	2	In classroom 210	Left		WT-042916-2139- A	< 1	WT-042916-2139- B	< 1				
38	WALKER-JONES EC	5/3/2016	WS- 002121	Fountain	2	In classroom 210	Right		WT-042916-2138- A	< 1	WT-042916-2138- B	1				
39	WALKER-JONES EC	5/3/2016	WS- 002118	Classroom	2	In classroom 212	Left		WT-042916-2135- A	< 1	WT-042916-2135- B	< 1				
40	WALKER-JONES EC	5/3/2016	WS- 002117	Fountain	2	In classroom 212	Right		WT-042916-2134- A	1	WT-042916-2134- B	< 1				
41	WALKER-JONES EC	5/3/2016	WS- 002116	Fountain	2	In hallway adjacent to classroom 209	Left		WT-042916-2133- A	< 1	WT-042916-2133- B	< 1				
42	WALKER-JONES EC	5/3/2016	WS- 002115	Fountain	2	In hallway adjacent to Classroom 209	Right		WT-042916-2132- A	< 1	WT-042916-2132- B	< 1				
43	WALKER-JONES EC	5/3/2016	WS- 002114	Classroom	2	In classroom 220	Left		WT-042916-2131- A	< 1	WT-042916-2131- B	< 1				
44	WALKER-JONES EC	5/3/2016	WS- 002113	Fountain	2	In classroom 220	Right		WT-042916-2130- A	1.3	WT-042916-2130- B	< 1				
45	WALKER-JONES EC	5/3/2016	WS- 002112	Classroom	2	In classroom 217	Mid		WT-042916-2129- A	< 1	WT-042916-2129- B	< 1				
46	WALKER-JONES EC	5/3/2016	WS- 002111	Fountain	2	In classroom 217	Right		WT-042916-2128- A	< 1	WT-042916-2128- B	< 1				
47	WALKER-JONES EC	5/3/2016	WS- 002110	Fountain	2	In classroom 222	Right		WT-042916-2127- A	< 1	WT-042916-2127- B	< 1				
48	WALKER-JONES EC	5/3/2016	WS- 002109	Classroom	2	In classroom 222	Left		WT-042916-2126- A	< 1	WT-042916-2126- B	< 1				
49	WALKER-JONES EC	5/3/2016	WS- 002108	Classroom	2	In classroom 219	Mid		WT-042916-2125- A	3.5	WT-042916-2125- B	< 1				
50	WALKER-JONES EC	5/3/2016	WS- 002107	Fountain	2	In classroom 219	Right		WT-042916-2124- A	< 1	WT-042916-2124- B	< 1				
51	WALKER-JONES EC	5/3/2016	WS- 002106	Fountain	2	In classroom 224	Right		WT-042916-2123- A	< 1	WT-042916-2123- B	< 1				
52	WALKER-JONES EC	5/3/2016	WS- 002105	Classroom	2	In classroom 224	Left		WT-042916-2122- A	< 1	WT-042916-2122- B	< 1				



WALKER-JONES EC LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
53	WALKER-JONES EC	5/3/2016	WS- 002104	Classroom	2	In Classroom 221 Mid	WT-042916-2121- A	< 1	WT-042916-2121- B	< 1				
54	WALKER-JONES EC	5/3/2016	WS- 002103	Fountain	2	In Classroom 221 Right	WT-042916-2120- A	< 1	WT-042916-2120- B	< 1				
55	WALKER-JONES EC	5/3/2016	WS- 002102	Classroom	2	In Classroom 226 Left	WT-042916-2119- A	< 1	WT-042916-2119- B	< 1				
56	WALKER-JONES EC	5/3/2016	WS- 002101	Fountain	2	In classroom 226 Right	WT-042916-2118- A	< 1	WT-042916-2118- B	< 1				
57	WALKER-JONES EC	5/3/2016	WS- 002100	Fountain	2	In classroom 226 Right	WT-042916-2117- A	5.7	WT-042916-2117- B	< 1				
58	WALKER-JONES EC	5/3/2016	WS- 002099	Classroom	2	In classroom 226 Left	WT-042916-2116- A	< 1	WT-042916-2116- B	5.2				
59	WALKER-JONES EC	5/3/2016	WS- 002098	Classroom	2	In classroom 227 Left	WT-042916-2115- A	< 1	WT-042916-2115- B	< 1				
60	WALKER-JONES EC	5/3/2016	WS- 002097	Fountain	2	In classroom 227 Right	WT-042916-2114- A	1.5	WT-042916-2114- B	< 1				
61	WALKER-JONES EC	5/3/2016	WS- 002096	Classroom	2	In classroom 230C Mid High	WT-042916-2113- A	2.6	WT-042916-2113- B	< 1				
62	WALKER-JONES EC	5/3/2016	WS- 002095	Fountain	2	In classroom 230C Right	WT-042916-2112- A	< 1	WT-042916-2112- B	< 1				
63	WALKER-JONES EC	5/3/2016	WS- 002094	Classroom	Basement	In Training room 043 Mid	WT-042916-2111- A	1.3	WT-042916-2111- B	3.5				
64	WALKER-JONES EC	5/3/2016	WS- 002093	Fountain	Basement	In Training room 043 Right	WT-042916-2110- A	2.2	WT-042916-2110- B	11.8				
65	WALKER-JONES EC	5/3/2016	WS- 002092	Fountain	Basement	In classroom 036 Right	WT-042916-2109- A	4.3	WT-042916-2109- B	< 1				
66	WALKER-JONES EC	5/3/2016	WS- 002091	Classroom	Basement	In classroom 036 Left	WT-042916-2108- A	< 1	WT-042916-2108- B	< 1				
67	WALKER-JONES EC	5/3/2016	WS- 002090	Classroom	Basement	In Classroom 034 Mid	WT-042916-2107- A	< 1	WT-042916-2107- B	< 1				
68	WALKER-JONES EC	5/3/2016	WS- 002089	Fountain	Basement	In Classroom 034	WT-042916-2106- A	3	WT-042916-2106- B	< 1				
69	WALKER-JONES EC	5/3/2016	WS- 002088	Fountain	Basement	In classroom 032 Left	WT-042916-2105- A	< 1	WT-042916-2105- B	< 1				
70	WALKER-JONES EC	5/3/2016	WS- 002087	Classroom	Basement	In classroom 032 Left	WT-042916-2104- A	1	WT-042916-2104- B	1.4				
71	WALKER-JONES EC	5/3/2016	WS- 002086	Fountain	Basement	In hallway Adjacent to room 041 Mid	WT-042916-2103- A	< 1	WT-042916-2103- B	< 1				
72	WALKER-JONES EC	5/3/2016	WS- 002085	Fountain	Basement	In hallway adjacent to room 041 Mid	WT-042916-2102- A	< 1	WT-042916-2102- B	< 1				
73	WALKER-JONES EC	5/3/2016	WS- 002084	Health Suite	1	In health suite 123A Left	WT-042916-2101- A	< 1	WT-042916-2101- B	< 1				
74	WALKER-JONES EC	5/3/2016	WS- 002083	Fountain	1	In health suite 123A Right	WT-042916-2100- A	< 1	WT-042916-2100- B	< 1				
75	WALKER-JONES EC	5/3/2016	WS- 002082	Fountain	1	In Classroom 126 Mid	WT-042916-2099- A	2	WT-042916-2099- B	< 1				
76	WALKER-JONES EC	5/3/2016	WS- 002081	Fountain	1	In classroom 126 Right	WT-042916-2098- A	1.7	WT-042916-2098- B	< 1				
77	WALKER-JONES EC	5/3/2016	WS- 002080	Fountain	1	In classroom 128 Right	WT-042916-2097- A	< 1	WT-042916-2097- B	< 1				
78	WALKER-JONES EC	5/3/2016	WS- 002079	Classroom	1	In classroom 128 Left	WT-042916-2096- A	3.5	WT-042916-2096- B	< 1				



WALKER-JONES EC LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
79	WALKER-JONES EC	5/3/2016	WS- 002078	Fountain	1	In classroom 119 Right Low	WT-042916-2095- A	< 1	WT-042916-2095- B	< 1				
80	WALKER-JONES EC	5/3/2016	WS- 002077	Fountain	1	In classroom 119 Mid	WT-042916-2094- A	< 1	WT-042916-2094- B	< 1				
81	WALKER-JONES EC	5/3/2016	WS- 002076	Classroom	1	In classroom 117 Left	WT-042916-2093- A	< 1	WT-042916-2093- B	< 1				
82	WALKER-JONES EC	5/3/2016	WS- 002075	Fountain	1	In classroom 117 Right	WT-042916-2092- A	< 1	WT-042916-2092- B	< 1				
83	WALKER-JONES EC	5/3/2016	WS- 002074	Fountain	1	In classroom 122 Right	WT-042916-2091- A	< 1	WT-042916-2091- B	< 1				
84	WALKER-JONES EC	5/3/2016	WS- 002073	Classroom	1	In classroom 122 Left	WT-042916-2090- A	< 1	WT-042916-2090- B	< 1				
85	WALKER-JONES EC	5/3/2016	WS- 002072	Fountain	1	In classroom 120 Right	WT-042916-2089- A	87.3	WT-042916-2089- B	< 1	Filtered	6/16/2016	1.2	<1
86	WALKER-JONES EC	5/3/2016	WS- 002071	Classroom	1	In classroom 120 Left	WT-042916-2088- A	< 1	WT-042916-2088- B	< 1				
87	WALKER-JONES EC	5/3/2016	WS- 002070	Fountain	1	In classroom 115 Right	WT-042916-2087- A	< 1	WT-042916-2087- B	< 1				
88	WALKER-JONES EC	5/3/2016	WS- 002069	Classroom	1	In classroom 115 Left	WT-042916-2086- A	3.7	WT-042916-2086- B	< 1				
89	WALKER-JONES EC	5/3/2016	WS- 002068	Classroom	1	In room 112 Left	WT-042916-2085- A	< 1	WT-042916-2085- B	< 1				
90	WALKER-JONES EC	5/3/2016	WS- 002067	Fountain	1	In room 112 Right	WT-042916-2084- A	< 1	WT-042916-2084- B	< 1				
91	WALKER-JONES EC	5/3/2016	WS- 002066	Cooler	1	In hallway adjacent to room 11 Right Low	WT-042916-2083- A	< 1	WT-042916-2083- B	< 1				
92	WALKER-JONES EC	5/3/2016	WS- 002065	Cooler	1	In hallway adjacent to room 11 Left High	WT-042916-2082- A	< 1	WT-042916-2082- B	< 1				
93	WALKER-JONES EC	5/3/2016	WS- 002064	Classroom	1	In classroom 108 Mid	WT-042916-2081- A	< 1	WT-042916-2081- B	< 1				
94	WALKER-JONES EC	5/3/2016	WS- 002063	Fountain	1	In classroom 108 Right	WT-042916-2080- A	< 1	WT-042916-2080- B	< 1				
95	WALKER-JONES EC	5/3/2016	WS- 002062	Fountain	1	In classroom 106 Right	WT-042916-2079- A	< 1	WT-042916-2079- B	< 1				
96	WALKER-JONES EC	5/3/2016	WS- 002061	Classroom	1	In classroom 106 Left	WT-042916-2078- A	< 1	WT-042916-2078- B	< 1				
97	WALKER-JONES EC	5/3/2016	WS- 002060	Classroom	1	In class room 103 Left	WT-042916-2077- A	< 1	WT-042916-2077- B	< 1				
98	WALKER-JONES EC	5/3/2016	WS- 002059	Classroom	1	In classroom 105 Right	WT-042916-2076- A	< 1	WT-042916-2076- B	< 1				
99	WALKER-JONES EC	5/3/2016	WS- 002058	Fountain	1	In classroom 105 Right	WT-042916-2075- A	< 1	WT-042916-2075- B	< 1				
100	WALKER-JONES EC	5/3/2016	WS- 002057	Fountain	1	In classroom 103 Right	WT-042916-2074- A	< 1	WT-042916-2074- B	< 1				
101	WALKER-JONES EC	5/3/2016	WS- 002056	Classroom	1	In classroom 104 Mid Low	WT-042916-2073- A	< 1	WT-042916-2073- B	< 1				
102	WALKER-JONES EC	5/3/2016	WS- 002055	Fountain	1	In class room 104 Right	WT-042916-2072- A	< 1	WT-042916-2072- B	< 1				
103	WALKER-JONES EC	5/3/2016	WS- 002054	Kitchen	1	In kitchen south wall (spray nozzle) Right	WT-042916-2071- A	1.3	WT-042916-2071- B	< 1				
104	WALKER-JONES EC	5/3/2016	WS- 002053	Kitchen	1	In kitchen south wall Mid	WT-042916-2070- A	< 1	WT-042916-2070- B	< 1				



WALKER-JONES EC LEAD WATER TEST RESULTS

May 11th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
105	WALKER-JONES EC	5/3/2016	WS- 002052	Kitchen	1	In kitchen south wall Left	WT-042916-2069- A	< 1	WT-042916-2069- B	< 1				
106	WALKER-JONES EC	5/3/2016	WS- 002051	Other	1	In kitchen ice machine next to room 101E	WT-042916-2068- A	< 1	WT-042916-2068- B	< 1				
107	WALKER-JONES EC	5/3/2016	WS- 002050	Kitchen	1	In kitchen east wall Left	WT-042916-2067- A	< 1	WT-042916-2067- B	< 1				
108	WALKER-JONES EC	5/3/2016	WS- 002049	Utility	Basement	In room 051 main water supply line to the building NE corner (water source)	WT-042916-2066- A	68.8	WT-042916-2066- B	2.8	Not accessible to children			

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.