



# WASHINGTON METRO LEAD WATER TEST RESULTS

May 16th, 2016



| Building Location             | Sample Collected Date | Water Source ID | Device Type  | Floor    | Device Location                       | 1st Draw - Sample ID | Final Result - 1st Draw (ug/L) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ug/L) | Remediation                | Retest Date | Retest 1st Draw | Retest 2nd Draw |
|-------------------------------|-----------------------|-----------------|--------------|----------|---------------------------------------|----------------------|--------------------------------|----------------------|--------------------------------|----------------------------|-------------|-----------------|-----------------|
| 1 Washington Metropolitan HS  | 5/18/2016             | WS- 011962      | Utility      | Basement | In boiler room                        | WT-042916-11979- A   | 1.3                            | WT-042916-11979- B   | < 1                            |                            |             |                 |                 |
| 2 Washington Metropolitan HS  | 5/18/2016             | WS- 011963      | Classroom    | 1        | In classroom 106 Left                 | WT-042916-11980- A   | 860                            | WT-042916-11980- B   | 2.8                            | labeled "not for drinking" |             |                 |                 |
| 3 Washington Metropolitan HS  | 5/18/2016             | WS- 011964      | Classroom    | 1        | In classroom 106 Right                | WT-042916-11981- A   | 35                             | WT-042916-11981- B   | 3.9                            | labeled "not for drinking" |             |                 |                 |
| 4 Washington Metropolitan HS  | 5/18/2016             | WS- 011965      | Classroom    | 1        | In classroom 103 Left                 | WT-042916-11982- A   | 47                             | WT-042916-11982- B   | 9.2                            | labeled "not for drinking" |             |                 |                 |
| 5 Washington Metropolitan HS  | 5/18/2016             | WS- 011966      | Classroom    | 1        | In classroom 103 Right                | WT-042916-11983- A   | 150                            | WT-042916-11983- B   | 10                             | labeled "not for drinking" |             |                 |                 |
| 6 Washington Metropolitan HS  | 5/18/2016             | WS- 011967      | Cooler       | 1        | In hallway adjacent to men's restroom | WT-042916-11984- A   | < 1                            | WT-042916-11984- B   | < 1                            |                            |             |                 |                 |
| 7 Washington Metropolitan HS  | 5/18/2016             | WS- 011968      | Cooler       | 1        | In hallway adjacent to classroom 106  | WT-042916-11985- A   | < 1                            | WT-042916-11985- B   | < 1                            |                            |             |                 |                 |
| 8 Washington Metropolitan HS  | 5/18/2016             | WS- 011969      | Other        | 1        | In kitchen ( ice maker )              | WT-042916-11986- A   | 1.4                            | WT-042916-11986- B   | 1.7                            |                            |             |                 |                 |
| 9 Washington Metropolitan HS  | 5/18/2016             | WS- 011970      | Kitchen      | 1        | In kitchen Left                       | WT-042916-11987- A   | < 1                            | WT-042916-11987- B   | < 1                            |                            |             |                 |                 |
| 10 Washington Metropolitan HS | 5/18/2016             | WS- 011971      | Other        | 1        | In kitchen (spray nozzle)             | WT-042916-11988- A   | 1.3                            | WT-042916-11988- B   | < 1                            |                            |             |                 |                 |
| 11 Washington Metropolitan HS | 5/18/2016             | WS- 011972      | Kitchen      | 1        | In kitchen Right                      | WT-042916-11989- A   | < 1                            | WT-042916-11989- B   | < 1                            |                            |             |                 |                 |
| 12 Washington Metropolitan HS | 5/18/2016             | WS- 011973      | Cooler       | 2        | In hallway adjacent to men's restroom | WT-042916-11990- A   | < 1                            | WT-042916-11990- B   | < 1                            |                            |             |                 |                 |
| 13 Washington Metropolitan HS | 5/18/2016             | WS- 011974      | Cooler       | 2        | In hallway adjacent to room 210       | WT-042916-11991- A   | < 1                            | WT-042916-11991- B   | < 1                            |                            |             |                 |                 |
| 14 Washington Metropolitan HS | 5/18/2016             | WS- 011975      | Cooler       | 3        | In hallway adjacent to room 312       | WT-042916-11992- A   | < 1                            | WT-042916-11992- B   | < 1                            |                            |             |                 |                 |
| 15 Washington Metropolitan HS | 5/18/2016             | WS- 011976      | Cooler       | 3        | In hallway adjacent to room 303       | WT-042916-11993- A   | < 1                            | WT-042916-11993- B   | < 1                            |                            |             |                 |                 |
| 16 Washington Metropolitan HS | 5/18/2016             | WS- 011977      | Classroom    | 3        | In classroom 302 Right                | WT-042916-11994- A   | 3.6                            | WT-042916-11994- B   | 3                              |                            |             |                 |                 |
| 17 Washington Metropolitan HS | 5/18/2016             | WS- 011978      | Classroom    | 3        | In classroom 302 Left                 | WT-042916-11995- A   | < 1                            | WT-042916-11995- B   | 3.1                            |                            |             |                 |                 |
| 18 Washington Metropolitan HS | 5/18/2016             | WS- 011979      | Other        | 1        | In nurses office (ice maker)          | WT-042916-11996- A   | < 1                            | WT-042916-11996- B   | < 1                            |                            |             |                 |                 |
| 19 Washington Metropolitan HS | 5/18/2016             | WS- 011980      | Fountain     | 1        | In nurses office                      | WT-042916-11997- A   | 31                             | WT-042916-11997- B   | 8.6                            | Filtered                   | 7/1/2016    | <1              | <1              |
| 20 Washington Metropolitan HS | 5/18/2016             | WS- 011981      | Health Suite | 1        | In nurses office                      | WT-042916-11998- A   | < 1                            | WT-042916-11998- B   | < 1                            |                            |             |                 |                 |

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.