



Washington Metropolitan HS Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011967	4/30/2018	4/30/2019	1	Cooler	In hallway adjacent to boys' restroom	WF-04302018-011967	1/6/2019	FT-FY19-122018-011967-A	<1	FT-FY19-122018-011967-B	<1
WS- 011968	4/30/2018	4/30/2019	1	Cooler	In hallway adjacent to room 106	WF-04302018-011968	1/6/2019	FT-FY19-122018-011968-A	<1	FT-FY19-122018-011968-B	<1
WS- 011973	9/14/2018	9/14/2019	2	Cooler	In hallway adjacent to boys' restroom	WF-09142018-011973	1/6/2019	FT-FY19-122018-011973-A	<1	FT-FY19-122018-011973-B	<1
WS- 011974	4/30/2018	4/30/2019	2	Cooler	In hallway adjacent to room 210	WF-04302018-011974	1/6/2019	FT-FY19-122018-011974-A	<1	FT-FY19-122018-011974-B	<1
WS- 011975	4/30/2018	4/30/2019	3	Cooler	In hallway adjacent to room 312	WF-04302018-011975	1/6/2019	FT-FY19-122018-011975-A	<1	FT-FY19-122018-011975-B	<1
WS- 011976	4/30/2018	4/30/2019	3	Cooler	In hallway adjacent to room 303	WF-04302018-011976	1/6/2019	FT-FY19-122018-011976-A	<1	FT-FY19-122018-011976-B	<1
WS- 011981	4/30/2018	4/30/2019	1	Health Suite	In health suite in restroom	WF-04302018-011981	1/6/2019	FT-FY19-122018-011981-A	<1	FT-FY19-122018-011981-B	<1
WS- 011982	4/30/2018	4/30/2019	1	Cooler	In health suite	WF-04302018-011982	1/6/2019	FT-FY19-122018-011982-A	<1	FT-FY19-122018-011982-B	<1
WS- 011983	4/30/2018	5/1/2019	1	Cooler	In cafeteria	WF-04302018-011983	1/6/2019	FT-FY19-122018-011983-A	<1	FT-FY19-122018-011983-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011972	1	Food Prep Sink	In kitchen third clockwise from entry door Right	1/6/2019	FT-FY19-122018-011972-A	<1	FT-FY19-122018-011972-B	<1